

# Appendix I: Meeting Materials Only



City of Santa Cruz

**FINAL**  
**SANTA CRUZ REGIONAL RECYCLED WATER**  
**FACILITIES PLANNING STUDY**

*June 2018*

**Kennedy/Jenks Consultants**



**This Page Intentionally Blank**



## **Kennedy/Jenks Consultants**

303 Second Street, Suite 300 South  
San Francisco, California 94107  
415-243-2150  
FAX: 415-896-0999

---

# **FINAL City of Santa Cruz Regional Recycled Water Facilities Planning Study**

6 June 2018

Prepared for

**City of Santa Cruz**  
212 Locust Street, Suite C  
Santa Cruz, CA 95060

K/J Project No. 1668007.00



*Note to Reader:*

*The Draft RWFPS was submitted to the SWRCB in September 2017, representing the City of Santa Cruz's decisions based on the understanding of regional projects, regulatory requirements and water supply conditions at that time. There have been and continue to be developments that influence the City's pursuit of recycled water, such as the Soquel Creek Water District finalizing aspects of their recycled water program and other regulatory milestones related to indirect and direct potable reuse. The City recognizes that some of the information in this document is no longer current, and that as regional projects and regulations evolve, future opportunities for reuse may also evolve. The City is committed to tracking the state of regulations and regional reuse programs in the future.*

## Acknowledgments

Funding for this plan has been provided in full or in part through an agreement with the State Water Resources Control Board. The contents of this document do not necessarily reflect the views and policies of the State Water Resources Control Board, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.



Prepared by

**Kennedy/Jenks Consultants**

Supported by



**Merritt Smith Consulting**



**Michael R. Welch, Ph.D., P.E.  
CONSULTING ENGINEER**





This Page Intentionally Blank



## Appendix I: Meeting Materials

---

Agendas and materials from the following meetings, workshops and webinars conducted with project partners during the study are included in this appendix.

Meeting/Workshop	Date	Focus
Kick-Off Meeting	03/30/16	Define study objectives, scope, roles and responsibilities.
Long-List Prelim Screening	06/28/16	Align on short-list of alternatives
Screening Criteria Webinar	08/29/16	Define alternative screening criteria
Alternative Webinar Part 1	10/18/16	Non-potable reuse alternative focus
Alternative Webinar Part 2	12/02/16	Potable reuse alternative focus (SWA/SFA/DPR)
Alternative Webinar Part 3	03/01/17	Beltz Wellfield IPR focus
Alternative Webinar Part 4	04/27/17	Regional IPR focus
Alternative Scoring and Ranking	06/01/17	Scoring and ranking outcomes
Recommended Facilities Plan	07/17/17	Align on recommended project



*This page intentionally blank.*





## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Kick-Off Meeting

**30 March 2016 from 9 am – 11 am**

Location: 809 Center St., Santa Cruz, CA 95060  
Planning Department Conference Room, Room 107

---

#### ATTENDEES:

Kennedy/Jenks - Dawn Taffler, Sachi Itagaki and Melanie Tan  
City of Santa Cruz - Heidi Luckenbach, David Kehn, Catherine Borrowman, Anne Hogan,  
Rosemary Menard, Eileen Cross, Dan Seidel, Mark Dettle, Mike Sanders, Amy Poncato  
Soquel Creek WD - Ron Duncan  
Scotts Valley WD - Piret Harmon  
Santa Cruz County - John Ricker, Kent Edler

#### AGENDA:

1. Introduction and Roles (All)
2. Background (City)
3. Overall project goals and expectations (All)
  - a. Meet SWRCB Grant Requirements
  - b. Assess beneficial reuse of wastewater from a resource recovery perspective
  - c. Evaluate local and regional recycled water projects
  - d. Identify near-term, mid-term and long-term projects
  - e. Meet schedule for WSAC Outcome Element #3 - Advanced Treated Recycled Water
  - f. Initiate strategy for continued outreach related to recycled water
  - g. Others?
4. Scope of Work (Tables 1, 2, and 3) (K/J)
5. RWFPS Schedule (Figure 1) (K/J)
6. Data Request (K/J)
7. Open Discussion (All)

#### ACTION ITEMS:

*\* Regional Recycled Water Study Driving Tour to Follow \**

### Kennedy/Jenks Consultants

\\sfocad\projects\pw-proj\2016\1668007.00\_santacruzrwfps\07-meetings\7.01\_mtg\_client\2016.03.30\_kickoff\meeting\_package\kickoffagenda\_santacruz\_rwfps\_03.30.2016.docx\sfocad\projects\pw-proj\2016\1668007.00\_santacruzrwfps\07-meetings\7.01\_mtg\_client\pre-kickoff\_santacruz\_rwfps\_03.02.2016.docx



**Table 1: Scope of Work – Tasks and Major Deliverables**

<b>Task</b>	<b>Regional RWFPS Chapter</b>	<b>Major Deliverables</b>
Task 1 - Project Management & QA/QC		Monthly Invoices, Status Reports, Schedule Updates, Project Work Plan
Task 2 - Background Information	Chapter 1 – Study Area Characteristics Chapter 2 – Water Supply Characteristics and Facilities	Data Request / Tracking Sheet Summary Tables/Figures
Task 3 - RW Market Analysis	Chapter 3 – Wastewater Characteristics and Facilities Chapter 5 – Recycled Water Market	Summary Tables/Figures Market Survey Map TM #1 Groundwater Replenishment TM #2 Surface Water Augmentation TM #3 Streamflow Augmentation TM #4 Direct Potable Reuse
Task 4 - Treatment Evaluation / Reg Requirements	Chapter 4 – Treatment Requirements for Discharge and Reuse	Summary Tables/Figures TM #5 Treatment Evaluation
Task 5 - Alternatives Analysis	Chapter 6 – Project Alternative Analysis	Summary Tables/Figures Screening Tables, Cost Tables
Task 6 – Stakeholder Involvement	Chapter 5 – Recycled Water Market	Materials as requested
Task 7 - Recommended Project	Chapter 7 – Recommended Facilities Project Plan	Summary Tables/Figures
Task 8 – Financial Analysis	Chapter 8 – Construction Financing Plan and Revenue Program	Summary Tables/Figures
Task 9 – Regional RWFPS Report		Admin Draft, SWRCB Draft, Final
Task 10 - Meetings and Workshops		Meeting Materials

**Subconsultants**

- Merritt Smith Consulting– Regulatory Strategy Support (Tasks 3, 5, 9 & 10)
- Data Instincts – Stakeholder Outreach (Tasks 6 & 10)
- Trussell Technologies – WWTF Facility/Supply Analysis, Treatment Technologies and QA/QC Support (Tasks 3, 4 & 10)
- Stratus Consulting/Abt Associates – Triple Bottom Line Analysis (Tasks 5 & 10)
- GHD Inc. – CEQA/Environmental Compliance Support (Task 5)
- Michael Welch, PhD. – Reservoir Augmentation (Task 3)

**Kennedy/Jenks Consultants**



**Table 2: Scope of Work - SubTasks and Budgets**

<b>Description</b>	<b>Total Budget</b>
<b>Task 1 - PM &amp; QA/QC</b>	
1.1 Project Management	\$ 20,216
1.2 Status Calls/Web Meetings	\$ 20,655
<b>Task 2 - Background Info</b>	
2.1 Data Collection	\$ 16,493
2.2 Background Info	\$ 6,508
<b>Task 3 - Recycled Water Market Analysis</b>	
3.1 WWTF Facility and Supply Analysis	\$ 10,540
3.2 Non Potable Reuse Market Analysis	\$ 15,249
3.3 Groundwater Recharge Reuse	\$ 16,838
3.4 Reservoir Augmentation	\$ 12,055
3.6 Streamflow Augmentation	\$ 8,473
3.7 Direct Potable Reuse Potential	\$ 22,253
<b>Task 4 - Treatment Evaluation/Regulatory Requirements</b>	
4.1 Water Quality and Regulatory Requirements	\$ 8,660
4.2 Treatment Evaluation	\$ 16,821
<b>Task 5 - Alternatives Analysis</b>	
5.1 Refine Long-List of Alternatives	\$ 14,610
5.2 Preliminary Screening	\$ 28,477
5.3 Evaluate Short List of Alternatives	\$ 51,091
5.4 Alternative Capital, O&M and Life Cycle Costs	\$ 16,493
<b>Task 6 - Stakeholder Involvement</b>	
6.1 Outreach Strategy and Advice	\$ 15,325
6.2 Outreach Materials and Support	\$ 14,825
<b>Task 7 - Recommended Project</b>	
7.1 Preliminary Facilities Design Criteria	\$ 13,648
7.2 Implementation Plan	\$ 7,630
<b>Task 8 - Financial Analysis</b>	
8.1 Anticipated Financing Plan	\$ 6,161
8.2 Revenue Projection Program	\$ 4,570
<b>Task 9 - Regional RWFPS Report</b>	
9.1 Admin Draft for City	\$ 33,290
9.2 SWRCB Draft	\$ 22,673
9.3 Final Report	\$ 17,577
<b>Task 10 - Meetings and Workshops</b>	
10.1 Face to Face Meetings	\$ 24,645
10.2 Workshops	\$ 24,381
10.3 Presentations	\$ 15,845
<b>Total =</b>	<b>\$ 486,000</b>

**Kennedy/Jenks Consultants**



**Table 3: Preliminary List of Recycled Water Projects**

Long-List of Projects	Recycled Water Use	Source Water	Treatment	Project Area(s)
1a	Industrial Use/ Landscape Irrigation	Santa Cruz WWTP	Tertiary	City, District and County
1b		Local Raw Wastewater	MBR Tertiary	UC Santa Cruz
2a	Irrigation	Santa Cruz WWTP	Tertiary	North Coast Agricultural Irrigation
2b		Santa Cruz WWTP -or- SVWD WWTP	Secondary or Tertiary	Pasatiempo + Other Landscape
2c		Santa Cruz WWTP	Tertiary	Landscape
3	Seawater Barrier	Santa Cruz WWTP	Advanced Treatment	Lower Groundwater Basins
4a	Groundwater Replenishment	Santa Cruz WWTP	Advanced Treatment	Upper/Lower Groundwater Basins
4b		Local Raw Wastewater	MBR + Advanced Treatment	
4c		Santa Cruz WWTP -and- SVWD WWTP	Advanced Treatment	Santa Margarita GW Basin
5	Reservoir Augmentation	Santa Cruz WWTP	Advanced Treatment	Loch Lomond Reservoir
6	Streamflow Augmentation	Santa Cruz WWTP	Tertiary or Advanced Treatment	San Lorenzo River
7	Direct Potable Reuse	Santa Cruz WWTP	Advanced Treatment	City, District and County

**Discussion:**



**Figure 1: Schedule**

Task and Key Deliverables	2016												2017										
	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	
SWRCB Grant Commitment Letter	✓																						
SWRCB Meeting					*											○							
Notice to Proceed				✓																			
Task 1 – PM & QA/QC				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 2 – Background Info				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 3 – Recycled Water Market Analysis				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 4 – Treatment Eval/Reg Requirements				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 5 – Alternatives Analysis				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 6 – Stakeholder Involvement				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 7 – Recommended Project				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 8 – Financial Analysis				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 9 – Regional RWFPS Report				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
Task 10 - Meetings and Workshops				)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)	)
					Kickoff			Long-List			Short-List		Recommended		Admin Draft		Draft				Final		

- \* SWRCB Scoping Call
- SWRCB Meeting
- F2F Meeting/Workshop
- ) Conf Call/Web
- ◆ Draft Deliverable
- ✓ Final Deliverable

**Kennedy/Jenks Consultants**



## Schedule for Water Supply Advisory Committee (WSAC) Outcome

### Element 3: Advanced Treated Recycled Water or Desalination (from WSAC)

- **Advanced Treated RW or Desalinated Water** = Supply augmentation plan to use advanced-treated recycled water with desalination as a back-up if advanced-treated recycled water is not feasible. Enacted if Strategy 1 proves insufficient to meet the plan's goals of cost-effectiveness, timeliness or yield.
  - 2016 = Identify RW alternatives, increase understanding of recycled water (regulatory framework, feasibility, funding opportunities, public outreach and education) \* **this is the RWFPS (Start in March 2016 – 18 months duration)**
  - 2017 = Complete high level feasibility studies, as-needed demonstration testing and conceptual level designs of alternatives; define CEQA processes and continue public outreach and education. Select preferred approach (i.e. DPR, IPR, desal) \* **this is the outcome of the RWFPS (end mid-2017)**
  - 2020 = Preliminary design, CEQA (including preparation of draft EIR) and apply for approvals and permits (except building permit)
  - 2022 = Complete property acquisition, final design , complete CEQA and all permits
  - 2024 = Construction completed: plant start-up, water production begins (milestone)

### Element 2: Aquifer Storage and Recovery (ASR)

- ASR will be studied in parallel to Element 3, using raw water sources
- **Nexus with the RWFPS**
  - Using recycled water for ASR may be beneficial if (1) there is not enough supply, (2) if the facilities have to be too large to meet the supply gap during the winter when the water is available or (3) if the ability of the basin to be actively recharged in the winter is insufficient
  - An ASR pilot could also be useful for assessing RW IPR
  - There may be overlap with WQ and geochemical analyses to meet both needs

# City of Santa Cruz Recycled Water Facilities Planning Study

Kick Off Meeting  
March 30 2016

1

## Agenda

- ▶ Introduction and Roles (All)
- ▶ Background (City, SqCWD, SVWD)
- ▶ Overall project goals and expectations (All)
- ▶ Scope of Work (Tables 1, 2, and 3) (K/J)
- ▶ RWFPS Schedule (Figure 1) (K/J)
- ▶ Data Request (K/J)
- ▶ Open Discussion (All)
- ▶ Driving Tour

2


# Background – Prior RW Studies

- ▶ **Fall 2013**
  - Contemplated as Regional Project; City and Soquel Creek co-applicants to SWRCB grant
- ▶ **Early 2014**
  - Agencies still thinking of doing joint project as the details of Water Supply Planning for each agency unfolded
- ▶ **WSAC April 2014 – October 2015**
- ▶ **Late 2014**
  - Decided to apply to SWRCB separately
- ▶ **Early 2015**
  - Did similar hiring process, interviewed together, hired different consultants, Soquel Creek nearing completion of their study
- ▶ **Early 2016 – Hired Kennedy/Jenks**
  - Deferred until conclusion of WSAC process

3

# Background – WSAC Outcome

Figure 12 Gantt Chart  
Implementation Plan and Timeline





## Background – Project Participants

- ▶ Joint project between Water & Public Works Departments
- ▶ Technical Working Group
- ▶ Regional Partners – Scotts Valley Water District & Soquel Creek Water District
- ▶ Other agency work (Scotts Valley/SqCWD)

5

### City of Santa Cruz Water System



Raw Water System & Rehab/Replacement Projects  
Santa Cruz Water Department

6


# Scotts Valley Water District

## Update on Recycled Water Activities

7

### Existing RW System

- Legend
- Pump
  - Tank
  - Pressure Main
  - Scotts Valley Water District
  - Existing Recycled Water Customers
  - Quarry Location



8

# Groundwater Replenishment



# Soquel Creek Water District

Update on Recycled Water Activities


## SqCWD – AWPR at SC WWTF



## SqCWD – AWPR at SqCWD



## SqCWD – MBR at SqCWD



# City of Santa Cruz Recycled Water Facilities Planning Study

## Overall Project Goals & Expectations

1. Meet SWRCB Grant Requirements
2. Assess beneficial reuse of wastewater from a resource recovery perspective
3. Evaluate local and regional recycled water projects
4. Identify near-term, mid-term and long-term projects
5. Meet schedule for WSAC Outcome Element #3 – Advanced Treated Recycled Water
6. Initiate strategy for continued outreach related to recycled water
7. Others?

15

## Scope of Work

Task	Regional RWFPS Chapter
Task 1 – Project Management & QA/QC	
Task 2 – Background Information	Chapter 1 – Study Area Characteristics Chapter 2 – Water Supply Characteristics and Facilities
Task 3 – RW Market Analysis	Chapter 3 – Wastewater Characteristics and Facilities Chapter 5 – Recycled Water Market
Task 4 – Treatment Evaluation / Reg Requirements	Chapter 4 – Treatment Requirements for Discharge and Reuse
Task 5 – Alternatives Analysis	Chapter 6 – Project Alternative Analysis
Task 6 – Stakeholder Involvement	Chapter 5 – Recycled Water Market
Task 7 – Recommended Project	Chapter 7 – Recommended Facilities Project Plan
Task 8 – Financial Analysis	Chapter 8 – Construction Financing Plan and Revenue Program
Task 9 – Regional RWFPS Report	
Task 10 – Meetings and Workshops	

RWFPS must meet SWRCB Grant Requirements

16

## Major Deliverables & Budget

Task	Major Deliverables	Total Budget
Task 1 – Project Management & QA/QC	Monthly Invoices, Status Reports, Schedule Updates, Project Work Plan	\$40,871
Task 2 – Background Information	Data Request / Tracking Sheet Summary Tables/Figures	\$23,001
Task 3 – RW Market Analysis	Summary Tables/Figures Market Survey Map TM #1 Groundwater Replenishment TM #2 Surface Water Augmentation TM #3 Streamflow Augmentation TM #4 Direct Potable Reuse	\$85,408
Task 4 – Treatment Evaluation / Reg Requirements	Summary Tables/Figures TM #5 Treatment Evaluation	\$25,481
Task 5 – Alternatives Analysis	Summary Tables/Figures Screening Tables, Cost Tables	\$110,672
Task 6 – Stakeholder Involvement	Materials as requested	\$30,150
Task 7 – Recommended Project	Summary Tables/Figures	\$21,277
Task 8 – Financial Analysis	Summary Tables/Figures	\$10,730
Task 9 – Regional RWFPS Report	Admin Draft, SWRCB Draft, Final	\$73,539
Task 10 – Meetings and Workshops	Meeting Materials	\$64,870
	<b>Total Budget</b>	<b>\$486,000</b>

17


## Subconsultant Roles

- ▶ **Merritt Smith Consulting**– Regulatory Strategy Support (Tasks 3, 5, 9 & 10)
- ▶ **Data Instincts** – Stakeholder Outreach (Tasks 6 & 10)
- ▶ **Trussell Technologies** – WWTF Facility/Supply Analysis, Treatment Technologies and QA/QC Support (Tasks 3, 4 & 10)
- ▶ **Stratus Consulting/Abt Associates** – Triple Bottom Line Analysis (Tasks 5 & 10)
- ▶ **GHD Inc.** – CEQA/Environmental Compliance Support (Task 5)
- ▶ **Michael Welch, PhD.** – Reservoir Augmentation (Task 3)



18

# Preliminary List of Projects

Long-List of Projects	Recycled Water Use	Source Water	Treatment	Project Area(s)
1a	Industrial Use/ Landscape Irrigation	Santa Cruz WWTP	Tertiary	City, District and County
1b		Local Raw Wastewater	MBR Tertiary	UC Santa Cruz
2a	Irrigation	Santa Cruz WWTP	Tertiary	North Coast Agricultural Irrigation
2b		Santa Cruz WWTP -or- SVWD WWTP	Secondary or Tertiary	Pasatiempo + Other Landscape
2c		Santa Cruz WWTP	Tertiary	Landscape
3	Seawater Barrier	Santa Cruz WWTP	Advanced Treatment	Lower Groundwater Basins
4a	Groundwater Replenishment	Santa Cruz WWTP	Advanced Treatment	Upper/Lower Groundwater Basins
4b		Local Raw Wastewater	MBR + Advanced Treatment	
4c		Santa Cruz WWTP -and- SVWD WWTP	Advanced Treatment	Santa Margarita GW Basin
5	Reservoir Augmentation	Santa Cruz WWTP	Advanced Treatment	Loch Lomond Reservoir
6	Streamflow Augmentation	Santa Cruz WWTP	Tertiary or Advanced Treatment	San Lorenzo River
7	Direct Potable Reuse	Santa Cruz WWTP	Advanced Treatment	City, District and County 19









### 2014 Water Reuse Water Supply Convention Maps (City)


#### Potable Reuse and Groundwater Replenishment for Tait Well Field and River Augmentation



### 2014 Water Reuse Water Supply Convention Maps (City)

#### Santa Cruz Regional Groundwater Replenishment Project





# Data Request

- ▶ Relevant Studies
- ▶ Demand Data
- ▶ WWTP Information
- ▶ GIS/Drawings
- ▶ Financial Information
- ▶ Other Information

Santa Cruz Regional RWSP  
Data Request List

Kennedy/Jenks Consultants

Project Name: [Redacted] [Yellow] [Green] [Blue]

Date: 3/27/18

Request # & Priority	Location	Type	Cost	Requestor/Party	Est. Requested	Est. Requested	Est. Requested	Notes
<b>Relevant Studies</b>								
1	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
2	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
3	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
4	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
5	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
6	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
7	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
8	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
9	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
10	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>
11	2012 San Jose Regional Wastewater Treatment Plant Upgrade	100,000	100,000	100,000	100,000	100,000	100,000	Final Report available at: <a href="#">http://www.santa-cruz.org/~/media/2012/08/2012_Santa_Cruz_Regional_Wastewater_Treatment_Plant_Upgrade_Final_Report.pdf</a>


# Open Discussion

# Driving Tour

Estimated Arrival Time	Location	Points of Interest
11:00	City Hall	Kick-Off Meeting (9 am to 10:55 am)
11:10	Santa Cruz Wastewater Treatment Plant (WWTP)	Santa Cruz WWTP
11:20	Delaware Ave industrial area, west of WWTP	Potential AWTF Site
		Possible Recycled Water Pipeline alignment RW Alignment View
11:30	Drive north to past potential Industrial and Irrigation Use sites	Possible Irrigation User – UCSC
	Drive north along Upper Western Drive	Potential Raw Water tie-in – Bay Street Reservoir
	<i>**Time-Permitting: Potential Viewing Point at UCSC**</i>	Panoramic View of System
11:45	Coast Pump Station	Point out Potential AWTF Site
		Point out Tait Well approx location
12:05	Graham Hill WTP	Location of Graham Hill WTP + Lunch
12:55	Pasatiempo	Pasatiempo Proposed Recycled Water tank
13:05	Drive along Highway 1 towards Soquel	Possible Recycled Water Pipeline alignment
13:15	Beltz Well and nearby City Wells	Beltz 12 WTP
13:35	Capitola	Oneill Ranch (Proximity of two major wells)
13:45		SqCWD Headquarters
14:10	Beltz Well Field	Capitola City Hall
14:20		Beltz WTP
14:30	Lode Street, Mid-County RAWPF	Various Beltz wells
14:40		DA Porath District Pump Station
14:50	Possible drive along Front Street pipeline alignment	
14:55	Santa Cruz Water Department	

29

# Driving Tour





## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Alternatives Workshop

**28 June 2016 from 9 am – 1 pm**

**Location:** 110 California Street Santa Cruz 95060

*Come through unlocked gate. Staff will be available to direct traffic.*

*Conference call and Web Meeting info to be provided*

---

### AGENDA

**Overall Workshop Objective:** Present approach to identify preliminary alternatives, obtain input from Study Partners and come to alignment on the alternatives to be studied in the Santa Cruz RWFPS.

---

**PART I Goal:** Identify alternatives for evaluation in the Santa Cruz RWFPS **9:00 am to 11:00 am**

1. Introduction and Roles
2. Review of Study Objectives
3. Project Component Matrix (Long List)
4. Set Basic Guidelines for Evaluating Project Components
5. Evaluate Project Components
6. Identify Alternatives for Further Evaluation
7. Open Discussion

### BREAK & SNACKS

---

**PART II Goal:** Discuss recycled water treatment concepts, siting preferences and relocation considerations for treatment options at the Santa Cruz WWTF. **11:30 am to 12:15 pm**

1. Tertiary Treatment Concepts (process, capacity, footprint)
2. Advanced Water Treatment Concepts (process, capacity, footprint)
3. Siting Preferences and Facility Relocation Considerations
4. Open Discussion

### WWTF TOUR

---

**PART III Tour Goal:** Visit identified locations for expanding tertiary treatment, siting advanced water treatment facilities and potential opportunities for relocating displaced facilities on-site. **12:15 pm to 1:00 pm**

**Kennedy/Jenks Consultants**

# City of Santa Cruz Recycled Water Facilities Planning Study

Alternatives Workshop

June 28 2016


*\* Includes amended notes to reflect discussion at workshop*

Kennedy/Jenks Consultants 1

## Agenda

- Introduction and Roles
- Review of Study Objectives
- Project Component Matrix (Long List)
- Set Basic Guidelines for Evaluating Project Components
- Evaluate Project Components
- Identify Alternatives for Further Evaluation
- Open Discussion

Kennedy/Jenks Consultants 2




## Review of Study Objectives

**TABLE 1**

#	Study Objectives	Abbreviated
1	Assess beneficial reuse of wastewater from a resource recovery perspective	Beneficial Reuse
2	Meet or reduce the water supply gap (1.2 BGY, 3.3 MGD or 3,700 AFY)	Water Supply Gap
3	Evaluate local and regional recycled water projects	Local and Regional Projects
4	Identify a phased approach to reuse in Santa Cruz	Phased Approach
5	Identify potential impacts to WWTF operations	SCWWTF Impacts
6	Initiate plan for continued recycled water outreach and education	Outreach Plan
7	Meet SWRCB grant requirements	SWRCB Grant
8	Meet schedule and intent of WSAC Outcome Element #3	WSAC Outcome

Kennedy/Jenks Consultants 4





## Basic Guidelines for Evaluating Project Components

**TABLE 1**

#	Basic Guidelines for Evaluation of Project Components	Abbreviated
A	Project uses Santa Cruz WWTF effluent or wastewater destined for Santa Cruz WWTF	Reuse of Santa Cruz WWTF Effluent
B	Project offsets or increases Santa Cruz potable supplies to meet or reduce the Santa Cruz water supply gap	Offset or Increase Potable Supplies
C	Non-Potable reuse that is at least tertiary level of treatment; Potable reuse and streamflow augmentation require advanced treatment; Preference is to avoid over-treatment for a given use	Right Treatment for Right Use
D	Tertiary treatment is located at SC WWTF; AWTF located at the SC WWTF or GHWTP.	Consolidate Treatment Facilities
E	Sewer mining would only be considered at sites with flows > 2 MGD; MBR would only be considered for demands >1 MGD	Sufficient Flows and Demands for MBR
F	WWTF impacts to water quantity, water quality, facilities and O&M activities should be minimized	Minimize Impacts to WW collection and treatment
G	ASR study will identify potential City GWRR location(s), characteristics and limitations	GWRR at Identified ASR Sites
H	Potable Reuse and streamflow augmentation project capacity will be bookended by available space for treatment facilities	AWTF Capacity Limited by Siting
I	Projects could involve outside agencies/users and/or have (at least) a preliminary agreement (letter of willingness to pursue) for anticipated use (farmers, UCSC, industry)	Preliminary Agreements Imminent
J	RW use is currently approved under existing regulatory conditions or implemented in the USA	Approved/Practiced Reuse

Kennedy/Jenks Consultants 6


## Alignment of Objectives and Guidelines

TABLE 1

Basic Guidelines for Evaluation of Project Components		Primary Alignment of Guidelines with Study Objectives							
		1	2	3	4	5	6	7	8
		Beneficial Reuse	Water Supply Gap	Local and Regional Projects	Phased Approach	SCWWTF Impacts	Outreach Strategy	SWRCB Grant	WSAC Outcome
A	Reuse of Santa Cruz WWTF Effluent	✓							
B	Offset or Increase Potable Supplies		✓						
C	Right Treatment for Right Use			✓					
D	Consolidate Treatment Facilities					✓			
E	Sufficient Flows and Demands for MBR					✓			
F	Minimize Impacts to WW collection and treatment					✓			
G	GWRR at Identified ASR Sites								✓
H	AWTF Capacity Limited by Siting				✓				
I	Preliminary Agreements Imminent							✓	
J	Approved/Practiced Reuse						✓		

*Intent is to have at least one objective tied to each guideline, though others may apply*

## Flow Diagram - Approach



**Non-Potable Reuse  
 Component Evaluation (1 – 10)**

**TABLE 2**

Potential Project Components	Recycled Water Use	Source Water	Treatment	Description	Reuse of Santa Cruz WWTF Effluent	Offset or Increase Potable Supplies	Right Treatment for Right Use	Consolidate Treatment Facilities	Sufficient Flow and Demands for MBR	Minimize Impacts to WW collection and treatment	GWRR at Identified ASR Sites	AWTF Capacity Limited by Siting	Preliminary Agreements Imminent	Approved/ Practiced Reuse		
1	Non-Potable Reuse	Santa Cruz WWTF	Secondary	Limited use in Santa Cruz (in-plant, restricted areas, truck filling)	○	●	◄	○		○			○	○		
2				Unrestricted use in Santa Cruz (irrigation, commercial, industrial, truck filling) including UC Santa Cruz	○	○	○	○		○			○	○		
3			Tertiary	North Coast Agricultural Irrigation	○	●	○	○			○			◄	○	
4				Unrestricted use in Santa Cruz (irrigation, commercial, industrial, truck filling) including UC Santa Cruz	○	○	●	○			○			○	○	
5			Advanced Treatment	North Coast Agricultural Irrigation	○	◄	●	○			○			◄	○	
6				Customers along pipeline alignments to IPR/DPR or streamflow augmentation	○	○	◄	○			○			○	○	
7		Local Raw Wastewater	MBR (Tertiary)	Anchor customers in Santa Cruz (Unrestricted use)	○	○	○	◄	●	◄				●	○	
8					UC Santa Cruz	○	○	○	◄	◄	◄				○	○
9					North Coast Agricultural Irrigation	○	●	○	◄	●	●				●	○
10			Scotts Valley WWTF	Secondary (outfall)	Pasatiempo Golf Course	●	○	●	◄		○			○	○	

Kennedy/Jenks Consultants

**Non-Potable Reuse:  
 Components Removed from Further Consideration**

- **Secondary: Limited use in Santa Cruz**
  - Limited uses, minimal benefit to water supply
  - Public acceptance issues
- **Tertiary/AWT: North Coast Agricultural Irrigation**
  - Uncertainty about the **quantity, quality and seasonality** of water **available** for exchange
  - Permitting challenges for State Parks
  - Challenge to confirm willingness to use (ag opponents)
  - High cost with minimal incentive to support rates for revenue
- **AWT: Unrestricted use in Santa Cruz**
  - Beyond regulatory requirement for NPR
  - Significantly higher cost/energy
  - Keep as an option for customers along pipeline alignments that carry advanced treated water for potable reuse.

Kennedy/Jenks Consultants 10

## Seawater Intrusion Barrier Component Evaluation (11 – 12)

**TABLE 2**

Potential Project Components	Recycled Water Use	Source Water	Treatment	Description	Reuse of Santa Cruz WWTF Effluent	Offset or Increase Potable Supplies	Right Treatment for Right Use	Consolidate Treatment Facilities	Sufficient Flows and Demands for MBR	Minimize Impacts to WW collection and treatment	GWRR at Identified ASR Sites	AWTF Capacity Limited by Siting	Preliminary Agreements Imminent	Approved/ Practiced Reuse
11	Seawater Intrusion Barrier	Santa Cruz WWTF	Advanced Treatment	Identified groundwater basin subject to seawater intrusion	○	●	○	○		○	●	○	○	○
12		Local Raw Wastewater	MBR + Advanced Treatment	Identified groundwater basin subject to seawater intrusion	○	●	○	●	●	○	●		○	○

Kennedy/Jenks Consultants

## Seawater Intrusion Barrier: Removed from Further Consideration

- Threat to City wells is currently low
- Provides limited water supply
- Very costly "insurance" (potential future loss of Beltz coastal wells)
- Potential opportunity for zero discharge study
- MBR has limited available supply



*Seawater intrusion avoidance could be considered a baseline assumption for any groundwater replenishment alternative*

Per City: Seawater intrusion is included in the ASR groundwater modeling scenarios. The intent is to use it more as a barrier, while managing wells for extraction.

Kennedy/Jenks Consultants 12

## Groundwater Replenishment Reuse (GWRR) Component Evaluation (13 – 19)

TABLE 2

Potential Project Components	Recycled Water Use	Source Water	Treatment	Description	Reuse of Santa Cruz WWTF Effluent	Offset or Increase Potable Supplies	Right Treatment for Right Use	Consolidate Treatment Facilities	Sufficient Flows and Demands for MBR	Minimize Impacts to WW collection and treatment	GWRR at Identified ASR Sites	AWTF Capacity Limited by Siting	Preliminary Agreements Imminent	Approved/ Practiced Reuse	
13	Groundwater Replenishment	Santa Cruz WWTF	Advanced Treatment	Suitable Santa Cruz GWRR site(s) to be defined in the ASR Study	○	○	○	○		○	○	○	○	○	
14				SqCWD GWRR Sites in Aptos/Purisima Basins (per GWRR Feasibility Study)	○	●	○	○		○	○	○	○	○	○
15				Santa Margarita GW Basin	○	●	○	○		○	●	○	○	○	○
16		Local Raw Wastewater	MBR + Advanced Treatment	Suitable Santa Cruz GWRR site(s) to be defined in the ASR Study	○	○	○	●	●	○	○	○	○	○	
17				SqCWD GWRR Sites in Aptos/Purisima Basins (per GWRR Feasibility Study)	○	●	○	●	○	○	○	○	○	○	○
18		Scotts Valley WWTF or Outfall	Advanced Treatment	Suitable site to be defined in the ASR Study	●	○	○	○		○	○	○	○	○	
19	Santa Margarita GW Basin			●	●	○	○		○	●	○	○	○	○	

Kennedy/Jenks Consultants

### GWRR: Components Removed from Further Consideration

- **SqCWD GWRR Sites in Aptos/Purisima Basins: per GWRR Feasibility Study**
  - No direct augmentation of Santa Cruz potable supplies
  - Indirect access would require complex institutional arrangements and significant new infrastructure
  - Siting challenges for MBR/AWTF

*Potential to "T" off of conveyance system for NPR or IPR in Santa Cruz is covered under other alternatives*
- ▶ **Santa Margarita GW Basin**
  - No direct augmentation of Santa Cruz potable supplies
  - Indirect access would require complex institutional arrangements and significant new infrastructure
  - High cost to treat and pump to this upper basin




Kennedy/Jenks Consultants

## GWRR: Components Removed from Further Consideration

- **Use of Scotts Valley WWTF or Outfall**

- Does not use Santa Cruz WW
- Minimal flow is available in the outfall due to
  - ✓ existing SVWD recycled water program,
  - ✓ planned Pasatiempo use of RW from the outfall and
  - ✓ proposed GWRR currently being explored for SVWD
- SVWD is already studying this project in a separate RWFPS
- **Use of outfall for conveyance of recycled water from SC WWTF is not viable due to operational concerns if discharge is needed**

Scotts Valley WRF Average Daily Flows, 2014



Kennedy/Jenks Consultants 15

## Reservoir Augmentation, Streamflow Augmentation and Direct Potable Reuse Component Evaluation (20 - 24)

TABLE 2

Potential Project Components	Recycled Water Use	Source Water	Treatment	Description	Reuse of Santa Cruz WWTF Effluent	Offset or Increase Potable Supplies	Right Treatment for Right Use	Consolidate Treatment Facilities	Sufficient Flows and Demands for MBR	Minimize Impacts to WW collection and treatment	GWRR at Identified ASR Sites	AWTF Capacity Limited by Siting	Preliminary Agreements Imminent	Approved/ Practiced Reuse
20	Reservoir Augmentation	Santa Cruz WWTF	Advanced Treatment	Loch Lomond Reservoir	○	○	○	○	○	○	○	○	○	●
21	Streamflow Augmentation	Santa Cruz WWTF	Tertiary	San Lorenzo River (Direct/Indirect Discharge)	○	○	●	○	○	○	○	○	○	●
22			Advanced Treatment	San Lorenzo River (Direct/Indirect Discharge)	○	○	○	○	○	○	○	○	○	○
23	Direct Potable Reuse	Santa Cruz WWTF	Advanced Treatment	Raw Water Blending at Graham Hill WTP (via Coast PS)	○	○	○	○	○	○	○	○	○	●
24				Pipe to Pipe (Downstream of Graham Hill WTP)	○	○	○	○	○	○	○	○	○	○

Kennedy/Jenks Consultants

**Streamflow:  
Components Removed from Further Consideration**

- **Tertiary Treatment**
  - Environmental and habitat concerns related to water quality
  - Proximity to raw water diversion
  - Regulatory and permitting challenges
  - **TMDL for Nitrogen would be a limiting factor**

*Assume higher level of treatment as the baseline for a streamflow augmentation project*

*\* An advanced treatment option should consider need for denitrification to minimize nitrogen loading in the basin.*

Kennedy/Jenks Consultants 17

**DPR: Components Removed from Further Consideration**

- **Pipe-to-Pipe: d/s of Graham Hill WTP**
  - Lacks additional treatment, barrier and response time provided by blending prior to a drinking WTP
  - No project of this type is currently or has been permitted in the US
  - Significant public acceptance issues

*Assume source water blending u/s of the WTP as the baseline for a DPR project*

Kennedy/Jenks Consultants 18

## Alternatives for Further Evaluation

- Alternative 1 – Centralized Non-Potable Reuse
- Alternative 2 – Decentralized Non-Potable Reuse
- Alternative 3 – Santa Cruz Participation in SqCWD-led GWRR Project
- Alternative 4 – Santa Cruz GWRR Project
- Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir
- Alternative 6 – Streamflow Augmentation
- Alternative 7 – Direct Potable Reuse

Kennedy/Jenks Consultants

## Alternatives 1 & 2: Non-Potable Reuse

TABLE 3

Alternative	Sub Alt	Description	Source Water	Treatment	Use
Alternative 1 – Centralized Non-Potable Reuse	1a	Santa Cruz PWD Phase 2 Project	Santa Cruz WWTF	Tertiary Treatment at SC WWTF	3° In-plant uses, truck filling and demonstration site (park near WWTF)
	1b	Maximize tertiary treatment at the SC WWTF			3° Unrestricted use in Santa Cruz including UC Santa Cruz (Sites TBD)
Alternative 2 – Decentralized Non-Potable Reuse	2	UC Santa Cruz	Local Raw Wastewater (UCSC)	MBR at UCSC	3° On campus uses (irrigation, agricultural, cooling towers, dual-plumbed facilities)

Kennedy/Jenks Consultants



## Alternatives 1 & 2: Non-Potable Reuse


2013 Santa Cruz Demand	Total (mgd)	Total (AFY)
Irrigation	0.7	770
Commercial	1.7	1,913
Interdept	0.2	192
UCSC	0.5	560
<b>Total</b>	<b>3.1</b>	<b>3,435</b>

Note: Demands in tables are average annual. Peak day demand will be higher

Meters (AFY)	
Irrigation	0-3
	4-10
	11-138
Comm (gen, hotel, rest, indust)	0-3
	4-10
	11-61
Interdepartmental	0-3
	4-10
	11-20
UCSC	0-3
	4-10
	10-140
City Limits	
Water Service Area	

Decentralized

Centralized



Kennedy/Jenks Consultants

## Alternative 3: Santa Cruz Participation in a SqCWD-led GWRR

TABLE 3


Sub Alt	Description	Source Water	Treatment	Use
3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (serve NPR users along the way)	Santa Cruz WWTF	On-Site Treatment at NPR Customer sites	2° + filter NPR Customers along secondary pipelines alignment from SC WWTF to AWTF
3b	Send tertiary effluent from SCWWTF to SqCWD (serve NPR users along the way)		Tertiary Treatment at SC WWTF	3° NPR Customers along tertiary pipeline alignment from SC WWTF to AWTF
3c (New)	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD WTF to recharge Santa Cruz GWRR		Advanced Treatment at SqCWD Headquarters	AWT SqCWD AWTF water delivered to Santa Cruz GWRR injection sites
3d	Send advanced treated RW from SCWWTF to SqCWD, (serve NPR users along the way)		Advanced Treatment at SC WWTF	AWT NPR Customers along pipeline alignment from SC WWTF to SqCWD injection sites
3e	Send advanced treated RW from SCWWTF to SqCWD, (GWRR and NPR along the way)		Advanced Treatment at SC WWTF	AWT GWRR in Santa Cruz (Beltz Well Field) and NPR customers along pipeline alignments
removed	GWRR in Santa Cruz through an extension from MBR + AWTF at SqCWD	Local Raw Wastewater (SCCSD)	MBR + Advanced Treatment at SqCWD	AWT GWRR in Santa Cruz (Beltz Well Field)

Kennedy/Jenks Consultants


## SqCWD GWRR Feasibility Study Recommended Alternative: AWPf at SqCWD




## Alternative 3 – Santa Cruz Participation in SqCWD led GWRR Project 3a: NPR w/ On-Site Treatment of Secondary RW




**Alternative 3 – Santa Cruz Participation in SqCWD led GWRR Project**  
**3b: NPR w/ Tertiary RW use at Customer sites**



**Alternative 3 – Santa Cruz Participation in SqCWD led GWRR Project**  
**3c: Secondary RW+ Santa Cruz GWRR**




## SqCWD GWRR Feasibility Study Recommended Alternative: AWPf at SC WWTP




AWPF AT SC WWTP  
 PROJECT OVERVIEW  
 FIGURE E32  
 SOQUEL CREEK WATER DISTRICT  
 GROUNDWATER REPLENISHMENT FEASIBILITY STUDY


## Alternative 3 – Santa Cruz Participation in SqCWD led GWRR Project 3d: Serve NPR users along the way




**Alternative 3 – Santa Cruz Participation in SqCWD led GWRR Project**  
**3e: GWRR near City wells and serve NPR users along the way**



**SqCWD GWRR Feasibility Study Recommended Alternative: MBR at SqCWD**






## Alternative 4: Santa Cruz GWRR

**TABLE 3**

Sub Alt	Description	Source Water	Treatment	Use
4a	Santa Cruz GWRR with AWTF at SC WWTF (serve NPR users along the way)	Santa Cruz WWTF	Advanced Treatment at SC WWTF	Suitable Santa Cruz GWRR site(s) to be defined in the ASR Study. Once extracted, recharged water would be distributed through the existing potable water distribution system.
4b	Santa Cruz GWRR with AWTF of secondary effluent at off-site location (serve NPR users along the way)		Advanced Treatment off-site (location TBD)	
4c	Santa Cruz GWRR with MBR + AWTF at DA Porath PS (serve NPR users along the way)	Local Raw Wastewater (SCCSD)	MBR + Advanced Treatment	




### Alternative 5: Surface Water Augmentation

**TABLE 3**

Sub Alt	Description	Source Water	Treatment	Use
5	Advanced treatment of Santa Cruz effluent for blending in Loch Lomond Reservoir	Santa Cruz WWTF	Advanced Treatment at SC WWTF	AWT Reservoir augmentation in Loch Lomond for blending and storage, to be conveyed to the GHWTP and enter the City's potable water distribution system.

Kennedy/Jenks Consultants

## Alternative 5: Surface Water Augmentation



- RW delivered ~ 3 mgd
  - Based on treating only City of Santa Cruz flows
- Potentially limited by
  - Regulatory requirements (i.e. dilution and retention time)
  - Available AWTf space

Kennedy/Jenks Consultants

## Alternative 6: Streamflow Augmentation


TABLE 3

Sub Alt	Description	Source Water	Treatment	Use
6a	AWTF of secondary effluent with direct discharge to the San Lorenzo River btw Felton and Tait (serve NPR users along the way)	Santa Cruz WWTF	Advanced Treatment at SC WWTF	AWTF Augment San Lorenzo River flows to maintain habitat, meet future fish release requirement, and allow for increased diversions to expand future drinking water supplies.
6b	AWTF of secondary effluent with indirect discharge to the San Lorenzo River d/s of Tait Street Diversion at Tait Well Field (serve NPR users along the way)			AWTF

Key Consideration: Meeting TMDL for Nitrogen in the river

Kennedy/Jenks Consultants





### Alternative 7: Direct Potable Reuse


TABLE 3

Sub Alt	Description	Source Water	Treatment	Use
7	Raw Water Blending at Graham Hill WTP (via Coast PS)	Santa Cruz WWTF	Advanced Treatment at SC WWTF	AWT The advanced treated water would be blended with raw water coming from North Coast sources, the San Lorenzo River, and Loch Lomond water at the Coast Pump Station, and further treated at the GHWTP prior to distribution as finished water, suitable for drinking.

Additional Consideration: GHWTP source water issues include high turbidity, high TOC, DBPs, solids issues, etc. Consider synergies between GHWTP investments and AWPf when evaluating siting and blending.

Kennedy/Jenks Consultants

## Alternative 7: DPR with Raw Water Blending at Graham Hill WTP




- **GHWTP** : Treat blended raw water + purified water to produce drinking water
- **Coast Pump Station:** Raw Water
- **SC WWTP + AWPf:** Purified Water

Kennedy/Jenks Consultants

## OPEN DISCUSSION

\* Workshop participants came to alignment on alternatives as developed, upon incorporation of comments from today's workshops.

Kennedy/Jenks Consultants




QUESTIONS


Kennedy/Jenks Consultants

# City of Santa Cruz Wastewater Treatment Facility

Future Facility Layout Estimates  
Trussell Technologies, Inc.  
June 28, 2016


*\* Includes amended notes to reflect decisions at workshop*





## Layout considerations

- **Goal:** identify space limitations at WWTF
- **Two water quality objectives:**
  - Compatibility with 175 gpm (0.25 mgd) tertiary
  - Tertiary (non-potable):
    - ✓ 1.5 mgd
  - AWPF (advanced treated water):
    - ✓ Scenario 1: 1.3 mgd (based on Soquel RWFPS)
    - ✓ Scenario 2: 5.0 mgd (based on June flow)
- **Siting Considerations:** Potential layout options and relocation of displaced facilities can be discussed at a high-level.



- ## Processes Included in TT Estimate
- ### AWPF

  - MF (n+1)
    - 20 gfd flux
    - 90% recovery
  - RO (n+1)
    - 12 gfd flux
    - 80% recovery
  - UV/AOP (n+1)
    - H<sub>2</sub>O<sub>2</sub>
  - Chemical Storage
  - Not **YET** included
    - Operations building
    - Post treatment
    - Product water pump station
    - Relocation of facilities

### Tertiary

  - Granular media filtration
    - 5 gpm/sf
  - Disinfection
    - Combined chlorine
      - ✓ 80% baffling efficiency CCB
      - ✓ > 90-min modal, 450 CT
    - UV (smaller footprint)
      - ✓ 55% UVT minimum influent possible
  - Meets Title-22 requirements
  - No product water storage
- Trussell

## 0.25 mgd Tertiary Layout (Phase 2 Project)

Trussell

### 0.25 mgd Tertiary Treatment Design (Phase 2 Project)

- Footprint area estimate  
– 0.08 acre
- Uses existing conveyance infrastructure, filters and chemical storage



- 25,000 gal New CCB
- 25,000 gal Existing CCB
- 95,000 gal Product Water Storage
- Filters and Chemical Storage

## Increasing Capacity Beyond 0.25 mgd

### Up to 0.25 mgd Capacity

- Existing infrastructural limitations:
  - Conveyance piping
  - Conveyance pumps
  - Filter capacity


### Beyond 0.25 mgd Capacity

- Upgrade conveyance piping and pumps
- Add additional filters
- Add additional disinfection capacity

Trussell

## Flexibility of 0.25 mgd Tertiary Treatment Design



- Allows space for 1.5 mgd tertiary




Trussell




# 1.5 mgd Tertiary Layout






## 1.3 mgd AWPf Layout



## 5.0 mgd AWPf Layout



## Preliminary Site Layout Options Summary

Treatment Design Options	Flow Rate (mgd)	Footprint Estimate (acre)
<b>Phase 2 Tertiary</b>	0.25	0.08
<b>Tertiary Alternatives:</b>		
Chlorine Contact Basin	1.5	0.15
UV Disinfection	1.5	0.10
<b>AWPF Alternatives</b>	1.3	0.10
	5.0	0.40

*Per discussions during the workshop, the bookends of site layouts for tertiary and AWPf are to be expanded to maximize treatment in the available space. The table on the following page represents the revised layouts to be evaluated.*

## Revised Site Layout Options (to be evaluated)

Treatment Design Options	Min Flow Rate (mgd)	Min Footprint Estimate (acre)	Max Flow Rate (mgd)	Max Footprint Estimate (acre)
<b>Phase 2 Title 22 Tertiary Project</b>	0.25	0.08	same	same
<b>Tertiary Alternatives:</b>				
Media Filtration + Chlorine Disinfection	1.5	0.15	5.5	TBD
Media Filtration + UV Disinfection	1.5	0.10	5.5	TBD
MF Filtration + UV Disinfection	1.5	0.10	9.5	TBD
<b>AWTF Alternatives:</b>				
AWTF Alternative for IPR	1.3	0.10	5.5	0.40
AWTF Alternative for DPR	5.5	0.40	9.5	TBD



## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Screening Webinar

**29 Aug 2016 from 1 to 3 pm**

Conf Call - (855) 813-2486 Code – 2484

Web Meeting - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Webinar Objective:** Present approach for screening alternatives. Discuss and seek input on screening categories, criteria, guidelines for scoring and weighting to compare alternative projects in the Santa Cruz RWFPS.

**Action Item:** Project Partners to fill out and submit weighting table following the workshop.

---

1. Introduction and Roles
2. Overview of Today's Workshop
3. Overall Alternatives Evaluation Approach (Figure 1)
4. Alternatives Screening Approach (Figures 2 & 3)
5. Screening Criteria and Guidance for Scoring (Table 5)
6. Weighting for Screening Criteria (Table 6)
7. Method to Score and Weight Alternative Projects (Table 7)
8. Ranking and Sensitivity Analysis (Table 8)
9. Open Discussion
10. Next Steps

# City of Santa Cruz Recycled Water Facilities Planning Study

Screening Criteria Workshop  
August 29, 2016

Kennedy/Jenks Consultants

## Agenda


- Introduction and Roles
- Today's Workshop
- Overall Alternatives Evaluation Approach (Figure 1)
- Alternatives Screening Approach (Figures 2 & 3)
- Screening Criteria and Guidance for Scoring (Table 5)
- Weighting for Screening Criteria (Table 6)
- Method to Score and Weight Alternative Projects (Table 7)
- Ranking and Sensitivity Analysis (Table 8)
- Open Discussion
- Next Steps

Kennedy/Jenks Consultants

## Today's Workshop

- **Objective:** Present approach for screening alternatives.
- **Goal:** Discuss and seek input on screening categories, criteria and guidelines for scoring and weighting alternative projects.
- **Action Items:** Project Partners to fill out and submit weighting table following the workshop.

Kennedy/Jenks Consultants






## Overall Approach - Meetings

- Mar-2016 Kickoff
- Jun-2016 Alternatives Workshop
- Aug-2016 Screening Webinar (TODAY)
- Oct-2016 Alternative Webinar – Part I
- Nov-2016 Alternative Webinar – Part II
- Dec-2016 Scoring and Ranking Workshop
- Feb-2017 Present Recommended Alternatives

FIGURE 1 (Table at Bottom)

Kennedy/Jenks Consultants


## Alternatives Screening Categories



- Four categories to compare alternatives
- Triple Bottom Line (TBL) approach
- Integrates engineering and operational considerations

FIGURE 2

Kennedy/Jenks Consultants



### QUANTITATIVE Results from Alternatives Evaluation

Recycled Water Delivered:	Costs:	Energy / Other:
Annual Volume (AFY)	Construction Costs (\$)	Energy (kWH/AF) of RW Delivered
Average Annual Flow (mgd)	O&M Costs (\$/yr)	GHG emissions (MT of CO <sub>2</sub> e per year)
Peak Season Deliveries (AF Summer)	Life Cycle Costs (\$/AFY)	Social Cost of Carbon (\$/MT)
Peak Flow (mgd)	Annualized Cost per Million gallons of Average year Yield (ACAVY)	Construction Footprint (SF)
Average year Yield (MG)		# and Size of Facilities

**QUANTITATIVE results will be provided for each alternative and used to inform qualitative scoring**

AF = acre-feet      kWH = kilowatt hour  
 AFY = acre-feet per year      MT = metric ton  
 MG = million gallons      CO<sub>2</sub>e = carbon dioxide equivalent  
 mgd = million gallons per day      SF = square feet

**TABLE 5** Kennedy/Jenks Consultants

### QUALITATIVE Criteria for Comparing Alternatives

Categories	Alternatives Screening Criteria	Considerations for Assessing Project based on Criteria
<b>ENGINEERING &amp; OPERATIONAL CONSIDERATIONS</b>	Improve <b>Regional</b> Water Supply	Ability to fill City water supply gap, supplement supply in peak season, timeline for implementation
	<b>Maximize Beneficial Reuse</b>	<b>Maximizes reuse of wastewater now and/or does not limit future options to fully utilize wastewater</b>
	Ease of Implementation	Permitability, construction complexity, flexibility for phasing and potential for expansion
	Operational Complexity	<b>Complexity of</b> treatment requirements and <b>short- and long-term</b> impacts to WWTF O&M activities
<b>ECONOMIC</b>	Cost Effectiveness	Relative unit <b>life cycle</b> costs
	Financial Implementability	Relative capital <b>investment</b> and tradeoffs
<b>ENVIRONMENTAL</b>	CEQA Considerations	Potential impacts and mitigation requirements
	Environmental Enhancement	Opportunity to enhance ecosystem and social cost of carbon (GHG emissions)
<b>SOCIAL</b>	Agency Coordination, Partnerships and Agreements	Level of effort and willingness to work together
	Social Issues & Siting	Public acceptance and local disruption

**QUANTITATIVE results and other considerations are used to guide scoring for each QUALITATIVE screening criteria**

TABLE 5

### Scoring for QUALITATIVE Criteria

Scoring Legend:	Score
Fully <b>Exceeds-Meets</b> Criteria	5
Mostly <b>Exceeds Meets</b> Criteria	4
Generally Meets Criteria	3
Somewhat Meets Criteria	2
Unable to Meet Criteria	1

**Scores are assigned based on the range of QUANTITATIVE results and relative findings from the QUALITATIVE assessment**

Kennedy/Jenks Consultants

## Engineering and Operational Considerations

- Water Supply Gap = 1.2 BGY, 3.3 mgd or 3,700 AFY
  - Quantitative Results = RW Delivered annually and during peak season (mgd or AF).
  - Qualitative Assessment = How often and to what level can project fill the City water supply gap. **Considers potential excess supply to fill Regional water supply gap**
- Construction Challenges
  - Quantitative Results = Number and size of facilities.
  - Qualitative Assessment = How much anticipated disturbance and likely construction complexity.

Kennedy/Jenks Consultants

## Engineering and Operational Considerations

- Source of WW and Type of Treatment
  - Quantitative Results = Flow variation and source water quality.
  - Qualitative Assessment = Level of complexity for treatment processes and related operations.
- Siting new Treatment Facilities
  - Quantitative Results = Number and size of facilities and construction footprint.
  - Qualitative Assessment = Impact of relocation of existing facilities or disruption due to off-site operations.

Kennedy/Jenks Consultants

## Economic

- Economic Feasibility / Cost Effectiveness
  - Quantitative Results = Capital, O&M and life cycle unit costs and ~~Annualized Cost per Million gallons of Average year Yield (ACAYY)\*~~.
  - Qualitative Assessment = Comparison to baseline and avoided baseline costs.

*\* The WSAC defined ACAYY as a cost metric to evaluate the cost-effectiveness of different water supply projects using the Confluence Model to estimate yield. A similar approach will be used to the yield of each recycled water alternative to allow for comparison btw alternatives and with other water supply options (i.e. ASR Study). The RWFPS will provide the data to calculate the ACAYY for others to use in the comparison of priority RW projects with other WSAC projects; however, the ACAYY will not be used in the evaluation of RW alternatives in the RWFPS.*

- Financially implementable project
  - Quantitative Results = Capital costs.
  - Qualitative Assessment = Need to issue debt, potential impact on rates and required tradeoffs (i.e. the ability to implement other water supply projects.)

Kennedy/Jenks Consultants

## Environmental

- CEQA Considerations
  - Quantitative Results = Need for MND vs. EIR.
  - Qualitative Assessment = Complexity of CEQA and permitting process; extent of mitigation required, especially if on-going effects on O&M.

*Note: City will strive to offset energy requirement of any project(s) with green power. Other environmental impacts may include construction, noise, brine discharge, etc.*

Kennedy/Jenks Consultants

## Environmental

- Enhance Ecosystems
  - Quantitative Results = Not available.
  - Qualitative Assessment = Contributes **significant, some** or minimal benefit to enhancing the environment.
  
- Contribution to global warming
  - Quantitative Results = GHG emissions (Metric Tons of CO<sub>2</sub>e per year) based on energy (kWH/AF) of RW delivered and social cost of carbon (\$/MT).
  - Qualitative Assessment = Relative social cost of carbon compared to other projects and sources.

Kennedy/Jenks Consultants

## Social

- Level of Coordination and Partnership
  - Quantitative Results = Not available.
  - Qualitative Assessment = Level of City control and current interest from partners in agreements and cost sharing.
  
- Perceived Public Acceptance
  - Quantitative Results = Not available.
  - Qualitative Assessment = Supportive to opposed.
  
- Local Disruption
  - Quantitative Results = Construction footprint.
  - Qualitative Assessment = Challenges with land acquisition and opposition to on-going O&M activities.

Kennedy/Jenks Consultants

## Weighting for Screening Criteria

Categories	Alternatives Screening Criteria	Example % Weighting	What's YOUR Weighting?
<b>ENGINEERING &amp; OPERATIONAL CONSIDERATIONS</b>	Improve Regional Water Supply	20%	Consultant Team City Water Team City PW Team SqCWD Team* SVWD Team* Santa Cruz County Team*
	Ease of Implementation	15%	
	Operational Complexity	10%	
<b>ECONOMIC</b>	Cost Effectiveness	12%	
	Financial Implementability	12%	
<b>ENVIRONMENTAL</b>	CEQA Considerations	8%	
	Environmental Enhancement	8%	
<b>SOCIAL</b>	Agency Coordination, Partnerships and Agreements	10%	
	Social Issues & Siting	5%	
<b>TOTAL</b>		<b>100%</b>	<b>Each team provides a unique point of view.</b> <i>* Integration of non-financial partner weighting in ranking to be determined .</i>

**TABLE 6** Kennedy/Jenks Consultants

## Alternative Project Scoring and Weighting Evaluation

**TABLE 7**

Categories	Alternatives Screening Criteria	ENGINEERING & OPERATIONAL CONSIDERATIONS										ECONOMIC			ENVIRONMENTAL			SOCIAL			TOTAL Weighted Score (max 100)		
		Improve Water Supply		Maximize Beneficial Reuse		Ease of Implementation		Operational Complexity		Cost Effectiveness	Financial Implementability	CEQA Considerations 4	Environmental Enhancement		Agency Coordination, Partnerships and Agreements		Social Issues & Siting						
		Supply Cost	Flexibility	Maximum Use Now	Future Expansion	Remediability	Construction	Expansion	Treatment				Siting	Regulatory Mitigation	Enhance	CEQA	Level of Willingness	Public Acceptance	Local Disruption				
<b>COMMENDED Weighting based on input from Project Partners</b>		30.4		4.6		15.9		10.1		45.1	15.0	10.6	25.6	6.8	6.4	13.2	10.6	5.0	15.6	100			
Alternative 1 - Centralized Non-Potable Reuse	1a	3	4	3	3	4	5	4	5	3	38.2	4	5	22.6	5	4	4	11.9	5	5	5	55.6	
	1b	3	3	3	3	4	4	5	5	5	38.1	4	4	20.5	5	4	4	11.9	5	5	4	51.1	
Alternative 2 - Decentralized Non-Potable Reuse	2	1	1	3	3	3	4	4	4	4	21.9	3	4	17.5	5	4	4	11.9	4	5	4	33.0	
		Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (same NPR users along the way)	1	1	3	3	5	5	2	5	3	32.1	5	5	25.4	5	4	4	11.9	5	5	4	55.1
Alternative 3 - Santa Cruz Participation in SqCWD and Groundwater Recharge Reuse (GWR) Project	3a	Send tertiary effluent from SCWWTF to SqCWD (same NPR users along the way)	2								25.1	4	4	18.1	5	4	4	11.9	5	5	4	51.1	
	3b	Send additional secondary effluent from SCWWTF to SqCWD (same NPR users along the way)	5	5	3	3	4	4	4	4	31.2	4	4	18.1	5	4	4	11.9	5	5	4	62.3	
	3c	Send secondary effluent from SCWWTF to SqCWD (same NPR users along the way)	2	2	3	3	3	3	3	3	21.1	4	4	11.9	5	5	4	11.9	5	5	4	51.1	
	3d	Send advanced treated RW from SCWWTF to SqCWD (same NPR users along the way)	5	5	3	3	3	3	3	3	31.1	4	4	18.1	5	4	4	11.9	4	3	4	52.0	
	3e	Send advanced treated RW from SCWWTF to SqCWD (same NPR users along the way)	5	5	3	3	3	3	3	3	32.1	4	3	18.4	4	4	4	11.9	4	3	3	51.5	
Alternative 4 - Santa Cruz GWR Project	4a	Santa Cruz GWRs with WWT of secondary effluent at all-rs location (DO NOT reuse NPR users along the way)	5	5	3	3	3	3	3	2	29.6	4	3	18.4	3	4	4	11.9	4	3	3	51.5	
	4b	Santa Cruz GWRs with WWT of secondary effluent at all-rs location (DO NOT reuse NPR users along the way)	4	4	3	3	2	2	1	3	3	25.4	3	3	15.4	3	4	2	7.9	4	3	3	41.2
Alternative 5 - Surface Water Augmentation (SWA) in Luch Lamond Reservoir	5	Advanced treatment of Santa Cruz effluent for bonding in Luch Lamond Reservoir (DO NOT reuse NPR users along the way)	5	5	3	3	2	3	3	2	27.1	4	2	16.3	3	3	1	6.4	2	2	2	6.9	
	6a	WWT of secondary effluent with direct discharge to the San Lorenzo River (no Filter and Fall) (DO NOT reuse NPR users along the way)	2	2	3	3	1	3	3	2	2	19.9	2	2	10.3	1	3	2	4.8	2	3	3	7.9
Alternative 6 - Streamflow Augmentation	6b	WWT of secondary effluent with indirect discharge to the San Lorenzo River (at all Stream Discharge to Fall Well Field) (DO NOT reuse NPR users along the way)	2	2	3	3	1	3	3	2	2	19.9	2	2	10.3	1	3	2	4.8	2	3	3	7.9
	7	Flow Water Bonding of Graham Hill WTP (No Coad PG)	5	5	3	3	3	4	4	2	2	29.6	4	2	16.3	3	2	2	6.4	4	2	3	51.6

PLACEHOLDER SCORES/WEIGHTING FOR EXAMPLE ONLY

Kennedy/Jenks Consultants

# Alternative Project Ranking

TABLE 8

Categories		SCORING for each Weighted Category					RANKING for each Weighted Category					
Alternative	Sub-Alt # Description	ENGINEERING/OPERATIONAL/ENVIRONMENTAL	ECONOMIC	ENVIRONMENTAL	SOCIAL	Total Score	ENGINEERING/OPERATIONAL/ENVIRONMENTAL	ECONOMIC	ENVIRONMENTAL	SOCIAL	Total Score	
Alternative 1 - Centralized Non-Potable Reuse	1a	Santa Cruz PMD Phase 2 Project	35.7	22.6	13.9	17.2	89.5	1	1	1	1	1
	1b	Maximize tertiary treatment at the SC WWTF	35.2	20.5	13.9	16.6	86.2	1	2	1	2	3
Alternative 2 - Decentralized Non-Potable Reuse	2	UC Santa Cruz	23.9	17.5	13.9	14.4	69.8	1	6	1	6	10
	3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (some NPR users along the way)	27.6	25.6	13.9	16.6	83.8	1	2	1	2	5
Alternative 3 - Santa Cruz Participation in SqCWD led Groundwater Recharge Reuse (GWR) Project	3b	Send tertiary effluent from SCWWTF to SqCWD (some NPR users along the way)	12.3	25.6	13.9	16.6	68.5	1	2	1	2	2
	3c	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF to recharge Santa Cruz GWRB (some NPR users along the way)	22.1	20.5	13.9	13.0	69.5	1	2	1	2	2
	3d	Send advanced treated RW from SCWWTF to SqCWD (some NPR users along the way)	15.0	15.0	13.9	13.0	55.9	1	2	1	2	2
	3e	Send advanced treated RW from SCWWTF to SqCWD (GWRB and NPR along the way)	15.0	15.0	13.9	13.0	55.9	1	2	1	2	2
Alternative 4 - Santa Cruz GWR Project	4a	Santa Cruz GWRB with AWTF at SC WWTF (some NPR users along the way)	22.1	20.5	13.9	13.0	69.5	1	2	1	2	2
	4b	Santa Cruz GWRB with AWTF at secondary effluent at off-site location (some NPR users along the way)	22.1	20.5	13.9	13.0	69.5	1	2	1	2	2
	4c	Santa Cruz GWRB with MBR + AWTF at LaPozah PS (some NPR users along the way)	24.8	24.4	9.3	12.6	71.1	1	2	1	2	2
	4d	Santa Cruz GWRB with MBR + AWTF at LaPozah PS (some NPR users along the way)	24.8	24.4	9.3	12.6	71.1	1	2	1	2	2
Alternative 5 - Surface Water Augmentation (SWA) in Loch Lomond Reservoir	5	Advanced treatment of Santa Cruz effluent for blending in Loch Lomond Reservoir	27.2	16.3	7.7	6.9	58.1	12	15	12	15	13
Alternative 6 - Streamflow Augmentation	6a	AWTF of secondary effluent with direct discharge to the San Lorenzo River (bif filter and T all) (some NPR users along the way)	17.7	10.3	5.4	8.1	41.4	14	13	14	13	14
	6b	AWTF of secondary effluent with indirect discharge to the San Lorenzo River (bif of Tall Street Diversion at Tall Well Field) (some NPR users along the way)	17.7	10.3	5.4	8.1	41.4	14	13	14	13	14
Alternative 7 - Direct Potable Reuse	7	Raw Water Blending at Graham Hill WTP (via Coast PS)	28.8	16.3	7.7	11.9	65.8	12	12	12	12	11

Ranking Legend: Categories

Highest Ranked	
Lowest Ranked	

PLACEHOLDER SCORES/RANKING FOR EXAMPLE ONLY

# Sensitivity Analysis

TABLE 8

Categories		RANKING for each Weighted Category					RANKING for Sensitivity Analysis					
Alternative	Sub-Alt # Description	ENGINEERING/OPERATIONAL/ENVIRONMENTAL	ECONOMIC	ENVIRONMENTAL	SOCIAL	Total Score	Equal Weighted	Maximize Water Supply	Lower Cost	Maximize Environmental Benefits	Average Project Partner Weighting Factors	
Alternative 1 - Centralized Non-Potable Reuse	1a	Santa Cruz PMD Phase 2 Project	1	1	1	1	1	1	1	1	2	
	1b	Maximize tertiary treatment at the SC WWTF	1	2	1	2	3	9	3	5	3	4
Alternative 2 - Decentralized Non-Potable Reuse	2	UC Santa Cruz	1	6	1	6	10	10	12	10	8	10
	3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (some NPR users along the way)	1	2	1	2	5	5	8	3	5	5
Alternative 3 - Santa Cruz Participation in SqCWD led Groundwater Recharge Reuse (GWR) Project	3b	Send tertiary effluent from SCWWTF to SqCWD (some NPR users along the way)	1	2	1	2	2	2	5	1	2	3
	3c	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF to recharge Santa Cruz GWRB (some NPR users along the way)	1	2	1	2	2	2	5	1	2	3
	3d	Send advanced treated RW from SCWWTF to SqCWD (some NPR users along the way)	1	2	1	2	2	2	5	1	2	3
	3e	Send advanced treated RW from SCWWTF to SqCWD (GWRB and NPR along the way)	1	2	1	2	2	2	5	1	2	3
Alternative 4 - Santa Cruz GWR Project	4a	Santa Cruz GWRB with AWTF at SC WWTF (some NPR users along the way)	1	2	1	2	2	2	5	1	2	3
	4b	Santa Cruz GWRB with AWTF at secondary effluent at off-site location (some NPR users along the way)	1	2	1	2	2	2	5	1	2	3
	4c	Santa Cruz GWRB with MBR + AWTF at LaPozah PS (some NPR users along the way)	11	9	11	9	12	12	13	13	11	12
	4d	Santa Cruz GWRB with MBR + AWTF at LaPozah PS (some NPR users along the way)	11	9	11	9	12	12	13	13	11	12
Alternative 5 - Surface Water Augmentation (SWA) in Loch Lomond Reservoir	5	Advanced treatment of Santa Cruz effluent for blending in Loch Lomond Reservoir	12	15	12	15	13	13	11			
Alternative 6 - Streamflow Augmentation	6a	AWTF of secondary effluent with direct discharge to the San Lorenzo River (bif filter and T all) (some NPR users along the way)	14	13	14	13	14	14	14			
	6b	AWTF of secondary effluent with indirect discharge to the San Lorenzo River (bif of Tall Street Diversion at Tall Well Field) (some NPR users along the way)	14	13	14	13	14	14	14			
Alternative 7 - Direct Potable Reuse	7	Raw Water Blending at Graham Hill WTP (via Coast PS)	12	12	12	12	11	11	10			

Sensitivity Analysis Weighting Factors

Equal Weighted (average of participant weighting factors)
Maximize Water Supply
Lower Cost
Maximize Environmental Benefits
Average Project Partner Weighting Factors

PLACEHOLDER SCORES/RANKING FOR EXAMPLE ONLY



# OPEN DISCUSSION

Kennedy/Jenks Consultants

## Next Steps - RWFPS Schedule

★ SWRCB Scoping Call     📄 F2F Meeting/Workshop     ◆ Draft Deliverable  
● SWRCB Meeting/Call     🗣️ Conf Call     ✓ Final Deliverable  
⬇️ SWRCB Deliverable Due     📅 Webinar

Task and Key Deliverables	2016												2017												
	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov
SWRCB Grant Commitment Letter	✓																								
SWRCB Meeting					*												●					●			
Notice to Proceed				✓																					
Task 1 - PM & QA/QC				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 2 - Background Info				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 3 - Recycled Water Market Analysis				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 4 - Treatment Eval/Reg Requirements				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 5 - Alternatives Analysis				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 6 - Stakeholder Involvement				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 7 - Recommended Project				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 8 - Financial Analysis				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 9 - Regional RWFPS Report				✓	✓	✓	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅
Task 10 - Meetings and Workshops				📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅	📅

**Next Meetings:**  
**Alternative Webinars (Oct/Nov)**  
**to present initial evaluation of alternative projects**

Part III  
Kennedy/Jenks Consultants 22

## Next Steps

- Alternative Webinar - Part I (Oct 2016)
  - **Objective:** Present evaluation for 1st set of Alternatives
    - ✓ Preliminary maps, facilities, costs, etc.
    - ✓ Alt 1&2 (NPR), **Alt 3 (NPR only)**
  - **Goal:** Obtain input and clarify assumptions
  - **Action Items:** Response to specific requests for information

Kennedy/Jenks Consultants

## Next Steps

- Alternative Webinar - Part II (Nov 2016)
  - Present evaluation for 2<sup>nd</sup> set of Alternatives
    - ✓ Preliminary maps, facilities, costs, etc.
    - ✓ Alt 5 (SWA), Alt 6 (SFA) and Alt 7 (DPR)
- **Alternative Webinar - Part III (Dec 2016/Jan 2017)**
  - **Present evaluation for 3<sup>rd</sup> set of Alternatives**
    - ✓ **Preliminary maps, facilities, costs, etc.**
    - ✓ **Alt 3 & 4 (GWRR)**

Kennedy/Jenks Consultants

## Next Steps

- Scoring & Ranking Workshop (Dec 2016)
  - **Objective:** Overview of Alternatives, Discuss Prelim Scoring and Ranking
  - **Goal:** Identify Recommended Alternative (or Phased Projects) for further development
  - **Action Items:** Input from each project partner on scoring and ranking tables.

Kennedy/Jenks Consultants

## Homework

Categories	Alternatives Screening Criteria	Considerations for Assessing Project based on Criteria	TEAM: Individual:
ENGINEERING & OPERATIONAL CONSIDERATIONS	Improve Water Supply	- Ability to fill City supply gap (1.2 BGY or 3,700 APY), supplement peak season supply with a new source or offset and/or contribute to regional supply - Ability to implement Project, with supplies available in a timely manner	<div style="border: 2px solid red; padding: 10px;"> <p><b>Please fill out and submit your proposed weightings for each of the screening criteria by Friday, Sept 2nd</b></p> </div>
	Maximize Beneficial Reuse	- Maximizes reuse of wastewater effluent now - Regulatory viability and ability to obtain a recycled water permit - Current (DOW and RWQCB) regulatory pathway/approved use	
	Ease of Implementation	- Potential construction challenges (#/size of facilities, ROW, utilities, terrain, disturbed/undisturbed area, seismic/sea level rise vulnerability, etc.) - Flexibility for phasing and opportunities to expand/transition to a higher yield and/or treatment level	
	Operational Complexity	- Source of wastewater and/or type treatment required for beneficial reuse minimizes impacts to wastewater collection and/or WWTF operations - Siting new treatment facilities minimize short-term impacts on SC WWTF operations (during construction) and long-term impacts (related to facility relocation, off-site location and/or interference with O&M activities) - Economically feasible or cost effective project (relative life cycle unit costs)	
ECONOMIC	Cost Effectiveness	- Financially implementable project (capital investment does not limit ability to implement other water projects and program)	
ENVIRONMENTAL	CEQA Considerations	- Potential environmental impacts and mitigation requirements - Enhance local and regional ecosystems and environments including rivers, groundwater basins - Social cost of carbon compared to other projects and supplies; Relative contribution to global warming (based on GHG emissions)	
	Financial Implementability	- Level of cooperation and coordination required between multiple outside agencies/users - Willingness and interest of anticipated users/partners for cost-sharing	
SOCIAL	Agency Coordination, Partnerships and Agreements	- Perceived public acceptance and comfort with level of public health and safety associated with reuse	
	Social Issues & Siting	- Level of impact on local residents for new construction and ongoing maintenance - Land acquisition requirements (property not currently owned by the City)	

\* Percentages must add up to 100%

Kennedy/Jenks Consultants

## QUESTIONS

Kennedy/Jenks:	Dawn Taffler	<a href="mailto:DawnTaffler@KennedyJenks.com">DawnTaffler@KennedyJenks.com</a>
	Melanie Tan	<a href="mailto:MelanieTan@KennedyJenks.com">MelanieTan@KennedyJenks.com</a>
Abt Associates:	Bob Raucher	<a href="mailto:Bob_Raucher@abtassoc.com">Bob_Raucher@abtassoc.com</a>
	Jim Henderson	<a href="mailto:Jim_Henderson@abtassoc.com">Jim_Henderson@abtassoc.com</a>
GHD:	Pat Collins	<a href="mailto:Pat.Collins@ghd.com">Pat.Collins@ghd.com</a>

Kennedy/Jenks Consultants 27

## THANK YOU

Kennedy/Jenks Consultants 28



## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Alternatives Webinar – Part 1

18 October 2016 from 9 am to 11 am

Conf Call - (855) 813-2486 Code – 2484

Web Meeting - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Webinar Objective:** Present preliminary evaluation for non-potable reuse (NPR) alternatives using preliminary maps, tables and figures to illustrate facility locations, capacities and costs.

**Goal:** Discuss and seek input on assumptions, facility locations and other project components.

**Action Items:** Respond to specific requests for information, update alternatives (as-needed) and memorialize discussion points to support scoring of alternative projects.

---

1. Recycled Water Supply
2. NPR Market Assessment and Demand
3. NPR Treatment Requirements
4. NPR Alternatives
  - a. Alternative 1: Centralized
  - b. Alternative 2: Decentralized
  - c. Alternative 3: Santa Cruz Participation in SqCWD-led GWRR Project (NPR uses only)
5. Quantitative Results
6. Cost Comparison
7. Qualitative Considerations
8. Next Steps

# City of Santa Cruz Recycled Water Facilities Planning Study

Alternatives Webinar Part I

October 18, 2016


*\* Includes amended notes to reflect discussion at workshop*

Kennedy/Jenks Consultants 1

## Agenda


- Approach & Objective
- Recycled Water Supply
- NPR Market Assessment and Demand
- NPR Treatment Requirements
- NPR Alternatives
  - Quantitative Results
  - Cost Comparison
- Qualitative Considerations
- Open Discussion

Kennedy/Jenks Consultants 2



## Alternatives Webinar Objective

- **Objective:** Present preliminary evaluation for non-potable reuse (NPR) alternatives using preliminary maps, tables and figures to illustrate facility locations, capacities and preliminary costs.
- **Goal:** Obtain input and clarify assumptions
- **Action Items:** Response to specific requests for information, update alternatives, and memorialize discussion points to support scoring of alternative projects.





### Recycled Water Supply



	Effluent (MGD)	2015	2008 - 2016 Average
<b>Dry Weather Flow (June)</b>	Average	6.1	7.1
	Minimum	5.4	5.1
<b>Wet Weather Flow (Dec)</b>	Average	8.4	9.0
	Maximum	20.9	28.8



- 2015 econometric analysis of demand and forecast shows average annual wastewater flow increase by 0.18 MGD (about 1%)
  - 2015 flow data is used



Kennedy/Jenks Consultants











## Satellite Treatment of Secondary Effluent



Amiad AMF Filter Pilot at Pasatiempo Golf Course

(Photo: Waterworks Engineers)

Described by manufacturer as a “self-cleaning microfiber water-filters for treatments as fine as 2 micron that provides cartridge filter performance without cartridge filter replacement”, which indicates performance similar to a tertiary media filter.

ts 15


## Treatment Evaluation for NPR of - Advance Treated Effluent -

### Reuse Type

Potable Reuse  
With Secondary  
Feedwater



Membrane  
Filtration



Reverse  
Osmosis



Ultraviolet  
Light/Advanced  
Oxidation

### Uses


- Potable and non-potable applications

Unrestricted AWT for reuse, as discussed the Alternatives Development Workshop:

- Beyond regulatory requirement for NPR
- Significantly higher cost/energy
- Keep as an option for customers along pipeline alignments that carry advanced treated water for potable reuse

*\*Based on the proposed treatment train for the SqCWD GRRP Feasibility Study.*

Graphics by Trussell



## Alternatives for Further Evaluation

- Alternative 1 – Centralized Non-Potable Reuse
- Alternative 2 – Decentralized Non-Potable Reuse
- Alternative 3 – Santa Cruz Participation in SqCWD-led GWRR Project\* \* NPR projects only
- Alternative 4 – Santa Cruz GWRR Project
- Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir
- Alternative 6 – Streamflow Augmentation
- Alternative 7 – Direct Potable Reuse


Kennedy/Jenks Consultants

## Preliminary capital & annualized costs

- Capital Costs
  - Treatment
  - Pipelines
  - Pump Stations
  - Storage
  - Site Retrofit
- Annualized capital & O&M costs for alternative comparison
- Further inputs to confirm the following after webinar
  - Phasing of capital costs
  - Pipeline special crossing costs
  - Energy and labor costs
  - Interest and contingencies
  - Retrofit costs

Kennedy/Jenks Consultants

## NPR Market Survey Map



Kennedy/Jenks Consultants

## Alternatives 1: Centralized Non-Potable Reuse

Alternative	Sub Alt	Description	Source Water	Treatment		Use
Alternative 1 - Centralized Non-Potable Reuse	1A	Santa Cruz PWD Phase 2 Project	Santa Cruz WWTF	Tertiary Treatment at SC WWTF	3°	In-plant uses, truck filling and demonstration site (park near WWTF)
	1B	Maximize tertiary treatment at the SC WWTF				3°

Kennedy/Jenks Consultants

## Alternative 1A: Santa Cruz PWD Phase 2 Project



0.25 MGD tertiary treatment capacity to meet in-plant needs and provide irrigation to La Barranca Park

- 25,000 gal New CCB
- 25,000 gal Existing CCB
- Up to 142,000 gal Storage

✓ Add pipeline to truck fill hydrant on California street

Kennedy/Jenks Consultants




## Alternative 1A: Santa Cruz PWD Phase 2 Project

- Project Size
  - 0.25 MGD tertiary treated recycled water
- Facilities
  - No new filters needed
  - Chlorine Contact Basin #2
  - Interconnecting Piping
  - Chemical dosing System
  - Control System
  - Other Miscellaneous Components – including pipeline to La Barranca Park
- RFP expected to be released late 2016

*\* Add demand and associated pipeline for hydrant at California street*

Kennedy/Jenks Consultants




### Alternative 1B: Maximize tertiary treatment at the SC WWTF

	Phase 1 (To San Lorenzo Park)	Phase 2 (To DeLaveaga Park & Golf Course)	Phase 3 (To Good Shepherd School)	Phase 4 (To UCSC)	Total
NPR Demand	0.06 MGD/ 71 AFY	0.17 MGD/ 192 AFY	0.13 MGD/ 145 AFY	0.06 MGD/ 71 AFY	<b>0.44 MGD/ 493 AFY</b>
Treatment Capacity	0.11 MGD	0.24 MGD	0.18 MGD	0.09 MGD	<b>0.62 MGD</b>
Pipelines	29,000 LF – 6"	20,000 LF – 6"	31,000 LF – 6"	14,000 LF – 6"	<b>17.5 miles</b>
Pump Stations	80 gpm 50 HP	-	500 gpm 90 HP	100 gpm, 50 HP	
Storage	To be determined by hydraulic modeling				
# of Customer Sites	7	13	29	3 clusters	<b>52</b>

Treatment capacity based on summer flow factor = 1.35  
 Pipeline and pump station sizing based on peak hourly demand, with pumping over 9 hours a day

**Kennedy/Jenks Consultants**



## Alternatives 2: Decentralized Non-Potable Reuse

Alternative	Sub Alt	Description	Source Water	Treatment		Use
Alternative 2 - Decentralized Non-Potable Reuse	2	UC Santa Cruz	Local Raw Wastewater (UCSC)	MBR at UCSC	3°	On campus uses (irrigation, agricultural, cooling towers, dual-plumbed facilities)

Kennedy/Jenks Consultants

## Alternatives 2: Decentralized Non-Potable Reuse at UCSC

- Project Size
  - 0.063 MGD tertiary treated recycled water
- Facilities
  - Decentralized MBR
  - Pipelines
  - Small Pump station
  - Pipelines
- Available sewer flows to be confirmed

✓ Confirm that potential demand from UCSC dual plumbed building has been captured

Kennedy/Jenks Consultants

## Alternatives 2: Decentralized Non-Potable Reuse at UCSC

Decentralized MBR	
NPR Demand	0.06 MGD / 71 AFY
Treatment Capacity	0.09 MGD
Pipelines	~2 miles of 6" pipeline
Pump Stations	TBD – depends on location of MBR, which depends on available WW flows
Storage	To be determined by hydraulic modeling
# of Customer Sites	3 clusters

Treatment capacity based on summer flow factor = 1.35  
Pipeline and pump station sizing based on peak hourly demand, with pumping over 9 hours a day

Kennedy/Jenks Consultants

## Alternatives 2: Decentralized Non-Potable Reuse at UCSC

Alt 2

Capital Cost (\$mil)	\$2.4
----------------------	-------

■ Annual O&M Cost (\$/AF)  
■ Annualized Buildout Unit Construction Cost (\$/AF)  
● Ave Annual Reuse (AFY)

### Preliminary capital & annualized costs

- To confirm location of MBR on UCSC campus
  - Available sewer flow
  - Land availability
- O&M costs would depend on location of facilities

Kennedy/Jenks Consultants

## Alternative 3: Santa Cruz Participation in a SqCWD-led GWRR


TABLE 3

Sub Alt	Description	Source Water	Treatment	Use
3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (serve NPR users along the way)	Santa Cruz WWTF	On-Site Treatment at NPR Customer sites	2° + filter NPR Customers along secondary pipelines alignment from SC WWTF to A WTF
3b	Send tertiary effluent from SCWWTF to SqCWD (serve NPR users along the way)		Tertiary Treatment at SC WWTF	3° NPR Customers along tertiary pipeline alignment from SC WWTF to A WTF
3c	Send additional secondary effluent from SCWWTF to SqCWD A WTF and deliver purified water from SqCWD WTF to recharge Santa Cruz GWRR		Advanced Treatment at SqCWD Headquarters	AWT SqCWD A WTF water delivered to Santa Cruz GWRR injection sites
3d	Send advanced treated RW from SCWWTF to SqCWD, (serve NPR users along the way)		Advanced Treatment at SC WWTF	AWT NPR Customers along pipeline alignment from SC WWTF to SqCWD injection sites
3e	Send advanced treated RW from SCWWTF to SqCWD, (GWRR and NPR along the way)			AWT GWRR in Santa Cruz (Beltz Well Field) and NPR customers along pipeline alignments

Today's focus is NPR in Santa Cruz - Only includes Alts 3a, 3b and 3d

- Apply to all Alt 3:*
- ✓ To include Caltrans irrigation demand
  - ✓ To include SqCWD NPR demand
  - ✓ Update pump station sizing
  - ✓ Identify one pipeline alignment for use in the RWFPS alternative comparison

## Alternative 3A: Secondary Effluent to SqCWD + NO NPR along the way



## Alternative 3A: Secondary Effluent to SqCWD NPR along the way


	Facilities
NPR Demand	0
SqCWD Demand	1.7 MGD Effluent
Treatment Capacity	No additional treatment required
Pipelines	7 miles – 14"
Pump Stations	2,800 gpm, 25 HP (or with booster station) <i>Update to reflect SqCWD constant flow</i>
Storage	To be determined by hydraulic modeling
Customer Sites	0

No NPR demand along the way.  
All 1.7 mgd RW delivered is going to SqCWD

Treatment capacity based on summer flow factor = 1.35  
Pipeline and pump station sizing based on peak hourly demand, with pumping over 9 hours a day

Kennedy/Jenks Consultants

## Alternative 3B.1: Tertiary Effluent to SqCWD + NPR along the way



Kennedy/Jenks Consultants


## Alternative 3B: Tertiary Effluent to SqCWD + NPR along the way

	Facilities
NPR Demand	0.13 MGD
SqCWD Demand	1.7 MGD Effluent
Treatment Capacity	1.87 MGD
Pipelines	7,700 LF – 6" (distribution) 7 miles – 16" (transmission – 2" larger than baseline Alt 3A )
Pump Stations	3,000 gpm, 760 HP (or with booster station) <i>Update to reflect SqCWD constant flow and NPR peak flow</i>
Storage	To be determined by hydraulic modeling
# of Customer Sites	43

Treatment capacity based on summer flow factor = 1.35 for NPR demand + no summer flow factor for SqCWD effluent demand  
Pipeline and pump station sizing based on peak hourly demand, with pumping over 9 hours a day

Kennedy/Jenks Consultants

## Alternative 3B.2: Tertiary Effluent to SqCWD + NPR along the way




## Alternative 3B.2: Tertiary Effluent to SqCWD + NPR along the way

	Facilities
NPR Demand	0.12 MGD
SqCWD Demand	1.7 MGD Effluent
Treatment Capacity	1.86 MGD
Pipelines	5,300 LF – 6" (distribution) 8.35 miles – 16" (transmission – 2" larger than baseline Alt 3A)
Pump Stations	3,000 gpm, 850 HP (or with booster station) <i>Update to reflect SqCWD constant flow and NPR peak flow</i>
Storage	To be determined by hydraulic modeling
Customer Sites	32

Treatment capacity based on summer flow factor = 1.35 for NPR demand + no summer flow factor for SqCWD effluent demand  
Pipeline and pump station sizing based on peak hourly demand, with pumping over 9 hours a day

Kennedy/Jenks Consultants

## Alternative 3D: AWT @ SC WWTF send to SqCWD + NPR along the way



✓ *Confirm that potential commercial user demands consider high quality of AWT water, as compared to tertiary water offered for other alternatives*

Kennedy/Jenks Consultants



## Alternative 3D: AWT @ SC WWTF sent to SqCWD + NPR along the way


	Facilities
NPR Demand	0.13 MGD
SqCWD Demand	1.3 MGD AWT Product Water
Treatment Capacity	0.18 MGD
Pipelines	4,200 LF – 6" (distribution) 7 miles – 14" (transmission)
Pump Stations	2,400 gpm, 215 HP (or with booster station) <i>Update to reflect SqCWD constant flow and NPR peak flow</i>
Storage	To be determined by hydraulic modeling
Customer Sites	34

Treatment capacity based on summer flow factor = 1.35 for NPR demand + no summer flow factor for SqCWD effluent demand  
Pipeline and pump station sizing based on peak hourly demand, with pumping over 9 hours a day

Kennedy/Jenks Consultants



## Alternative 3A, 3B.1, 3B.2 and 3D

■ Annual O&M Cost (\$/AF) ■ Annualized Buildout Unit Construction Cost (\$/AF) ● Ave Annual Reuse (AFY)



Capital Cost (\$mil)	Alt 3A	Alt 3B	Alt 3B alt	Alt 3D
	n/a	\$18.7	\$21.5	\$10.7
		<del>\$16.8</del>		

Kennedy/Jenks Consultants



## NPR Alternatives Evaluation Summary of QUANTITATIVE Results

Alternative	Sub Alt	Description	Treatment Level	Recycled Water Delivered				Estimated Costs			Energy / Others				
				Ave Annual Reuse (AFY)	Average Annual Flow (MGD)	Peak Season Deliveries (AF in Summer - June)	Peak Hourly Flow (MGD)	Estimated Construction Cost (\$mil)	Annual O&M Cost (\$mil/yr)	Total Annual Cost (\$/AF)	Unit Energy of RW Delivered (KWH/AF)	GHG Emissions (MTCO2/yr)	Social Cost of Carbon (\$)	Footprint (SF)	Number and Size of Facilities
Non Potable Reuse	Alt 1A	Centralized Non-Potable Reuse - Santa Cruz PWD Phase 2 Project	3 <sup>o</sup>	282	0.25	32	1.04	\$2	\$0.0	\$435	TBD	TBD	TBD	TBD	TBD
		Centralized Non-Potable Reuse - Maximize tertiary treatment at the SC WWTF		501	0.45	42	1.34				TBD	TBD	TBD	TBD	TBD
	Alt 1B	Phase 1	3 <sup>o</sup>	93	0.08	11	0.34	\$5	\$0.1	\$4,047	TBD	TBD	TBD	TBD	TBD
		Phase 2		192	0.17	22	0.71	\$4	\$0.1	\$1,764	TBD	TBD	TBD	TBD	TBD
		Phase 3		146	0.13	17	0.54	\$7	\$0.1	\$762	TBD	TBD	TBD	TBD	TBD
		Phase 4		71	0.06	8	0.26	\$3	\$0.1	\$1,162	TBD	TBD	TBD	TBD	TBD
Alt 2	Decentralized Non-Potable Reuse	3 <sup>o</sup>	71	0.06	8	0.26	\$2	\$0.1	\$3,857	TBD	TBD	TBD	TBD	TBD	
SqCWD Led GWRR	Alt 3A	Secondary Effluent to SqCWD + NPR along the way	2 <sup>o</sup> + filter	1,903	1.70	159	5.10	\$0	\$0.0	\$0	TBD	TBD	TBD	TBD	TBD
	Alt 3B	Tertiary Effluent to SqCWD + NPR along the way	3 <sup>o</sup>	141	0.13	175	5.62	\$19	\$0.5	\$11,304	TBD	TBD	TBD	TBD	TBD
	Alt 3B a	Tertiary Effluent to SqCWD + NPR along the way	3 <sup>o</sup>	132	0.12	174	5.59	\$22	\$0.6	\$13,674	TBD	TBD	TBD	TBD	TBD
	Alt 3C	Secondary Effluent to SqCWD + SC GWRR (AWT @ SqCWD)	AWT												
	Alt 3D	AWT @ SC WWTF sent to SqCWD + NPR along the way	AWT	150	0.13	17	0.55	\$11	\$0.6	\$13,674	TBD	TBD	TBD	TBD	TBD
	Alt 3E	AWT @ SC WWTF sent to SqCWD + NPR along the way + SC GWRR	AWT												
SC GWRR	Alt 4A	Santa Cruz GWRR Project - Advanced treatment at SCWWTF	2 <sup>o</sup>												
	Alt 4B	Santa Cruz GWRR Project - Advanced treatment at off-site	2 <sup>o</sup>												
	Alt 4C	Santa Cruz GWRR Project - MBR + JAWPF at DA Poram	AWT												
SWA	Alt 5	Surface Water Augmentation (SWA) in Loch Lomond Reservoir	AWT												
Stream Aug	Alt 6	Streamflow Augmentation	AWT												
DPR	Alt 7	Direct Potable Reuse	AWT												

Kennedy/Jenks Consultants

## NPR Alternatives Evaluation QUALITATIVE Considerations

Categories	Alternatives Screening Criteria	General Comments on NPR
<b>ENGINEERING &amp; OPERATIONAL CONSIDERATIONS</b>	Improve Water Supply	Ability to fill City water supply gap, supplement supply in peak season, timeline for implementation
	Beneficial Reuse of Wastewater	Maximizes reuse of wastewater now and/or does not limit future options to fully utilize wastewater
	Ease of Implementation	Permitability, construction complexity, flexibility for phasing and potential for expansion
	Operational Complexity	Treatment requirements and impacts to WWTF, facility siting
<b>ECONOMIC</b>	Cost Effectiveness	Relative unit costs
	Financial Implementability	Relative capital costs and tradeoffs
<b>ENVIRONMENTAL</b>	CEQA Considerations	Potential impacts and mitigation requirements
	Environmental Enhancement	Opportunity to enhance ecosystem and social cost of carbon (GHG emissions)
<b>SOCIAL</b>	Agency Coordination, Partnerships and Agreements	Level of effort and willingness to work together
	Social Issues & Siting	Public acceptance and local disruption

Kennedy/Jenks Consultants




FIGURE 1 – Screening Webinar

# QUESTIONS

Kennedy/Jenks:

Dawn Taffler  
Melanie Tan

[DawnTaffler@KennedyJenks.com](mailto:DawnTaffler@KennedyJenks.com)  
[MelanieTan@KennedyJenks.com](mailto:MelanieTan@KennedyJenks.com)

Kennedy/Jenks Consultants



## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Alternatives Webinar – Part 2

**02 December 2016 from 9 am to 11 am**

Conf Call - (855) 813-2486 Code – 2484

Web Meeting - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Webinar Objective:** Present preliminary evaluation for surface water augmentation (SWA), streamflow augmentation and direct potable reuse (DPR) alternatives using preliminary maps, tables and figures to illustrate facility locations, capacities and costs.

**Goal:** Discuss and seek input on assumptions, facility locations and other project components.

**Action Items:** Respond to specific requests for information, update alternatives (as-needed) and memorialize discussion points to support scoring of alternative projects.

---

1. Approach & Objective
2. Recycled Water Supply
3. Market Assessment for Potable Reuse
4. Treatment Requirements
5. SWA Alternative
6. Streamflow Augmentation Alternative
7. Direct Potable Reuse Alternative
8. Cost Comparison
9. Next Steps

# City of Santa Cruz Recycled Water Facilities Planning Study

Alternatives Webinar Part 2

December 02, 2016


*\* Includes amended notes to reflect discussion at workshop*

Kennedy/Jenks Consultants 1

## Agenda

- Approach & Objective
  - Recycled Water Supply
  - Market Assessment for Potable Reuse
  - Treatment Requirements
  - Alternatives Analysis
    - Surface Water Augmentation
    - Streamflow Augmentation
    - Direct Potable Reuse
  - Cost Comparison
  - Open Discussion
- } Facilities  
Quantitative Results  
Qualitative Considerations


Kennedy/Jenks Consultants 2



## Alternatives Webinar Objective

- **Objective:** Present preliminary evaluation for potable reuse alternatives using preliminary maps, tables and figures to illustrate facility locations, capacities and preliminary costs.
- **Goal:** Obtain input and clarify assumptions
- **Action Items:** Response to specific requests for information, update alternatives, and memorialize discussion points to support scoring of alternative projects.





### Total Available Effluent Supply

	Effluent (MGD)	2015	2008 - 2016 Average
<b>Dry Weather Flow (June)</b>	Average	6.1	7.1
	Minimum	5.4	5.1
<b>Wet Weather Flow (Dec)</b>	Average	8.4	9.0
	Maximum	20.9	28.8

- 2015 dry weather flow data is used to estimate the amount of effluent that would be consistently available for potable reuse

Kennedy/Jenks Consultants

## Purified Water Supply for Potable Reuse Alternatives

Total WW Supply	SC WWTF In-Plant Demand	SqCWD GWRR Demand	Secondary Effluent Available	Purified Water Produced
Average Daily Dry Weather Flow <sup>1</sup> (mgd)	Year-Round Internal Use + La Barranca Park <sup>2</sup> (mgd)	Year-Round Secondary Effluent (mgd)	after meeting other Demands (mgd)	Based on assumed AWPf Recovery Rate <sup>3</sup>
6.1	0.25	1.7	4.16	3.2

<sup>1</sup> Based on June 2015 flow data

<sup>2</sup> Assumes no additional NPR demands in Santa Cruz will be served

<sup>3</sup> Assumes MF/UF recover rate of 90% and RO recovery rate of 85%

Discussion that there may be an interest in serving NPR demands along a purified water alignment even if these demands were small. Review of potential customers only identified ~ 0.02 mgd of demand along the purified water alignments. These customers could be added later but recommendation was not to complicate the potable reuse alternatives.


Brine

Kennedy/Jenks Consultants

## Market Assessment for Potable Reuse

- Includes indirect and direct potable reuse opportunities
- Not associated with meters
- Focus is a more holistic approach to beneficially reuse the recycled water for potable uses, directly or indirectly, to fill the Santa Cruz region water supply gaps

Kennedy/Jenks Consultants



## Recycled Water Market: Potable Reuse

Potable Reuse	Available Supply mgd (AFY)	Demand mgd (AFY)	Use Limited by
Groundwater Recharge *	3.2 mgd (3,600 AFY)	TBD*	<ul style="list-style-type: none"> <li>Summer wastewater generation</li> <li>GRR Regulations</li> <li>Groundwater Basin Capacity</li> <li>Travel time from injection to extraction</li> </ul>
Surface Water Augmentation	3.2 mgd (3,600 AFY)	3.2 mgd (3,600 AFY)	<ul style="list-style-type: none"> <li>Summer wastewater generation</li> <li>SWA Regulations</li> <li>Operation of Loch Lomond Reservoir</li> </ul>
Streamflow Augmentation	3.2 mgd (3,600 AFY)	3.2 mgd (3,600 AFY)	<ul style="list-style-type: none"> <li>Summer wastewater generation</li> <li>TMDL for Nitrate</li> <li>Basin Plan requirements for Temperature and Dissolved Oxygen</li> </ul>
Direct Potable Reuse	3.2 mgd (3,600 AFY)	3.2 mgd (3,600 AFY)	<ul style="list-style-type: none"> <li>Summer wastewater generation</li> <li>GHWTP Treatment Capacity</li> <li>Coast Pump Station Capacity</li> <li>Pending DPR Regulations</li> </ul>

\* The demand for a GRRP will be evaluated based on the capacity of the groundwater aquifer to receive recycled water and meet GRR regulatory criteria.

Kennedy/Jenks Consultants

## Recycled Water Market: Potable Reuse

### Potential Benefits

- Develop a local, drought-proof and sustainable water supply
- Use of available recycled water flows in the winter and off-peak irrigation months
- Recharge groundwater basin(s) (via groundwater recharge)
- Maintain lake levels (via surface water augmentation)
- Supplement in-stream flows to maintain habitat and fisheries
- Provide an integrated approach solving multiple issues related to regional water supplies, which could bring together a number of stakeholders in the Santa Cruz Region

### Potential Challenges

- Higher costs associated with advanced treatment
- Higher costs associated with pumping and conveyance (for GRR and SWA projects)
- Additional regulatory requirements (i.e. permitting, monitoring, and reporting)
- Public acceptance
- Development of partnerships and agreements (between regional partners)
- Regulatory uncertainty related to SWA and DPR requirements

Kennedy/Jenks Consultants

## Market Assessment: Surface Water Augmentation

- No SWA projects currently exist in California
  - 2 moving forward
- Draft Uniform SWA criteria anticipated by end of 2016 and finalized in early 2017.
- Two key permits
  - City DDW drinking water supply permit
  - NPDES permit by RWQCB on behalf of EPA

Kennedy/Jenks Consultants

## Market Assessment: Surface Water Augmentation

- Minimum Retention Time of 4 to 6 months (TBD)
- Dilution and Mixing Options:
  - 100-to-1 dilution, or
  - 10-to-1 dilution with additional 1-log treatment
- Other Considerations
  - Source control
  - Reservoir O&M
  - Reliability, redundancy and response to failure
  - Reservoir dilution, retention, tracer studies and monitoring, and
  - public comment and notification

Kennedy/Jenks Consultants

## Market Assessment: Surface Water Augmentation

- RWFPS Concept
  - Augment Loch Lomond Reservoir
  - Surface water impoundment used for drinking water
  - GHWTP provides additional treatment prior to potable distribution
- Market Limited by:
  - Wastewater generation
  - SWA Regulations



Kennedy/Jenks Consultants

## Market Assessment: Streamflow Augmentation

- Currently no regulatory requirements and/or criteria for the beneficial use of recycled water for streamflow augmentation
  - Wastewater discharge is regulated by WDRs and NPDES permits
  
- Considerations
  - Water quality objectives in receiving water
  - Ecological risks
  - Public acceptance

Kennedy/Jenks Consultants

## Market Assessment: Streamflow Augmentation

- San Lorenzo River & Lagoon
  - 1.5 mg/L nitrate TMDL
  - Temp and Dissolved Oxygen (DO) Objectives
  - Eutrophication issues, morphology
- RWFPS Concept
  - Discharge purified water d/s of Tait Street Diversion
  - Maximize diversions within existing water rights
  - Reduce peak water supply shortage in dry years
- Market Limited by:
  - Wastewater generation
  - TMDL
  - Temperature and DO WQOs



Kennedy/Jenks Consultants

## Market Assessment: Direct Potable Reuse



- Loss of Environmental Buffer
  - For treatment
  - For response time
- Treatment Robustness and Reliability
  - Assurance of meeting microbial pathogen and chemical risk
- Other Considerations
  - Source Control
  - Coordination btw WWTF and DWTF
  - Public Perception
- Research needs to fill knowledge gaps

Kennedy/Jenks Consultants

## Market Assessment: Direct Potable Reuse

- RWFPS Concept
  - Provide highest level of advanced treatment
  - Blend with other raw water supplies entering the GHWTP
  - Utilize existing potable water distribution system.
- Market limited by
  - Wastewater generation
  - GHWTP Treatment Capacity
  - Coast Pump Station Capacity

Kennedy/Jenks Consultants





## Treatment Criteria - SWA

- Pathogen credits to be achieved at both the AWTF and the Drinking Water Treatment Facility
- Log reduction of V/G/C\* depends on:
  - Amount of dilution in the reservoir
  - Amount of residence time in reservoir

Dilution	Total log reduction	DWTF log reduction	AWTF log reduction (min)
100-to-1	12/10/10	4/3/2	8/7/8
10-to-1	13/11/11	4/3/2	9/8/9

\*V/G/C = virus, *Giardia*, and *Cryptosporidium*

Kennedy/Jenks Consultants

## Advanced Treatment Process - SWA

### Reuse Type

Potable Reuse  
With Nitrified  
Secondary  
Feedwater

### Potential Treatment Train\*



Membrane  
Filtration



Reverse  
Osmosis



Ultraviolet  
Light/Advanced  
Oxidation



Free Chlorine

- Potable and non-potable applications

Log Removal	MF	RO	UV/AOP	Free Chl.	Total
Virus	0	1.5 – 2	6	6	13.5 – 14
<i>Giardia</i>	4	1.5 – 2	6	0-1	11.5 – 13
<i>Cryptosporidium</i>	4	1.5 – 2	6	0	11.5 – 12

\*Assumes conservative reservoir operation with V/Q > 6 months and > 10:1 dilution

Discussion about need for denitrification at the WWTF and whether to include a placeholder cost

Kennedy/Jenks Consultants

## Treatment Criteria – Streamflow Augmentation

- Not defined in Title 22
- Likely site specific based on discharge requirements
- San Lorenzo River/Lagoon Considerations
  - Nutrients (nitrate TMDL)
  - Temperature
  - Dissolved Oxygen

Kennedy/Jenks Consultants

## Market Assessment: Streamflow Augmentation

- Nitrate Mass Target in SLR at Felton = 3,728 lbs nitrate per month
- Nitrate Concentration Target = 1.5 mg/L

Units		Secondary Effluent	Tertiary Effluent	Full Advanced Treatment	
Recycled Water	mgd	3.0	3.0	3.0	
Discharged	Nitrate concentration (as mg nitrate/L)	79	44	16	4
Nitrate Mass	lbs nitrate / month (as nitrate)	61,100	34,500	12,400	3,500
	Percent of Target load at Felton	1600%	930%	330%	90%

Comment that there is already an existing nitrate load of 3,600 lbs/month in the watershed so adding 3,500 from purified water would exceed the mass target.

Kennedy/Jenks Consultants


## Market Assessment: Streamflow Augmentation

- Temperature Objective per Basin Plan
  - Discharge < 5 deg F diff from ambient or no change
- DO Objective per Basin Plan
  - Discharge > 7.0 mg/L or > 5 mg/L

Comment that a 303D list may come out next week that will further address temperature

Ave monthly WWTF Temp  
- Ave monthly River Temp  
1.2 to 1.5 deg F;

Max monthly WWTF Temp  
- Min monthly River Temp  
6.5 to 17 deg F.



## Treatment Criteria – Streamflow Augmentation

- Assume same criteria as for SWA
  - 13/11/11 log reduction of V/G/C\*
- Additional treatment may be required for
  - Temperature reduction
  - Denitrification

Discussion about need for denitrification at the WWTF and whether to include a placeholder cost. Similarly, need and cost for temperature reducing facility (i.e. cooling tower) and whether to include a placeholder cost.

\*V/G/C = virus, *Giardia*, and *Cryptosporidium*

## Market Assessment: Direct Potable Reuse

- Per the Water Code, DPR comprises the
  - “planned introduction of recycled water either directly into a public water system...or into a raw water supply immediately upstream of a water treatment plant.”
- No DPR projects currently exist in California
- Draft DPR Feasibility Report recognized phased implementation of three types of DPR projects
  1. Source water Augmentation
  2. Direct Raw water Augmentation
  3. Direct Distribution in Drinking Water Supply
- Primary challenge is to ensure public health is reliably protected

Kennedy/Jenks Consultants

## Treatment Criteria - DPR

- No existing regulations or applications in California
- No specific LRV requirements for DPR
  - Bookend the range of likely value
  - Assume more stringent than SWA b/c no env buffer

DPR	Total log reduction	DWTF log reduction	AWTF log reduction (min)	
Source Water Blending	14/12/12 to 20/19/16	4/3/2	10/9/10 to 16/16/14	
Pipe-to-Pipe	13/11/11 to 20/19/16	0/0/0	13/11/11 to 20/19/16	Not included in RWFPS Alternatives

Kennedy/Jenks Consultants

## Advanced Treatment Process - DPR

**Reuse Type**

Potable Reuse With Nitrified, Filtered Feedwater

**Potential DPR Treatment\***

O<sub>3</sub>/BAC    Membrane Filtration    Reverse Osmosis    Ultraviolet Light/Advanced Oxidation    Free Chlorine

**Uses**

- Potable and non-potable applications

Log Removal	O <sub>3</sub> /BAC	MF	RO	UV/AOP	Free Chl.	Total
Virus	6	0	1.5 – 2	6	6	19.5 – 20
Giardia	6	4	1.5 – 2	6	0-1	17.5 – 19
Cryptosporidium	1-2	4	1.5 – 2	6	0	12.5 – 14

\*Based on treatment train studied in WRRF 14-12 and evaluated by State DPR Expert Panel

Kennedy/Jenks Consultants

## Treatment Facility Siting

- Santa Cruz WWTF
- Delaware Industrial Site
- Other locations

For Potable Reuse Alternatives: assume AWTF at the industrial site with caveat that the facility could be located at the SC WWTF or another site to be determined.

Discussion about benefits of keeping AWTF at the WWTF to address prior concerns by public. Challenge is space, competing projects and need to relocate facilities. City to reconsider decision on whether Alts 5-7 should show AWTF at WWTF

## Brine Discharge

- Potential Concerns

- TDS

- ✓ No TDS limit – exception because of TDS of marine waters exceed 3,000 mg/L
    - ✓ Brine likely around 6,000 – 7,000 mg/L, 25% of ocean TDS

- Toxicity

- ✓ Discharge mixing nozzle can be added

City's existing outfall has a diffuser at the end.

Kennedy/Jenks Consultants

## Alternatives for Further Evaluation

- Alternative 1 – Centralized Non-Potable Reuse
- Alternative 2 – Decentralized Non-Potable Reuse
- Alternative 3 – Santa Cruz Participation in SqCWD-led GWRR Project
- Alternative 4 – Santa Cruz GWRR Project
- Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir
- Alternative 6 – Streamflow Augmentation (SFA)
- Alternative 7 – Direct Potable Reuse (DPR)

Kennedy/Jenks Consultants

## Preliminary capital & annualized costs

- Capital Costs
  - Treatment
  - Pipelines
  - Pump Stations
  - Storage
  - Site Retrofit
- Annualized capital & O&M costs for alternative comparison
- Further inputs to confirm the following after webinar
  - Phasing of capital costs
  - Pipeline special crossing costs
  - Energy and labor costs
  - Interest and contingencies

Kennedy/Jenks Consultants

## Alternative 5: Surface Water Augmentation

TABLE 3

Sub Alt	Description	Source Water	Treatment	Use
5	Advanced treatment of Santa Cruz effluent for blending in Loch Lomond Reservoir	Santa Cruz WWTF	Advanced Treatment at SC WWTF (or Offsite?)	AWT Reservoir augmentation in Loch Lomond for blending and storage, to be conveyed to the GHWTP and enter the City's potable water distribution system.

Kennedy/Jenks Consultants

## Alternative 5: Surface Water Augmentation



- AWTF capacity 3.2 mgd
- Brine to existing ocean outfall
- Conveyance to Loch Lomond
- Point of discharge TBD
- Other uses – not included in costs
  - 0.25 MGD Phase 2
  - 1.70 MGD Secondary to SqCWD

3.2 MGD Purified water to Loch Lomond

Kennedy/Jenks Consultants

## Suitability of SWA at Loch Lomond

### Reservoir Dilution

- ✓ Purified water discharged during any 24-hour period must achieve a minimum 10:1 dilution into water that has been previously discharged into the reservoir
- ✓ Dilution must be verified by modeling and tracer studies
- ✓ The reservoir can theoretically be 100% comprised of purified water, as purified water that has been in the reservoir longer than a day can be used to meet the 10:1 dilution requirement
- ✓ The 3.2 mgd Loch Lomond purified discharge will be small compared to reservoir volume
- ✓ 10:1 dilution should be achievable even if the AWPf discharge point is near the withdrawal point
- ✓ It may be possible to achieve a 100:1 dilution of a 24-hour discharge with an appropriately engineered outfall/diffuser system

Kennedy/Jenks Consultants



## Suitability of SWA at Loch Lomond

### Computed Monthly Hydraulic Detention Time

Total Monthly Reservoir Withdrawals (Q) (water supply plus fish releases)			Computed Hydraulic Detention Time, V/Q (months) <sup>1</sup>								
			Reservoir volume (V) at the end of the month (% capacity and acre-feet)								
mgd	MG/month	AF/month	95%	90%	85%	80%	75%	70%	65%	60%	55%
3.2	99	304	28.1	26.6	25.1	23.6	22.2	20.7	19.2	17.7	16.2
3.6	112	342	24.9	23.6	22.3	21.0	19.7	18.4	17.1	15.8	14.4
4.0	124	381	22.4	21.3	20.1	18.9	17.7	16.5	15.4	14.2	13.0
4.4	136	419	20.4	19.3	18.3	17.2	16.1	15.0	14.0	12.9	11.8
4.8	149	457	18.7	17.7	16.7	15.8	14.8	13.8	12.8	11.8	10.8
5.2	161	495	17.3	16.4	15.4	14.5	13.6	12.7	11.8	10.9	10.0
5.6	174	533	16.0	15.2	14.3	13.5	12.7	11.8	11.0	10.1	9.3
6.0	186	571	15.0	14.2	13.4	12.6	11.8	11.0	10.2	9.5	8.7
6.4	198	609	14.0	13.3	12.6	11.8	11.1	10.3	9.6	8.9	8.1
6.8	211	647	13.2	12.5	11.8	11.1	10.4	9.7	9.0	8.3	7.6
7.2	223	685	12.5	11.8	11.2	10.5	9.8	9.2	8.5	7.9	7.2
7.6	236	723	11.8	11.2	10.6	9.9	9.3	8.7	8.1	7.5	6.8
8.0	248	761	11.2	10.6	10.0	9.5	8.9	8.3	7.7	7.1	6.5
8.4	260	799	10.7	10.1	9.6	9.0	8.4	7.9	7.3	6.8	6.2
8.8	273	837	10.2	9.7	9.1	8.6	8.1	7.5	7.0	6.4	5.9
9.2	285	875	9.8	9.2	8.7	8.2	7.7	7.2	6.7	6.2	5.6
9.6	298	913	9.4	8.9	8.4	7.9	7.4	6.9	6.4	5.9	5.4
10.0	310	951	9.0	8.5	8.0	7.6	7.1	6.6	6.1	5.7	5.2
10.4	322	989	8.6	8.2	7.7	7.3	6.8	6.4	5.9	5.7	5.2
10.65 <sup>2</sup>	330	1013	8.4	8.0	7.5	7.1	6.7	6.2	5.8	5.3	4.9

#### Key Take Aways:

- ✓ Monthly detention times (V/Q) > 6 months when reservoir volume > 6,000 AF
- ✓ The addition of 3,600 AF of purified water (3.2 mgd) would likely maintain storage above 6,500 AF
- ✓ SWA criteria may allow for as low as 4 months detention time

Kennedy/Jenks Consultants

## Other SWA Considerations

- **Biostimulation: controlling concentrations of nitrogen and phosphorus**
  - ✓ Potential to comply with Basin Plan Objective through phosphorus-limited approach
  - ✓ Requires coordination with regulatory agencies
- **Compliance with Drinking Water Standards**
  - ✓ AWPf will comply with drinking water standards and exceed existing reservoir water quality
  - ✓ To be confirmed with pilot testing

Discussion about SLR as a nitrogen limited system due to the naturally occurring loads of phosphorus in the river. Emphasis that modeling and monitoring phosphorus will be critical to validate.

## Other SWA Considerations

- **Toxics Rule Compliance**
  - ✓ AWPf likely to comply with most CTR standards for aquatic habitat
  - ✓ Compliance with NDMA and NDPA CTR standards may require special monitoring and analysis
  - ✓ Additional data is needed
  
- **Hydrodynamic reservoir modeling and tracer studies**
  - ✓ Required to confirm initial and 24-hour dilution


Kennedy/Jenks Consultants

## Alternative 5: Surface Water Augmentation

Loch Lomond Reservoir Augmentation	
NPR Demand	No new customers added
AWPF Capacity	3.2 MGD
Pipelines	~13.0 miles of 14" pipeline (to Loch Lomond) ~1.3 miles of 16" pipeline (to AWT) ~1.3 miles of 8" pipeline (brine line)
Pump Stations	2,222 gpm (3.2 mgd) 412 TDH; 1,400 HP
Discharge Facility	3.2 MGD

- ✓ Assumes that Phase 2 is implemented (does not include assoc. facilities and costs)
- ✓ Assumes that secondary effluent is delivered for the SqCWD GWRR Project (does not include assoc. facilities and costs)
- ✓ Treatment capacity = produced flow (based on available summer flows)
- ✓ Pipeline and pump station sizing based on average daily flow

Kennedy/Jenks Consultants






### Alternative 6: Streamflow Augmentation

Sub Alt	Description	Source Water	Treatment	Use
6	AWTF of secondary effluent with direct discharge to the San Lorenzo River <i>(serve NPR users along the way)</i>	Santa Cruz WWTF	Advanced Treatment at SC WWTF <i>(or Offsite?)</i>	AWT Augment San Lorenzo River flows to allow for increased diversions to expand future drinking water supplies, while maintaining habitat, and meeting fishery flow requirements.

- All purified water is delivered to the stream due to limitation of summer effluent.
- Removed sub-alternative for discharge near felton due to potential for classification as a direct potable reuse Project.

Kennedy/Jenks Consultants

### Alternative 6: Streamflow Augmentation Direct Discharge to San Lorenzo River


**Felton Diversion**

**Tait Street Diversion**

**Coast Pump Station**

Kennedy/Jenks Consultants

### Streamflow Augmentation



**Tait Street Diversion:**

- Concrete box with circular screened intake
- 6 - 7 mgd capacity
- Cleared in low season when top exposed
- Flows into a sump that blends raw water supplies from north coast, Lidel springs, major diversions, Laguna and SLR
- Pumped to GHWTP

**Key Considerations:**

- Meeting TMDL for Nitrogen in the river
- Temperature/DO of discharge flow
- Eutrophication in the Lagoon
- Proximity of point of discharge to Tait Street Diversion

The Confluence Model shows that:

- ✓ 5 cfs (3.2 mgd) of streamflow augmentation could
- ✓ reduce a worst year peak season shortage by 500 mg/year, or

K/J to work with City/Gary Fiske to confirm the assumed reasonable annual discharge volume for streamflow augmentation – 3.2 mgd max in summer but the annual average discharge would be less to recognize that the augmentation would only occur primarily in the summer (Confluence Model based on 181 days) and likely not in winter.

## Streamflow Augmentation



**Discharge Facility Concept:**

- Multi-port diffuser
- Maximize rapid and complete dispersion
- Minimize disruption to receiving water
- Maintain separation from Tait Street diversion



*Santa Rosa Diffuser*

- 48 mgd capacity,
- 48"-dia pipeline,
- 40 ft-long diffuser,
- 11, 24"-dia duckbill valves
- Above ground steel tee with manway access and air event

Kennedy/Jenks Consultants


## Alternative 6: Streamflow Augmentation

	Direct Discharge
NPR Demand	No new customers added
AWPF Capacity	3.2 MGD
Pipelines	~2.6 miles of 14" pipeline (to discharge) ~1.3 miles of 16" pipeline (to AWT) ~1.3 miles of 8" pipeline (brine line)
Pump Stations	2,222 gpm (3.2 mgd) 50 TDH; 170 HP
Discharge Facility	3.2 MGD

- ✓ Assumes that Phase 2 is implemented (does not include assoc. facilities and costs)
- ✓ Assumes that secondary effluent is delivered for the SqCWD GWRR Project (does not include assoc. facilities and costs)
- ✓ Treatment capacity = produced flow (based on available summer flows)
- ✓ Pipeline and pump station sizing based on average daily flow

Kennedy/Jenks Consultants

## Alternative 6: Streamflow Augmentation



## Alternative 7: Direct Potable Reuse

TABLE 3

Sub Alt	Description	Source Water	Treatment	Use
7	Raw Water Blending at Graham Hill WTP (via Coast PS)	Santa Cruz WWTF	Advanced Treatment at SC WWTF (or Offsite?)	AWT The advanced treated water would be blended with raw water coming from North Coast sources, the San Lorenzo River, and Loch Lomond water at the Coast Pump Station, and further treated at the GHWTP prior to distribution as finished water, suitable for drinking.

### Alternative 7: DPR with Raw Water Blending at Graham Hill WTP



- **GHWTP** : Treat blended raw water + purified water to produce drinking water
- **Coast Pump Station:** Raw Water
- **SC WWTP + AWWP:** Purified Water

Kennedy/Jenks Consultants


### Alternative 7: DPR with Raw Water Blending at Graham Hill WTP

	Direct Discharge
NPR Demand	No new customers added
AWPF Capacity	3.2 MGD
Pipelines	~2.6 miles of 14" pipeline (to Coast PS) ~1.3 miles of 16" pipeline (to AWT) ~1.3 miles of 8" pipeline (brine line)
Pump Stations	2,222 gpm (3.2 mgd) 85 TDH; 280 HP
Mixing (?) – check with Todd	3.2 MGD
Storage	Engineered Storage Buffer

- ✓ Assumes that Phase 2 is implemented (does not include assoc. facilities and costs)
- ✓ Assumes that secondary effluent is delivered for the SqCWD GWRR Project (does not include assoc. facilities and costs)
- ✓ Treatment capacity = produced flow (based on available summer flows)
- ✓ Pipeline and pump station sizing based on average daily flow

Kennedy/Jenks Consultants

## Alternative 7: DPR with Raw Water Blending at Graham Hill WTP



### Qualitative Considerations?


- Potential to maximize beneficial reuse of wastewater in summer
- Existing regulations have not been developed
- Operational complexity for treatment
- Impact on GHWTP source water issues (i.e. high turbidity, high TOC, DBPs, solids, etc)
- High energy/GHG emissions for treatment
- Public acceptance uncertain

Kennedy/Jenks Consultants

## Alternatives 5, 6 and 7 Evaluation Preliminary Summary of Eng Opinion of Probable Costs

■ Annual O&M Cost (\$/AF)    ■ Annualized Buildout Unit Construction Cost (\$/AF)    ● Ave Annual Reuse (AFY)

- ✓ 60% of Capital Cost is for Treatment
- ✓ 40% of Capital Cost is for Conveyance
- ✓ 40% of O&M Cost is for Energy




- ✓ 80% of Capital Cost is for Treatment
- ✓ 20% of Capital Cost is for Conveyance
- ✓ 34% of O&M Cost is for Energy

Preliminary capital & annualized costs

Kennedy/Jenks Consultants






### NPR Alternatives Evaluation Summary of QUANTITATIVE Results

Alternative	Sub Alt	Description	Treatment (Level)	Recycled Water Delivered				Estimated Costs			Energy / Others				
				Ave Annual Reuse (AFY)	Average Annual Flow (MGD)	Peak Season Deliveries (AF in Summer-June)	Peak Hourly Flow (MGD)	Estimated Construction Cost (\$mil)	Annual O&M Cost (\$mil/yr)	Total Annual Cost (\$/AF)	Unit Energy of RW Delivered (KWH/AF)	GHG Emissions (MTCO2/yr)	Social Cost of Carbon (\$)	Footprint (SP)	Number and Size of Facilities
Non Potable Reuse	Alt 1A	Centralized Non-Potable Reuse - Santa Cruz PHD Phase 2 Project	3"	282	0.25	32	1.04	\$2	\$0.0	\$545	TBD	TBD	TBD	TBD	TBD
	Alt 1B	Centralized Non-Potable Reuse - Maximize tertiary treatment at the SC WWTF	3"	866	0.77	67	2.16								
		Phase 1		340	0.30	32	1.04	\$6	\$0.1	\$8,311	TBD	TBD	TBD	TBD	TBD
		Phase 2		27	0.02	4	0.14	\$4	\$0.1	\$10,696	TBD	TBD	TBD	TBD	TBD
		Phase 3		146	0.13	23	0.74	\$8	\$0.1	\$955	TBD	TBD	TBD	TBD	TBD
Alt 2	Decentralized Non-Potable Reuse	3"	71	0.06	11	0.32	\$3	\$0.1	\$4,641	TBD	TBD	TBD	TBD	TBD	
SqCWD Led GWRR	Alt 3A	Secondary Effluent to SqCWD + NPR along the way	2" + filter	1,903	1.70	219	2.35	\$20	\$0.6	\$891	TBD	TBD	TBD	TBD	TBD
	Alt 3B	Tertiary Effluent to SqCWD + NPR along the way	3"	545	0.49	293	3.14	\$27	\$0.7	\$4,099	TBD	TBD	TBD	TBD	TBD
	Alt 3C	Secondary Effluent to SqCWD + SC GWRR (AWT @ SqCWD)	AWT	0	0.00	0	0.00	#N/A	#N/A	#N/A	TBD	TBD	TBD	TBD	TBD
	Alt 3D	AWT @ SC WWTF sent to SqCWD + NPR along the way	AWT	82	0.07	13	0.42	\$12	\$0.6	\$15,237	TBD	TBD	TBD	TBD	TBD
	Alt 3E	AWT @ SC WWTF sent to SqCWD + NPR along the way + SC GWRR	AWT	0	0.00	\$0.0	\$0	#N/A	#N/A	#N/A	TBD	TBD	TBD	TBD	TBD
SC GWRR	Alt 4A	Santa Cruz GWRR Project - Advanced treatment at SCWWTF	2"	0	0.00	0.00	\$0	#N/A	#N/A	#N/A	TBD	TBD	TBD	TBD	TBD
	Alt 4B	Santa Cruz GWRR Project - Advanced treatment at off-site	2"	0	0.00	0.00	\$0	#N/A	#N/A	#N/A	TBD	TBD	TBD	TBD	TBD
	Alt 4C	Santa Cruz GWRR Project - MBR + AWWP at DA Porch	AWT	0	0.00	0.00	\$0	#N/A	#N/A	#N/A	TBD	TBD	TBD	TBD	TBD
SWA	Alt 5	Surface Water Augmentation (SWA) in Loch Lomond Reservoir	AWT	3,584	3.20	412.16	\$4	\$116	\$4	\$3,118	TBD	TBD	TBD	TBD	TBD
Stream Aug	Alt 6	Streamflow Augmentation	AWT	3,584	3.20	412.16	\$4	\$83	\$3	\$2,028	TBD	TBD	TBD	TBD	TBD
DPR	Alt 7	Direct Potable Reuse	AWT	3,584	3.20	412.16	\$4	\$113	\$3	\$2,659	TBD	TBD	TBD	TBD	TBD

Kennedy/Jenks Consultants



## QUESTIONS

Kennedy/Jenks:

Dawn Taffler

[DawnTaffler@KennedyJenks.com](mailto:DawnTaffler@KennedyJenks.com)

Melanie Tan

[MelanieTan@KennedyJenks.com](mailto:MelanieTan@KennedyJenks.com)

Michael Welch:

Michael Welch

[mwelch1@san.rr.com](mailto:mwelch1@san.rr.com)

Trussell Tech:

Brian Pecson

[brianp@trusselltech.com](mailto:brianp@trusselltech.com)

Kennedy/Jenks Consultants



## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Alternatives Webinar – Part 3

**01 March 2017 from 9 am to 10:30 am**

Conf Call - (855) 813-2486 Code – 2484

Web Meeting - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Webinar Objective:** Present preliminary evaluation for groundwater replenishment reuse alternatives within the City’s boundaries using preliminary maps, tables and figures to illustrate facility locations, capacities and costs.

**Goal:** Discuss and seek input on assumptions, facility locations and other project components.

**Action Items:** Respond to specific requests for information, update alternatives (as-needed) and memorialize discussion points to support scoring of alternative projects.

---

1. Approach & Objective
2. Recycled Water Supply
3. Market for Groundwater Replenishment Reuse (GRR)
4. GRR Treatment Requirements
5. Beltz Wellfield Injection Capacity and Siting Study
6. Alternatives Analysis
  - a. Alternative 3 – Santa Cruz Participation in SqCWD-led GWRR Project
  - b. Alternative 4 – Santa Cruz GRR Project
7. Cost Comparison
8. Open Discussion
9. Next Steps

# City of Santa Cruz Recycled Water Facilities Planning Study

Alternatives Webinar Part 3

March 1, 2017


*\* Includes amended notes to reflect discussion at workshop*

Kennedy/Jenks Consultants 1

## Agenda

- Approach & Objective
  - Recycled Water Supply
  - Market for Groundwater Replenishment Reuse (GRR)
  - GRR Treatment Requirements
  - Beltz Wellfield Injection Capacity and Siting Study
  - Alternatives Analysis
    - Alternative 3 – Santa Cruz Participation in SqCWD-led GWRR Project
    - Alternative 4 – Santa Cruz GRR Project
  - Cost Comparison
  - Open Discussion
- } Facilities  
} Quantitative  
} Results  
} Qualitative  
} Considerations


Kennedy/Jenks Consultants 2



### Alternatives Webinar Objective

- **Objective:** Present preliminary evaluation for potable reuse alternatives using preliminary maps, tables and figures to illustrate facility locations, capacities and preliminary costs.
- **Goal:** Obtain input and clarify assumptions
- **Action Items:** Response to specific requests for information, update alternatives, and memorialize discussion points to support scoring of alternative projects.

Kennedy/Jenks Consultants



### Santa Cruz WWTF Supply for GRRP Alternatives

Total SC WWTF Supply	SC WWTF In-Plant Demand	SqCWD GWRR Demand	Secondary Effluent Available	Purified Water Produced
Average Daily Dry Weather Flow <sup>1</sup> (mgd)	Year-Round Internal Use + La Barranca Park <sup>2</sup> (mgd)	Year-Round Secondary Effluent (mgd)	after meeting other Demands (mgd)	Based on assumed AWWP Recovery Rate <sup>3</sup>
6.1	0.25	1.7	4.16	3.2

<sup>1</sup> Based on June 2015 flow data

<sup>2</sup> Assumes no additional NPR demands in Santa Cruz will be served

<sup>3</sup> Assumes MF/UF recover rate of 90% and RO recovery rate of 85%

Brine

Kennedy/Jenks Consultants

## Local Raw WW Supply for GRRP Alternatives

### D.A. Porath Pump Station


- Operated by the Santa Cruz County Sanitation District
- Main raw wastewater PS along the sewer transmission main
- Average Flow = 3.6 mgd (2014)
- Diurnal and seasonal flow patterns would need to be further evaluated
- Assumed Recovery rates
  - MBR (90% recovery)
  - RO/UV-AOP (85% recovery)
- Assuming no bypass and ability to treat average annual flow
- Max production of purified water would be 2.75 mgd



Source: SqCWD GW Replenishment Feasibility Study, 2015

Kennedy/Jenks Consultants

## Recycled Water Market: Indirect Potable Reuse



GRR = Groundwater Replenishment Reuse

Today's Focus



- Exploring GRR in two basins
  - Santa Cruz Mid County Basin
  - Santa Margarita



Legend  
 Santa Cruz Mid County Basin  
 Santa Margarita Basin

Kennedy/Jenks Consultants





## GRR Treatment Requirements Direct Injection



- IPR regulations were finalized June 18, 2014
  - Reduction Credits = 12/10/10 microorganism removal,
  - Response Time =  $\geq$  2 months
  - Recycled Water Contribution ~ 100%
- Treatment
  - Credits from raw sewage to finished water
  - Min 2 separate treatment processes (max 6 LRV each)
  - Requires Full Advanced Treatment (RO + AOP)
  - 1-log virus reduction credit per month of subsurface retention


Kennedy/Jenks Consultants

## GRR Treatment Requirements Direct Injection

- Other Requirements
  - Total N  $\leq$  10 mg-N/L; TOC  $\leq$  0.5/RWC
  - Nitrogen = GW Quality Objectives, Basin Plan
- Compliance with regulated compounds
  - NDMA ~ 10 ng/L California notification limit
  - Other Chemicals of Emerging Concern (CECs) with regulatory notification limits
  - Title 22 drinking water primary and secondary MCL's
  - Disinfection Byproducts – i.e. HAAs, THMs, chlorite
- Challenges: costs, brine disposal, siting
- Benefits: no diluent water required, less space

Kennedy/Jenks Consultants





### Beltz Wellfield Injection Capacity and Siting Study

- Perform a conceptual-level analysis of injection well capacity and siting for a GRRP at the Beltz Wellfield
  - Utilizing production and specific capacity data from Beltz Wells #8, #9, #10 and #12
  - Identify potential sites using prior siting studies
  - Estimate injection rate and travel time to extraction
  - Meet minimum of 6-month travel time


Kennedy/Jenks Consultants

## Beltz Wellfield Injection Capacity and Siting Study

- Approach
  - Injection rate is assumed to be 50% to 70% of extraction rate from existing wells
  - Utilized Darcy's Law
  - Utilized Simple MODFLOW/MODPATH Model
  - Proposed Injection Well Locations Based on Previous Siting Studies and Communication with City Staff

Kennedy/Jenks Consultants

## Beltz Wellfield Existing Production Wells




ROI – Radius of Influence – 1000'

- Est. time a particle/drop of water 1,000' away would take 5 years to reach the production well)
- ROI is not symmetrical as approach accounts for regional groundwater gradient and groundwater pumping

← Flow direction path = how a drop of water moves in the subsurface


- Approx. **EXISTING** Production Well Location(s)



Kennedy/Jenks Consultants

## Injection Sites near Beltz Wells #8, #9 and #10


- RESULTS:**
- This shows how the extraction well capture zones change upon 0.5 mgd injection at each location
  - The extraction well capture zone represents 5 years
  - The injection well travel time shape represents 6 months
  - Based on initial results, J would be less desirable due to travel time at or near 6 months



Kennedy/Jenks Consultants

## Injection Sites near Beltz Well #12

- RESULTS:**
- This shows how the extraction well capture zones change upon 0.5 mgd injection at each location
  - The extraction well capture zone represents 5 years
  - The injection well travel time shape represents 6 months



Kennedy/Jenks Consultants

## Beltz Wellfield Injection Capacity and Siting Study

- Recycled Injection Potential = 2 MGD
  - Beltz Well No's 8, 9 and 10 Sites
    - ✓ Injection Rate = Approx. 0.5 MGD per well location
    - ✓ Two Wells= 1.0 MGD
      - *Potential to do three wells if another viable site is identified.*
      - *Additional production wells may also need to be considered*
  - Beltz Well No. 12 Site
    - ✓ Injection Rate = Approx. 0.5 MGD per well
    - ✓ Two Wells = 1.0 MGD

Kennedy/Jenks Consultants

## Recycled Water Market: Potable Reuse

Potable Reuse	Available Supply mgd (AFY)	Demand mgd (AFY)	Use Limited by
Groundwater Recharge – Beltz Wellfield	<u>SC WWTF Effluent</u> 3.2 mgd (3,600 AFY)	2.0 (2,200 AFY)	<ul style="list-style-type: none"> <li>• Groundwater basin capacity</li> <li>• Injection well siting</li> <li>• Travel time from injection to extraction</li> </ul>
Groundwater Recharge – Beltz Wellfield	<u>Local Raw WW</u> 2.75 mgd (3,080 AFY)	2.0 (2,200 AFY)	<ul style="list-style-type: none"> <li>• Groundwater basin capacity</li> <li>• Injection well siting</li> <li>• Travel time from injection to extraction</li> </ul>
Groundwater Recharge – Santa Margarita Basin	<u>SC WWTF Effluent</u> 3.2 mgd (3,600 AFY)	TBD*	<ul style="list-style-type: none"> <li>• Regional wastewater generation</li> <li>• Groundwater basin capacity</li> <li>• Travel time from injection to extraction</li> </ul>
Surface Water Augmentation	<u>SC WWTF Effluent</u> 3.2 mgd (3,600 AFY)	3.2 mgd (3,600 AFY)	<ul style="list-style-type: none"> <li>• Summer wastewater generation</li> <li>• SWA Regulations</li> <li>• Operation of Loch Lomond Reservoir</li> </ul>
Streamflow Augmentation	<u>SC WWTF Effluent</u> 3.2 mgd (3,600 AFY)	3.2 mgd (3,600 AFY)	<ul style="list-style-type: none"> <li>• Summer wastewater generation</li> <li>• TMDL for Nitrate</li> <li>• Basin Plan requirements for Temperature and Dissolved Oxygen</li> </ul>
Direct Potable Reuse	<u>SC WWTF Effluent</u> 3.2 mgd (3,600 AFY)	3.2 mgd (3,600 AFY)	<ul style="list-style-type: none"> <li>• Summer wastewater generation</li> <li>• GHWTP Treatment Capacity</li> <li>• Coast Pump Station Capacity</li> <li>• Pending DPR Regulations</li> </ul>

Kennedy/Jenks Consultants

## Alternatives for Further Evaluation

- Alternative 1 – Centralized Non-Potable Reuse
- Alternative 2 – Decentralized Non-Potable Reuse
- Alternative 3 – Santa Cruz Participation in SqCWD-led GRR Project
- Alternative 4 – Santa Cruz GRR Project
- Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir
- Alternative 6 – Streamflow Augmentation (SFA)
- Alternative 7 – Direct Potable Reuse (DPR)

Kennedy/Jenks Consultants

## Preliminary capital & annualized costs

- Capital Costs
  - Treatment
  - Pipelines
  - Pump Stations
  - Injection & Monitoring Wells
  - Site Retrofit
- Annualized capital & O&M costs for alternative comparison
- Further inputs to confirm the following after webinar
  - Phasing of capital costs
  - Pipeline special crossing costs
  - Energy and labor costs
  - Interest and contingencies

Kennedy/Jenks Consultants



## Alt 3 - Santa Cruz Participation in a SqCWD-led GRR

- **AWPF @ SqCWD Headquarters (3 Sub-alternatives)**
  - Alt 3a - Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin
    - ✓ \*Baseline – no use in Santa Cruz
  - Alt 3b - Send tertiary effluent from SCWWTF to SqCWD
    - ✓ Serve tertiary RW to NPR users along the way
  - Alt 3c - Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF
    - ✓ Recharge advanced treated RW in Santa Cruz GW basin
    - ✓ Serve advanced treated RW to NPR users along the way to SC GW basin
- **AWPF @ Santa Cruz WWTF (2 Sub-alternatives)**
  - Alt 3d - Send advanced treated RW from SCWWTF to SqCWD
    - ✓ Serve advanced treated RW to NPR users along the way
  - Alt 3e - Send advanced treated RW from SCWWTF to SqCWD
    - ✓ Serve advanced treated RW to NPR users along the way
    - ✓ Recharge advanced treated RW in Santa Cruz GW Basin

Kennedy/Jenks Consultants


## Alt 3 - Santa Cruz Participation in a SqCWD-led GRR

Alt	Delivery to SqCWD	Use in Santa Cruz	Major Facilities in Santa Cruz
AWTF @ SqCWD Headquarters	3a 1.7 mgd secondary	None	Pump Station (PS) at SCWWTF, pipeline to SqCWD, brine line to SCWWTF
	3b 1.7 mgd tertiary	0.12 mgd NPR (~30 sites)	Tertiary Treatment and PS at SCWWTF, pipeline to SqCWD, brine line to SCWWTF, distribution pipelines to customer sites
	3c 4.3 mgd secondary	~2.0 mgd for GRR + 0.01 mgd NPR	PS at SCWWTF, pipeline to SqCWD, brine line to SCWWTF, pipeline from SqCWD to GW injection sites, GW injection wells
AWTF @ SCWWTF	3d 1.3 mgd purified	0.12 mgd NPR	AWTF and PS at SCWWTF, pipeline to SqCWD, distribution pipelines to customer sites
	3e 1.3 mgd purified *	0.15 mgd NPR + 2.0 mgd for GRR	AWTF and PS at SCWWTF, pipeline to SqCWD, distribution pipelines to customer sites and GW injection sites, GW injection wells


\* Pipeline to injection wells in Santa Cruz is sized to convey 3.3 mgd.

*Additional hydraulic evaluation to be conducted as part of future alignment study to determine if booster pumps would be needed along transmission main.*

## Alt 3 - Santa Cruz Participation in a SqCWD-led GRR (Overview)



## Alternative 3a: Secondary Effluent to SqCWD + NO NPR along the way (BASELINE)



## Alternative 3a: Secondary Effluent to SqCWD + NO NPR and NO GRR in the City along the way (BASELINE)

	Facilities
NPR Demand	0
SqCWD Demand	1.7 MGD Effluent (Constant Demand)
City GRR Demand	0
Treatment Capacity	No additional treatment required
Pipelines	8.4 miles – 14"
Pump Stations	WWTP PS – 2 nos: 670 gpm, 75 HP <i>(booster pump station if needed)</i>
Storage	None
Customer Sites	0


No NPR demand and No SC GRR along the way.  
All 1.7 mgd secondary delivered is going to SqCWD

No peak factor was used to size pipeline and pump station since it is a constant demand.

Kennedy/Jenks Consultants

## Alternative 3c: Secondary Effluent to SqCWD AWWP + Purified Water for NPR + GRR in the City

**4.44 MGD** Secondary effluent to SqCWD  
(includes 1.7 mgd for Pure Water Soquel)  
**2.00 MGD** GRR in the City (at Beltz)  
**0.01 MGD** of NPR demand in City  
**2.01 MGD** of reuse in the City



\*Current sizing does not include SqCWD NPR use in SqCWD

*AWT pipeline would NOT be in the same trench as the secondary pipeline due to separation requirements. Shown in same alignment to reduce community disruption if installed at same time. Future alignment study to evaluation further.*

### Alternative 3c: Secondary Effluent to SqCWD AWPF + Purified Water for NPR + GRR in the City

	Facilities
NPR Demand	0.01 MGD
SqCWD Demand	1.7 MGD Effluent
City GRR Demand	2.0 MGD AWT Product Water
AWPF Treatment Capacity	3.3 MGD
Pipelines	8.4 miles – 20" (transmission – 6" larger than baseline Alt 3A) 4.35 miles – 10" and 8" (to injection wells)
Pump Stations	WWTP PS – 2,720 gpm, 140 HP <i>(booster pump station if needed)</i>
Wells	5 injection wells (+ 1 backup); 5 monitoring wells
Customer Sites	11

Treatment capacity at SqCWD based on constant flow of 3.3 mgd (1.3 mgd SqCWD GRR and 2 mgd SC GRR) and summer peak month flow factor of 1.87 applied to NPR demands (0.01 mgd).  
For pipeline capacity, peak hour factor (assuming 8 hours of irrigation) only applied to NPR demand

Kennedy/Jenks Consultants


### Alternative 3e: AWPf @ SC WWTF, use purified water for NPR + GRR in the City + SqCWD GRR

1.30 MGD purified water to SqCWD

2.00 MGD GRR in the City (at Beltz)

0.15 MGD of NPR demand in City

2.15 MGD of reuse in the City



\*Current sizing does not include SqCWD NPR use

Kennedy/Jenks Consultants

### Alternative 3e: AWPf @ SC WWTF, use purified water for NPR + GRR in the City + SqCWD GRR

	Facilities
NPR Demand	0.15 MGD
SqCWD Demand	1.3 MGD AWT Product Water
City GRR Demand	2.0 MGD AWT Product Water
Treatment Capacity	3.45 MGD
Pipelines	8.4 miles – 16” (transmission – 2” larger than baseline Alt 3A) 3.1 miles – 6” and 8 “(to injection wells)
Pump Stations	WWTP PS – 2,720 gpm, 140 HP <i>(booster pump station if needed)</i>
Wells	5 injection wells (+ 1 backup); 5 monitoring wells
Customer Sites	41

Treatment capacity at SqCWD based on constant flow of 3.3 mgd (1.3 mgd SqCWD GRR and 2 mgd SC GRR) and summer peak month flow factor of 1.87 applied to NPR demands (0.15 mgd).

For pipeline capacity, peak hour factor (assuming 8 hours of irrigation) only applied to NPR demand

Kennedy/Jenks Consultants

### Alternative 3a, 3b, 3c, 3d and 3e


Facility Capital Costs					
1.0	Treatment				1,729,866
1.1	Microfiltration	1.7	MGD	2,250,000	3,805,096
1.2	Reverse Osmosis	1.4	MGD	3,308,000	4,755,187
1.3	UV/AOP	1.4	MGD	125,000	179,685
1.4	Free Chlorine	1.4	MGD	575,000	826,551
1.5	Post Treatment and Chemical Handling	1.4	MGD	923,000	1,326,795
1.6	Building	1.4	MGD	1,250,000	1,796,851
1.7	Remove SqCWD portion of treatment	1.30	MGD	8,431,000	(10,960,300)
2.0	Pipelines				1,179,947
2.1	Purified Water Pipeline from SCWWTP to SqCWD, serving NPR along the way				
	Alt3D_A	3,177	LF	72.00	228,769
	Alt3D_B	1,529	LF	72.00	110,099
	Alt3D_C	1,697	LF	72.00	122,182
	Alt3D_D	2,047	LF	72.00	147,359
	Alt3D_Main	44,106	LF	210.00	9,262,260
	Alt3D_A	3,222	LF	72	231,989
	Alt3D_B	1,529	LF	72	110,099
	Alt3D_C	1,697	LF	72	122,182
	Pipeline Constructability (Along Roads)			10%	1,033,494
	Microtunneling (Trenchless)	800	LF	700.00	560,000
2.2	Remove Baseline Pipeline Cost for Alt3A	1	LS	(10,748,486)	(10,748,486)
3.0	Pump Stations				430,000
3.1	From WWTP to SqCWD, serving NPR along the way		LS		1,740,000
3.2	Remove Baseline Pump Station Cost for Alt3A	1	LS	(1,310,000)	(1,310,000)

Alt 3A baseline costs removed from cost of Alts 3B, 3C, 3D and 3E

- ✓ Treatment
- ✓ Pipelines
- ✓ Pump Station

*Alternative approach to distribute pipeline and PS costs by flow (rather than taking out baseline cost from 3A) will also be looked at.*

Kennedy/Jenks Consultants



- ## Alt 4 - Santa Cruz GWRR
- **AWPF @ Santa Cruz WWTF**
    - Alt 4a - Send advanced treated RW from SCWWTF to SC GRR
      - ✓ Serve advanced treated RW to NPR users along the way to injection wells (more customers compared to Alt 4b)
      - ✓ Recharge advanced treated RW in Santa Cruz GW Basin
  
  - **MBR + AWWPF @ DA Porath**
    - Alt 4b - Send advanced treated RW from DA Porath (MBR + AWWPF) to SC GRR
      - ✓ Serve advanced treated RW to NPR users along the way to injection wells
      - ✓ Recharge advanced treated RW in Santa Cruz GW Basin
- Kennedy/Jenks Consultants


## Alt 4 - Santa Cruz Led GRRP

	Alt	Delivery to SqCWD	Use in Santa Cruz	Major Facilities in Santa Cruz
AWTF @ SCWWTF	4a	1.7 mgd secondary	0.13 mgd NPR + 2.0 mgd for GRR	AWPF and PS at SCWWTF, distribution pipelines to customer sites and GW injection sites, GW injection wells
MBR + AWTF @ DA Porath	4b	1.7 mgd secondary	0.01 mgd NPR + 2.0 mgd for GRR	MBR and AWPF at DA Porath, PS at SCWWTF, DA Porath, pump station, short brine line, distribution pipelines to customer sites and GW injection sites, GW injection wells

\*Facilities and cost of conveying secondary effluent to SqCWD not included as part of Alt 4

Kennedy/Jenks Consultants


## Alt 4 - Santa Cruz Led GRRP



### Other Considerations

- Maximizes beneficial reuse of wastewater in summer
- Maintaining GW levels
- Siting issues for MBR
- Operational complexity and energy for treatment
- Public acceptance uncertain
- Additional studies needed to confirm assumptions

Kennedy/Jenks Consultants




### Alternative 4a: Send advanced treated RW from SCWWTF to GRR in the City

	Facilities
NPR Demand	0.13 MGD
SqCWD Demand	Facilities and cost of conveying secondary effluent to SqCWD not included as part of Alt 4
City GRR Demand	2.0 MGD AWT Product Water
Treatment Capacity	2.25 MGD
Pipelines	5.1 miles – 12" (transmission) 3.6 miles – 6" and 10" (distribution to injection wells)
Pump Stations	WWTP PS – 2 nos: 670 gpm, 75 HP <i>(booster pump station if needed)</i>
Wells	5 injection wells (+ 1 backup); 5 monitoring wells
Customer Sites	37

Treatment capacity at SqCWD based on constant flow of 3.3 mgd (1.3 mgd SqCWD GRR and 2 mgd SC GRR) and summer peak month flow factor of 1.87 applied to NPR demands (0.15 mgd).  
 For pipeline capacity, peak hour factor (assuming 8 hours of irrigation) only applied to NPR demand

Kennedy/Jenks Consultants








### Alternative 4b: Send advanced treated RW from DA Porath (MBR + AWPf) to GRR in the City

	Facilities
NPR Demand	0.01 MGD
SqCWD Demand	Facilities and cost of conveying secondary effluent to SqCWD not included as part of Alt 4
City GRR Demand	2.0 MGD AWT Product Water
Treatment Capacity	2.02 MGD
Pipelines	2.7 miles – 6” and 8” (distribution to injection wells), <b>short brine line for disposal back to sewer</b>
Pump Stations	DA Porath Pump Station – 1,400 gpm, 190 HP
Wells	5 injection wells (+ 1 backup); 5 monitoring wells
Customer Sites	11

Treatment capacity at SqCWD based on constant flow of 3.3 mgd (1.3 mgd SqCWD GRR and 2 mgd SC GRR) and summer peak month flow factor of 1.87 applied to NPR demands (0.15 mgd).  
 For pipeline capacity, peak hour factor (assuming 8 hours of irrigation) only applied to NPR demand

**Kennedy/Jenks Consultants**







### NPR Alternatives Evaluation Summary of QUANTITATIVE Results

Alternative	Sub Alt	Description	Treatment Level	Recycled Water Delivered				Estimated Costs			Energy / Others						
				Regional Ave Annual Reuse (AFY)	Regional Average Annual Flow (MGD)	RW Use in Santa Cruz (AFY)	RW Use in Santa Cruz (MGD)	Peak Season Deliveries (AF in Summer - June)	Peak Hourly Flow (MGD)	Estimated Construction Cost (\$mil)	Annual O&M Cost (\$mil/yr)	Total Annual Cost (\$/AF)	Unit Energy of RW Delivered (KWH/AF)	GHG Emissions (MTCO2/yr)	Social Cost of Carbon (\$)	Footprint (SF)	Number and Size of Facilities
Non Potable Reuse	Alt 1A	Centralized Non-Potable Reuse - Santa Cruz PWD Phase 2 Project	3"	282	0.25	282	0.25	44	1.41	\$2	\$0.1	\$627	TBD	TBD	TBD	TBD	TBD
	Alt 1B	Centralized Non-Potable Reuse - Maximize tertiary treatment at the SC WWTF	3"	807	0.72	807	0.72	126	4.04				TBD	TBD	TBD	TBD	TBD
		Phase 1		340	0.30	340	0.30	44	1.40	\$20	\$1.2	\$40,124	TBD	TBD	TBD	TBD	TBD
		Phase 2		176	0.16	176	0.16	51	1.65	\$6	\$0.2	\$2,819	TBD	TBD	TBD	TBD	TBD
SqCWD Led GWRR	Alt 3A	Secondary Effluent to SqCWD + NPR along the way	2" + filter	1,903	1.70	0.00	0.00	297	3.16	\$20	\$0.8	\$10,001	TBD	TBD	TBD	TBD	TBD
	Alt 3B	Tertiary Effluent to SqCWD + NPR along the way	3"	2,448	2.19	545	0.49	417	4.47	\$26	\$0.8	\$4,188	TBD	TBD	TBD	TBD	TBD
SC GWRR	Alt 4A	Santa Cruz GWRR Project - Advanced treatment at SCWWTF + NPR along the way	AWT	3,704	3.31	2,248	2.01	577	6.18	\$73	\$2.5	\$2,993	TBD	TBD	TBD	TBD	TBD
	Alt 4B	Santa Cruz GWRR Project - MBR + MBR at DA Porah + NPR along the way	AWT	1,538	1.37	82	0.07	295	9.48	\$8	\$0.4	\$10,049	TBD	TBD	TBD	TBD	TBD
	Alt 4C	AWT @ SC WWTF sent to SqCWD + NPR along the way	AWT	3,765	3.35	2,299	2.05	585	6	\$2	\$2	\$2,641	TBD	TBD	TBD	TBD	TBD
SWA	Alt 5	Surface Water Augmentation (SWA) - Loch Lomond Reservoir	AWT	1,777	3.20	1,777	3.20	508.51	96	\$111	\$5	\$6,239	TBD	TBD	TBD	TBD	TBD
Stream Aug	Alt 6	Streamflow Augmentation	AWT	1,777	3.20	1,777	3.20	508.51	96	\$78	\$3	\$4,076	TBD	TBD	TBD	TBD	TBD
DPR	Alt 7	Direct Potable Reuse	AWT	3,584	3.20	3,584	3.20	508.51	96	\$108	\$3	\$2,637	TBD	TBD	TBD	TBD	TBD
Regional GRR	Alt 8a	With SqCWD	AWT	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD
	Alt 8b	Without SqCWD	AWT	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD

Kennedy/Jenks Consultants



## QUESTIONS

Kennedy/Jenks:

Dawn Taffler  
Melanie Tan  
Eddy Teasdale

[DawnTaffler@KennedyJenks.com](mailto:DawnTaffler@KennedyJenks.com)  
[MelanieTan@KennedyJenks.com](mailto:MelanieTan@KennedyJenks.com)  
[EddyTeasdale@KennedyJenks.com](mailto:EddyTeasdale@KennedyJenks.com)

Kennedy/Jenks Consultants



## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Alternatives Webinar – Part 4

27 April 2017 from 9 am to 11:00 am

Conf Call - (855) 813-2486 Code – 2484

Web Meeting - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Webinar Objective:** Present preliminary evaluation for regional groundwater replenishment reuse alternatives in the Santa Margarita Groundwater Basin using preliminary maps, tables and figures to illustrate facility locations, capacities and costs.

**Goal:** Discuss and seek input on assumptions, preliminary model results, facility locations and other project components.

**Action Items:** Respond to specific requests for information, update alternatives (as-needed) and memorialize discussion points to support scoring of alternative projects.

---

1. Approach & Objective
2. Regional Recycled Water Supply
3. Santa Margarita Groundwater Basin (SMGB) Initial Injection Capacity and Siting Study Results
4. GRR Treatment Requirements and Regional Considerations
5. Alternatives Analysis
  - a. Alternative 8a – 4-Way Regional GRR Project (to serve the City, Scotts Valley, Soquel Creek and San Lorenzo Valley)
  - b. Alternative 8b – 3-Way GWRR Project (to serve the City, Scotts Valley, and San Lorenzo Valley)
6. Preliminary Cost Comparison
7. Open Discussion
8. Scoring and Weighting Discussion
9. Next Steps

# City of Santa Cruz Recycled Water Facilities Planning Study

Alternatives Webinar Part 4


April 27, 2017

Kennedy/Jenks Consultants 1

## Agenda

- Approach & Objective
- Regional GRRP Concept
- Regional Recycled Water Supply
- GRR Treatment Requirements and Regional Considerations
- Santa Margarita Groundwater Basin (SMGB)
  - Initial Injection Capacity and Siting Study Results
- Alternative 8a/8b Analysis
- Preliminary Cost Comparison
- Open Discussion
- Scoring and Weighting Discussion

Kennedy/Jenks Consultants 2





### Alternatives Webinar Objective

- **Objective:** Present preliminary evaluation for potable reuse alternatives using preliminary maps, tables and figures to illustrate facility locations, capacities and preliminary costs.
- **Goal:** Obtain input and clarify assumptions
- **Action Items:** Response to specific requests for information, update alternatives, and memorialize discussion points to support scoring of alternative projects.

Kennedy/Jenks Consultants








## Regional GRR Concept

- **Description:** Regional AWTF to produce purified water for groundwater replenishment in the Santa Margarita Groundwater Basin. Utilize existing or new production wells to serve Santa Cruz, SVWD, SLVWD and SqCWD (or in parallel to an independent SqCWD GRRP)
- **Source:** Santa Cruz WWTF + Scotts Valley WRF
- **Project Size:** Groundwater recharge based on injection and extraction capacity
- **Uses:** Groundwater recharge only
- **Major Facilities:** AWTF, conveyance and distribution pipelines, pump stations, injection wells, production wells, brine line

Kennedy/Jenks Consultants


## Regional GRR Project Concept





## SVWD WWTF Supply for a Regional GRRP

- Per the SVWD Facilities Planning Report (K/J 2017)
  - AWPf Treatment design capacity = **1.0 mgd** for peak month
  - Average annual flow of product (purified water) = 0.5 mgd
  - After meeting existing RW demand + Pasatiempo GC secondary effluent needs there is little available supply in the summer
  - Winter supply is greater, thus the AWPf is sized to meet winter flows



Kennedy/Jenks Consultants

## Regional AWPf Capacity GRRP Alternatives

Treatment Design Capacity	Alt 8a Regional (no SqCWD GRRP)	Alt 8b Regional (independent SqCWD GRRP)	Assumptions
From Santa Cruz WWTF Secondary Flow	4.5	3.2	Based on available secondary effluent with assumed AWPf Recovery Rate <sup>1</sup>
From Scott Valley WRF Tertiary Flow	<u>1.0</u>	<u>1.0</u>	Based on peak month treatment capacity in winter months when NPR demand is low.
<b>Treatment Production at Regional AWPf</b>	<b>5.5</b>	<b>4.2</b>	This will be the aver annual volume recharged into the groundwater basin (assuming adequate available capacity in the SMGB).


Regional Alternatives: Alt 8a Alt 8b

<sup>1</sup> Assumes MF/UF recover rate of 90% and RO recovery rate of 85%

Kennedy/Jenks Consultants

## GRR Treatment Requirements Direct Injection


- IPR regulations were finalized June 18, 2014
  - Reduction Credits = 12/10/10 microorganism removal,
  - Response Retention Time =  $\geq 2$  months
  - Recycled Water Contribution ~ 100%
- Requires Full Advanced Treatment (RO + AOP)



- Other requirements (Total N, TOC, NDMA, CECs, and other GW water quality objectives from Basin Plan)

Summary of requirements for Alts 3 & 4; presented in Webinar Part 3

## GRRP Treatment Train




Log Removal	MF	RO	UV/AOP	RT	Total
Virus	0	1.5 – 2	6	4 - 6	11.5 – 13.5
<i>Giardia</i>	4	1.5 – 2	6	0	11.5 – 12
<i>Cryptosporidium</i>	4	1.5 – 2	6	0	11.5 – 12

Summary of Treatment Train for Alts 3 & 4; presented in Webinar Part 3

## Regional Treatment Considerations


- Influent to the AWPf is combination of secondary (City) and tertiary (SVWD)



## Regional Treatment Considerations


- Tertiary effluent comprising 12-16% of Inflow
  - No change to treatment processes
  - Potential for reduced fouling of membranes
    - ✓ lower energy requirements
    - ✓ reduced membrane replacement
- Increased AWPf production capacity
  - Benefit from economy of scale to bring capital cost down
    - ✓ Reduced duplication of facilities
    - ✓ Regional distribution of site development costs
    - ✓ Reduced building costs, also distributed regionally (i.e. admin, controls, etc)

### Groundwater Basins



Kennedy/Jenks Consultants

### Recharge the Lompico Aquifer of the Santa Margarita GW Basin



Kennedy/Jenks Consultants

## SMGB Injection Capacity and Siting Study Approach

- Perform a conceptual-level analysis of injection well capacity and siting for a GRRP in the SMGB
- Utilize existing MODFLOW Model of SMGB
- Methodology for estimate production and specific capacity
- Identify potential sites for injection and extraction
- Estimate injection rate and travel time to extraction
- Meet minimum of 6-month travel time from injection and extraction wells

Kennedy/Jenks Consultants

## SMGB Well Siting Study

- Proposed Well Locations Based on Preliminary Siting Study from Pueblo



Kennedy/Jenks Consultants



### SMGB Hydrogeology Assumptions

- Injection/Extraction Rates based on preliminary estimates from Pueblo (**Scenario 1**)

Potential NEW Well Sites	Est Injection Flow Rate (GPM)	Est Injection Flow Rate (MGD)	Potential SVWD FPS Well Sites	Est Injection Flow Rate (GPM)	Est Injection Flow Rate (MGD)
SV1	150	0.22	INJ Well #3	120	0.2
SV2	205	0.30	11A	120	0.2
SV3	200	0.29	<u>11B</u>	<u>120</u>	<u>0.2</u>
SV4	430	0.62	<b>Total</b>	<b>360</b>	<b>0.6</b>
SV5	250	0.36			
SV6	190	0.27			
SV7	205	0.30			
SV8	50	0.07			
<u>SV9</u>	<u>207</u>	<u>0.30</u>			
<b>Total</b>	<b>1,887</b>	<b>2.72</b>			

Based on SMGB Prior Model Runs for SVWD FPS for 1.0 mgd purified water production capacity

Insufficient to meet remaining purified water production of 4.5 mgd or 3.2 mgd

### SMGB Hydrogeology Assumptions

- Injection/Extraction Rates based on injection rate on percentage of production – 25% (**Scenario 2**)

Potential NEW Well Sites	Est Injection Flow Rate (GPM)	Est Injection Flow Rate (MGD)	Potential SVWD FPS Well Sites	Est Injection Flow Rate (GPM)	Est Injection Flow Rate (MGD)
SV1	328	0.47	INJ Well 3	120	0.2
SV2	422	0.61	11A	120	0.2
SV3	235	0.34	<u>11B</u>	<u>120</u>	<u>0.2</u>
SV4	250	0.36	<b>Total</b>	<b>360</b>	<b>0.6</b>
SV5	390	0.56			
SV6	390	0.57			
SV7	300	0.43			
SV8	438	0.63			
<u>SV9</u>	<u>218</u>	<u>0.32</u>			
<b>Total</b>	<b>11,890</b>	<b>4.28</b>			

Based on SMGB Prior Model Runs for SVWD FPS for 1.0 mgd purified water production capacity

sufficient to meet remaining purified water production of 4.5 mgd or 3.2 mgd

## SMGB Hydrogeology Assumptions

- Injection/Extraction Rates based on injection rate on percentage of production of 25% and added 5 new production wells (**Scenario 3**)

Potential NEW Well Sites	Est Injection Flow Rate (GPM)	Est Injection Flow Rate (MGD)	Potential SVWD FPS Well Sites	Est Extraction Flow Rate (GPM)	Est Injection Flow Rate (MGD)
SV1	328	0.47	5 Wells	594	0.86
SV2	422	0.61	<b>Total</b>	<b>360</b>	<b>4.28</b>
SV3	235	0.34			
SV4	250	0.36			
SV5	390	0.56			
SV6	390	0.57			
SV7	300	0.43			
SV8	438	0.63			
SV9	218	0.32			
<b>Total</b>	<b>11,890</b>	<b>4.28</b>			

New Extraction Rates = Proposed Injection Rates (SV-1 through SV-9)


sufficient to meet remaining purified water production of 4.5 mgd or 3.2 mgd

## SMGB Injection and Production Wells

- ⬡
**ROI – Radius of Influence**
  - Est. time a particle/drop of water would take 6 months to travel from **Injection Well**
- ⬡
**ROI – Radius of Influence**
  - Est. time a particle/drop of water would take 6 months to travel from **Existing Production Well**
- ⬡
**ROI – Radius of Influence**
  - Est. time a particle/drop of water would take 6 months to travel from **Proposed Production Well**

Kennedy/Jenks Consultants

## Preliminary "Scenario 1" Results for ALL Sites Considered




**RESULTS:**

- The injection well travel time shape represents 6 months

Kennedy/Jenks Consultants


## Preliminary "Scenario 1" Results for ALL Sites Considered



**RESULTS:**

- The injection well travel time shape represents 6 months

## Preliminary "Scenario 2" Results for ALL Sites Considered




**RESULTS:**

- The injection well travel time shape represents 6 months


Kennedy/Jenks Consultants

## Preliminary "Scenario 2" Results for ALL Sites Considered



**RESULTS:**

- The injection well travel time shape represents 6 months



## SMGB Injection Capacity and Siting Study

- SVWD FPS – Repurpose Existing Wells for Injection
  - 11A/B + Inj Well #3 (Recommended Project)
  - 3 Wells = 0.6 mgd
- New Injection Wells to Serve City + SqCWD
  - SV1 – SV9 (Siting Study Identified by Pueblo)
  - Scenario 1 Injection Rate = Approx. 0.3 mgd per well location
    - ✓ 9 Wells = 2.72 mgd
    - ✓ 2 to 6 additional sites needed to utilize Alt 8a and 8b Purified Water Supply
  - Scenario 2 Injection Rate = Approx. 0.5 mgd per well location
    - ✓ 9 Wells = 4.28 mgd
  - Scenario 3 Injection Rate
    - ✓ 9 Injection Wells = 4.28 mgd (0.48 mgd/well)
    - ✓ 5 Extraction Wells = 4.28 mgd (0.86 mgd/well)

Kennedy/Jenks Consultants

## SMGB

### Production Capacity and Siting Study

- SVWD FPS
  - Utilize existing production wells to capture replenished purified water
- Existing Production Wells
  - Next model run simulate interaction btw injection and extraction
- New Production Wells to Serve City (+ SqCWD)
  - Extraction Rate = Approx. 0.86 mgd per well location
  - Alt 8a (4.5 mgd supply) = Need 5 NEW well sites
  - Alt 8b (3.2 mgd supply) = Need 4 NEW well sites


Kennedy/Jenks Consultants

## El Pueblo Treatment Site

Facilities shown are for a 1 mgd AWPF

SVWD Facilities Planning Report (KJ 2017)

Kennedy/Jenks Consultants




### Alternative 8a: 4-Way Regional GRR Project (to serve the City, Scotts Valley, Soquel Creek and San Lorenzo Valley)

	Facilities
NPR Demand	0 MGD
City Demand	3.2 MGD AWT Product Water
SqCWD Demand	1.3 MGD AWT Product Water
SVWD Demand	1.0 MGD AWT Product Water Capacity (0.5 mgd ave annual)
Treatment Capacity	5.5 MGD
Pipelines	8.7 miles – 16” (secondary to El Pueblo) 6.7 miles – 16” (purified to injection and from extraction) 4.5 miles – 8” (brine to SVWD outfall at Pasatiempo)
Pump Stations	WWTP PS – 4,100 gpm, 2,300 HP GW PS from Production Wells to Newell Crk – 3,200 gpm, 800HP
New Wells	9 injection (+ 2 backup); 11 monitoring; 5 production
Customer Sites	0

For pipeline capacity, no peak hour factor applied.

Kennedy/Jenks Consultants



### Alternative 8b: 3-Way Regional GRR Project (to serve the City, Scotts Valley and San Lorenzo Valley)

	Facilities
NPR Demand	0 MGD
City Demand	3.2 MGD AWT Product Water
SqCWD Demand	0 MGD AWT Product Water
SVWD Demand	1.0 MGD AWT Product Water Capacity (0.5 mgd ave annual)
Treatment Capacity	4.2 MGD
Pipelines	8.7 miles – 18” (secondary to El Pueblo) 6.7 miles – 14” (purified to injection and from extraction) 4.5 miles – 6” (brine to SVWD outfall at Pasatiempo)
Pump Stations	WWTP PS – 2,900 gpm, 710 HP GW PS from Production Wells to Newell Crk – 2,300 gpm, 260HP No Brine PS at El Pueblo AWP needed
New Wells	7 injection (+ 2 backup); 9 monitoring; 4 production
Customer Sites	0

For pipeline capacity, no peak hour factor applied.

Kennedy/Jenks Consultants



## Alternative 8a and 8b

Item No.	Description	Qty	Units	Total Costs	
				\$/Unit	Total Capital Cost
<b>Facility Capital Costs</b>					
1.0	Treatment				20,974,852
1.1	Micofiltration	8.5	MGD	1,575,000	10,191,176
1.2	Reverse Osmosis	5.5	MGD	2,315,600	12,735,800
1.3	UV/ACP	5.5	MGD	87,500	481,750
1.4	Free Chlorine	5.5	MGD	403,500	2,213,750
1.5	Pack Treatment and Chemical Handling	5.5	MGD	846,100	3,353,550
1.6	Building	5.5	MGD	2,250,000	6,875,000
1.7	Remove SqCWD's portion of treatment	1.80	MGD	(5,954,841)	(8,521,034)
1.8	Remove SVWD's portion of treatment	1.00	MGD	(11,054,641)	(16,354,542)

Proportional Cost Sharing

- ✓ Treatment
- ✓ Pipelines
- ✓ Pump Station
- ✓ Wells

Project Partner	FPR AWPf Alternative Costs (\$mil)	Santa Cruz FPR AWPf Unit Cost (\$mil)	Santa Cruz FPR AWPf Flow Based Cost (\$mil)	Based on AWPf Capacity (mgd)
SqCWD	\$6.9 - \$8.8	\$9.3	\$8.5	1.3 mgd
SVWD	\$6.9 - \$7.6	\$7.2	\$6.6	1.0 mgd

Kennedy/Jenks Consultants

## Alternative 8a and 8b


Item No.	Description	Qty	Units	Total Costs	
				\$/Unit	Total Capital Cost
<b>2.0 Pipelines</b>					
2.1	Secondary Effluent Pipeline from SC WWTP to El Pueblo AWPf	46,792	LF	270	12,365,640
	Pipeline Constructability (Along Roads)			10%	1,236,384
	Microtunneling (Trenchless)	0	LF	700	0
	Major Intersections	0	LF	713	0
2.2	Purified Water Pipeline from El Pueblo AWPf to Regional GW Injection Wells	10,100	LF	240	2,424,000
	Pipeline Constructability (Along Roads)			10%	242,400
	Microtunneling (Trenchless)	0	LF	700	0
2.3	Extracted GW Pipeline from Regional GW Injection Wells to Existing Newell Creek Pipeline	23,533	LF	240	5,127,920
	Pipeline Constructability (Along Roads)			10%	612,792
	Microtunneling (Trenchless)	0	LF	700	0
	Major Intersections	0	LF	634	0
2.4	Brine pipeline from El Pueblo AWPf to SVWD outfall pipeline, at Pasatiempo Golfcourse	23,664	LF	112	2,652,608
	Pipeline Constructability (Along Roads)			10%	265,261
	Microtunneling (Trenchless)	0	LF	700	0
	Major Intersections	0	LF	317	0
2.5	Remove SqCWD's share of pipeline costs: Secondary + Purified + Extracted GW Drinking Water Pipeline	1.30	MGD	(5,112,741)	(6,446,364)
	Brine Pipeline	1.30	MGD	(530,523)	(869,678)
2.6	Remove SVWD's share of pipeline costs: Brine Pipeline	1.00	MGD	(200,322)	(300,322)

Proportional Cost Sharing



- ✓ Treatment
- ✓ Pipelines
- ✓ Pump Station
- ✓ Wells

Remove Flow Based Proportional Costs

Kennedy/Jenks Consultants



- ## Alt 8 – Regional GRR Project
- Other Considerations**
- Maximizes beneficial reuse of wastewater in the Region
  - Operational complexity for treatment
  - Significant energy for treatment and conveyance
  - Level of cooperation and coordination required between multiple agencies
  - Interagency infrastructure challenges (ownership, operations, construction, etc)
  - Potential for cost-sharing and pursuing funding as a Region
  - Water rights and transfer agreements
  - Future studies needed
- Kennedy/Jenks Consultants




# NPR Alternatives Evaluation Summary of QUANTITATIVE Results

Alternative	Sub Alt	Description	Treatment Level	Recycled Water Delivered					Estimated Costs			Energy / Others								
				Regional Ave Annual Reuse (AFY)	Regional Average Annual Flow (MGD)	RW Use in Santa Cruz (AFY)	RW Use in Santa Cruz (MGD)	Peak Season Deliveries (AF Deliveries/Year)	Peak Hours/Week (MGD)	Estimated Construction Cost (\$mil)	Annual O&M Cost (\$/AF/yr)	Total Annual Cost (\$/AF)	Unit Energy of RW Delivered (kWh/AF)	Est GHG Emissions (MTCO2/yr)	Total Pipeline Length (ft)	Pipeline GHG Emissions (MTCO2)	# of Non-Pipeline Facility Sites (#)	Est New Pipeline Footprint (SQ)		
Non Potable Reuse	Alt 1A	Santa Cruz FWD Phase 2 Project	3'	252	0.25	252	0.25	44	1.4	\$2	\$0.1	\$0.27	733	39	2,423	5	0.93	2	2,150	
	Alternative 1 - Centralized Non-Potable Reuse	Maintain tertiary treatment at the SC WWTP	3'	807	0.72	807	0.72	136	4.0	\$47	\$2.1	\$48,124	12,104	1,887	89,485	17	34	4	4,650	
		Phase 1	3'	340	0.30	340	0.30	44	1.4	\$20	\$1.2	\$40,124	8,239	536	16,113	3	6	1	1,529	
		Phase 2	3'	195	0.18	195	0.18	31	1.2	\$9	\$0.5	\$21,95	56	3	12,954	0	8	0	1,223	
Phase 3	3'	145	0.13	145	0.13	42	1.4	\$15	\$0.8	\$4,210	3,248	104	30,749	6	12	1	1,533			
Phase 4	3'	140	0.13	140	0.13	42	1.4	\$9	\$0.2	\$2,569	63	2	22,680	4	9	1	1,520			
Alternative 2 - Decentralized Non-Potable Reuse	Alt 2	SC Santa Cruz	3'	71	0.06	71	0.06	20	0.2	\$4	\$0.2	\$6,704	1,040	34	10,180	2	4	3	4,920	
SC/WD Use GRPP	Alt 3A	Send secondary effluent from SCWWTP to SC/WD's for injection in SC/WD's tanks (not for reuse NPS users along the way)	2' + 8ft	1,903	1.70	0.00	0.00	287	3.2	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
	Alternative 3 - Santa Cruz Participation in SC/WD's GRPP	Send tertiary effluent from SCWWTP to SC/WD's (reuse NPS users along the way)	3'	2,448	2.19	940	0.49	417	4.8	\$38	\$9.8	\$4,303	1,387	142	52,801	10	20	5	3,828	
		Send additional secondary effluent from SCWWTP to SC/WD's AWWTF (DO NOT serve NPS users along the way) and deliver purified water from SC/WD's AWWTF to exchange Santa Cruz GHWS (reuse NPS users along the way)	AWTF	3,704	3.31	2,348	2.01	577	6.2	\$59	\$2.5	\$2,893	1,091	855	66,921	13	26	17	17,180	
		Send additional treated RW from SCWWTP to SC/WD's (reuse NPS users along the way)	AWTF	1,538	1.37	85	0.07	295	3.5	\$8	\$0.4	\$10,049	2,007	39	99,004	11	23	3	440	
Alt 3B	Send additional treated RW from SCWWTP to SC/WD's (reuse NPS users along the way)	AWTF	3,890	3.45	2,410	2.15	602	6.5	\$65	\$3	\$2,642	2,073	304	62,477	11	23	16	16,000		
City Led GRPP	Alternative 4 - Santa Cruz GRPP	Alt 4A	Santa Cruz GHWS with AWWTF at SC WWTP	AWTF	2,389	2.13	2,389	2.13	372	4.0	\$85	\$2	\$2,905	1,370	625	45,421	9	17	14	14,890
	Alt 4B	Send AWWTF at San Francis PS (reuse NPS users along the way)	AWTF	2,254	2.01	2,254	2.01	301	3.4	\$74	\$2	\$2,637	1,280	543	14,096	3	5	13	13,510	
SWA	Alternative 5 - Surface Water Augmentation (SWA) at Lach Linnard Reservoir	Alt 5	Advanced treatment of Santa Cruz effluent for loading in Lach Linnard Reservoir (not for reuse NPS users along the way)	AWTF	1,777	3.20	1,777	3.20	559	6.0	\$111	\$5	\$6,239	8,365	2,439	67,303	13	26	3	19,300
Stream Aug	Alternative 6 - Streamflow Augmentation	Alt 6	AWTF of secondary effluent with discharge to the San Lorenzo River (not for reuse NPS users along the way)	AWTF	1,777	3.20	1,777	3.20	559	6.0	\$78	\$3	\$4,076	2,682	910	13,482	3	5	3	19,300
		Alt 6A	DO NOT serve NPS users along the way	AWTF	1,777	3.20	1,777	3.20	559	6.0	\$78	\$3	\$4,076	2,682	910	13,482	3	5	3	19,300
DPR	Alternative 7 - Direct Potable Reuse	Alt 7	Raw Water Rebound at Graham Hill WTP from City PS	AWTF	3,584	3.20	3,584	3.20	559	6.0	\$168	\$3	\$2,637	2,121	1,482	3	6	12	6	19,860
Alt 7a		Regional GRPP to serve the City, Santa Valley, Sugar Creek and San Lorenzo Valleys	AWTF	5,600	5.00	3,584	3.20	559	6.0	106	\$	3,873	2,799	1,916	102,109	20	40	31	25,960	
Regional GRP	Alternative 8 - Regional GHWS Project	Alt 8a	Regional GRPP to serve the City, Santa Valley and San Lorenzo Valley	AWTF	4,144	3.70	3,584	3.20	559	6.0	146	\$	3,873	3,384	2,453	105,109	20	40	26	24,500
Alt 8b		Regional GRPP to serve the City, Santa Valley and San Lorenzo Valley	AWTF	4,144	3.70	3,584	3.20	559	6.0	146	\$	3,873	3,384	2,453	105,109	20	40	26	24,500	

The Quantitative Results will be used to inform the Qualitative Metrics for Screening, Scoring and Ranking Alternative Projects

Kennedy/Jenks Consultants

## Quantitative Results and Qualitative Screening Criteria



Kennedy/Jenks Consultants

## Scoring, Weighting & Ranking Approach

- Alternative projects will be **scored** from 1 to 5 for each criteria
  - ✓ Score = 5 Fully Meets Criteria
  - ✓ Score = 4 Mostly Meets Criteria
  - ✓ Score = 3 Partially Meets Criteria
  - ✓ Score = 2 Somewhat Meets Criteria
  - ✓ Score = 1 Unable to Meet Criteria
- Scores will be **weighted** to provide a preliminary ranking of alternative projects
  - ✓ Weighting for Screening Criteria provided by SCWD and SCPWD
  - ✓ SCWD and SCPWD to provide input on initial scoring
  - ✓ Initial scores to be sent out prior to the next workshop
- Sensitivity Analysis will be performed to explore how **ranking** changes with different weightings

Kennedy/Jenks Consultants

Categories	Screening Criteria	Considerations for Assessing Project based on Criteria
ENGINEERING & OPERATIONAL CONSIDERATIONS	Improve Water Supply	- Ability to fill City supply gap (1.2 BGY or 3,700 AFY), supplement peak season supply with a new source or offset and/or contribute to regional supply - Ability to implement Project, with supplies available in a timely manner
	Maximize Beneficial Reuse	- Maximizes reuse of wastewater effluent - Does not limit future options at the WWTF to fully utilize wastewater effluent
	Ease of Implementation	- Regulatory viability and ability to obtain a recycled water permit - Current (DDW and RWQCB) regulatory pathway/approved use - Potential construction challenges (#/size of facilities, ROW, utilities, terrain, disturbed/undisturbed area, seismic/sea level rise vulnerability, etc.) - Flexibility for phasing and opportunities to expand/transition to a higher yield and/or treatment level.
	Operational Complexity	- Source of wastewater and/or type of treatment required for beneficial reuse minimizes impacts to wastewater collections and/or WWTF operations - Siting new treatment facilities minimizes short-term impacts on SC WWTF operations (during construction) and long-term impacts (related to facility relocation, off-site location and/or interference with O&M activities)
ECONOMIC	Cost Effectiveness	- Economically feasible or cost effective project (relative life cycle unit costs)
	Financial Implementability	- Financially implementable project (capital investment does not limit ability to implement other water projects and program)
ENVIRONMENTAL	CEQA Considerations	- Potential environmental impacts and mitigation requirements
	Environmental Enhancement	- Enhance local and regional ecosystems and environments including rivers, groundwater basins - Social cost of carbon compared to other projects and supplies; Relative contribution to climate change (based on GHG emissions)
SOCIAL	Agency Coordination, Partnerships and Agreements	- Level of cooperation and coordination required between multiple outside agencies/users - Willingness and interest of anticipated users/partners for cost-sharing
	Social Issues & Siting	- Perceived public acceptance and comfort with level of public health and safety associated with reuse - Level of impact on local residents for new construction and ongoing maintenance - Land acquisition requirements (property not currently owned by the City)

## Input on Approach for Scoring

- Solicit SqCWD experience with criteria being scrutinized
- Discuss public perception of scoring by project team
- How to address **Social Issues & Siting** category
  - Perceived public acceptance and comfort with level of public health and safety associated with reuse
  - Level of impact on local residents for new construction and ongoing maintenance
  - Land acquisition requirements (property not currently owned by the City)


Kennedy/Jenks Consultants

## Sensitivity Analysis

- Use of sensitivity analysis to address variation in different perceptive by artificially increasing weighting for certain categories
- Discuss Weighting Scenarios such as ...
  - ✓ Maximize Water Supply & Beneficial Reuse
  - ✓ Minimize Costs
  - ✓ Minimize Implementation Challenges & Minimize Operational Complexity
  - ✓ Maximize Environmental Benefits and Minimize Environmental Impacts
  - ✓ Strive for a Regional Solution

RANKING for Sensitivity Analysis			
Project Partner Weighting	Maximize Water Supply & Beneficial Use	Minimize Implementation Challenges & Operational Complexity	Strive for a Regional Solution
<b>SENSITIVITY RANKING</b>			
1	2	3	6
2	1	4	1
8	5	7	2
6	7	2	3
5	8	1	4
3	3	5	5
4	4	6	7
7	5	8	8

Kennedy/Jenks Consultants



## QUESTIONS

Speakers:

Dawn Taffler	<a href="mailto:DawnTaffler@KennedyJenks.com">DawnTaffler@KennedyJenks.com</a>
Brian Pecson	<a href="mailto:brianp@trusselltech.com">brianp@trusselltech.com</a>
Eddy Teasdale	<a href="mailto:EddyTeasdale@KennedyJenks.com">EddyTeasdale@KennedyJenks.com</a>
Melanie Tan	<a href="mailto:MelanieTan@KennedyJenks.com">MelanieTan@KennedyJenks.com</a>

Kennedy/Jenks Consultants



## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### Scoring and Ranking Workshop

**1 June 2017 from 10 am – 12:30 pm**

**Location:** 809 Center Street California Street Santa Cruz 95060

*Public Work Conference Room (aka Temp in Finance Room 100)*

*Conf Call - (855) 813-2486 Code - 2484*

Desktop Sharing - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Workshop Objective:** Review alternatives, discuss preliminary scoring and ranking, obtain consensus on recommended alternative (or Phased Projects) for further development.

---


#### **PART I: Overview of Alternatives and Screening Approach** **10:00 am to 10:45 am**

1. High Level Review of Alternatives (maps, facilities and costs) (K/J)
2. Review of Screening Criteria & Guidance (K/J)
3. Approach to Scoring, Weighting and Ranking (adjustments made to Criteria) (K/J)

#### **PART II: Discuss Preliminary Results and Solicit Input** **10:45 am to 12:30 pm**

4. Discuss Outcome of Sensitivity Analysis (K/J)
  - a. Projects that consistently rose to the top and why
  - b. Projects that fell to the bottom and why
  - c. Criteria most influenced by weighting
5. Finalizing RWFPS (City/All)
  - a. Putting sensitivity analysis into perspective when selecting project
  - b. Discuss and select what projects will be evaluated in Financial Analysis Phase 1.
  - c. Discuss how project alternative section will frame the next steps with regard to further financial analysis, potential to phase projects, potential for other (not selected) projects to be part of a water supply portfolio
6. Next Steps Beyond the RWFPS (City/All)
  - a. Parallel projects pursued by different departments/regional entities
  - b. Near-term vs Long-term pursuits
  - c. Nexus with WSAC Work (Phase 2 work for Corona and Raftelis is creating water supply portfolio(s))







# City of Santa Cruz Recycled Water Facilities Planning Study

## Scoring and Ranking Workshop June 1, 2017

Meeting Location: 809 Center Street California Street  
Santa Cruz 95060  
Conf Call: (855) 813-2486 Code – 2484  
Desktop Sharing: <http://conf.kennedyjenks.com/conference/2484>




KennedyJenks Consultants



## Agenda

- Today's Workshop
- PART I: Overview of Alternatives and Screening Approach
- PART II: Discuss Preliminary Results and Solicit Input




KennedyJenks Consultants

## Today's Workshop

- **Objective:** Present an overview of alternatives, discuss preliminary scoring and ranking and identify recommended alternative for further development.
- **Goal:** Obtain consensus on recommended alternative (or Phased Projects) for further development.

Kennedy/Jenks Consultants



## PART I: Overview of Alternatives and Screening Approach

1. High Level Review of Alternatives
2. Review of Screening Criteria & Guidance
3. Approach to Scoring, Weighting and Ranking

Kennedy/Jenks Consultants

## 1. High Level Review of Alternatives


<b>NPR</b>	<ul style="list-style-type: none"><li>• Alternative 1 – Centralized Non-Potable Reuse</li><li>• Alternative 2 – Decentralized Non-Potable Reuse</li></ul>
<b>IPR</b>	<ul style="list-style-type: none"><li>• Alternative 3 – Santa Cruz Participation in SqCWD-led GRR Project</li><li>• Alternative 4 – Santa Cruz GRR Project</li><li>• Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir</li><li>• Alternative 6 – Streamflow Augmentation</li></ul>
<b>DPR</b>	<ul style="list-style-type: none"><li>• Alternative 7 – Direct Potable Reuse</li></ul>
<b>IPR</b>	<ul style="list-style-type: none"><li>• Alternative 8 – Regional GRR Project</li></ul>


Kennedy/Jenks Consultants

## Alt 1 - Centralized Non-Potable Reuse Alt 1a - PWD Title 22 Upgrade





## Alt 1 - Centralized Non-Potable Reuse Alt 1b - Maximize Tertiary Treatment






- ## Alt 3 - Santa Cruz Participation in a SqCWD-led GWRR
- **AWTF @ SqCWD Headquarters (3 Sub-alternatives)**
    - Alt 3a - Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin
    - Alt 3b - Send tertiary effluent from SCWWTF to SqCWD
    - Alt 3c - Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF
  
  - **AWTF @ Santa Cruz WWTF (2 Sub-alternatives)**
    - Alt 3d - Send advanced treated RW from SCWWTF to SqCWD
    - Alt 3e - Send advanced treated RW from SCWWTF to SqCWD,
- Kennedy/Jenks Consultants



### Alternative 3c: Secondary Effluent to SqCWD AWWP + Purified Water for NPR + GRR in the City

- **City Demand:** 2.01 mgd (2,250 AFY)
- **Use:** GRR in Beltz Wellfield + NPR ~ 11 sites
- **Major Facilities:** Advanced treatment, pipelines, PS, injection and monitoring wells, brine



**Legend:**


- AWTF
- Santa Cruz WWTP
- Irrigation Meters**
  - < 10 AFY\*
  - > 10 AFY\*
- Commercial Meters**
  - < 10 AFY\*
  - > 10 AFY\*
- City Owned Meters**
  - < 10 AFY\*
  - > 10 AFY\*
- SqCWD NPR Sites
- Secondary effluent pipeline (parallel brine line)
- AWT pipeline
- Injection well
- Pump Station
- SqCWD Production Well

*Additional hydraulic evaluation to be conducted as part of future alignment study to determine if booster pumps would be needed.*

**Non-City Demands/Uses:**  
 1.7 mgd Secondary effluent to SqCWD  
 0.005 mgd SqCWD NPR along the way

### Alternative 3d: Advanced treated RW to SqCWD + NPR along the way

- **Demand:** 0.088 mgd (88AFY)
- **Use:** NPR ~ 34 customer sites
- **Major Facilities:** Advanced treatment, pipelines, PS, brine



**Legend:**


- AWTF
- Santa Cruz WWTP
- Irrigation Meters**
  - < 10 AFY\*
  - > 10 AFY\*
- Commercial Meters**
  - < 10 AFY\*
  - > 10 AFY\*
- City Owned Meters**
  - < 10 AFY\*
  - > 10 AFY\*
- SqCWD NPR Sites
- AWT Pipeline
- NPR Distrib. Pipeline
- Pump Station
- SqCWD Production Well

*Additional hydraulic evaluation to be conducted as part of future alignment study to determine if booster pumps would be needed.*

**Non-City Demands/Uses:**  
 1.3 mgd purified water to SqCWD  
 0.005 mgd SqCWD NPR along the way

### Alternative 3e: AWPf @ SC WWTF, use purified water for NPR + GRR in the City + SqCWD GRR

- **City Demand:** 2.16 mgd (2,420 AFY)
- **Use:** GRR in Beltz Wellfield + NPR ~ 41 sites
- **Major Facilities:** Advanced treatment, pipelines, PS, injection and monitoring wells,




- Legend:**
- AWPF
  - Santa Cruz WWTF
  - Irrigation Meters**
    - < 10 AFY\*
    - > 10 AFY\*
  - Commercial Meters**
    - < 10 AFY\*
    - > 10 AFY\*
  - City Owned Meters**
    - < 10 AFY\*
    - > 10 AFY\*
  - AWT pipeline
  - NPR Distrib. Pipeline
  - Injection well
  - Pump Station
  - SqCWD Production Well

*Additional hydraulic evolution to be conducted as part of future alignment study to determine if booster pumps would be needed.*

**Non-City Demands/Uses:**  
 1.3 mgd purified water to SqCWD  
 0.005 mgd SqCWD NPR along the way

### Alt 4 - Santa Cruz GRRP Alt 4a - Santa Cruz Centralized GRRP



- Legend:**
- AWPF
  - Santa Cruz WWTF
  - Irrigation Meters**
    - < 10 AFY\*
    - > 10 AFY\*
  - Commercial Meters**
    - < 10 AFY\*
    - > 10 AFY\*
  - City Owned Meters**
    - < 10 AFY\*
    - > 10 AFY\*
  - AWT pipeline
  - NPR Distrib. Pipeline
  - Injection well
  - Pump Station
  - SqCWD Production Well

*Additional hydraulic evolution to be conducted as part of future alignment study to determine if booster pumps would be needed.*

- **Description:** independent GRRP in Purisma (Beltz Wellfield area)
- **Project Size:** 2.13 mgd (2,400 AFY)
- **Uses:** GRR in Beltz Wellfield + NPR ~37 customers sites
- **Major Facilities:** AWPf, pipelines, PS, injection and monitoring wells, brine discharge



## Alt 4 - Santa Cruz GRRP

### Alt 4b - Santa Cruz Decentralized GRRP

**Legend:**

- AWTf
- Santa Cruz WWTF

**Irrigation Meters**

- < 10 AFY\*
- > 10 AFY\*

**Commercial Meters**

- < 10 AFY\*
- > 10 AFY\*

**City Owned Meters**

- < 10 AFY\*
- > 10 AFY\*

**AWT Pipeline**

- AWT pipeline
- + Injection well
- P Pump Station
- P SqCWD Production Well

*Additional hydraulic evaluation to be conducted as part of future alignment study to determine if booster pumps would be needed.*

- Description:** independent GRRP in Purisma (Beltz Wellfield area)
- Demand:** 2.01 mgd (2,250 AFY)
- Uses:** GRR + NPR ~ 11 customers sites
- Major Facilities:** MBR/AWTF, pipelines, PS, injection and monitoring wells, brine discharge

**Kennedy/Jenks Consultants**

## Alt 5 - Surface Water Augmentation (SWA)

### Loch Lomond Reservoir

**Discharge Facility**

**~ 13 miles of conveyance pipeline**

**Graham Hill WTP**



**AWTf at or near SC WWTF**



- Description:** Augment Loch Lomond in summer months with purified water
- AWTf:** 3.2 mgd production capacity
- Annual Reuse:** 1.6 mgd (1,800 AFY)
- Uses:** SWA
- Major Facilities:** AWTf, pipelines, PS, discharge facility at reservoir, brine discharge

- AWT pipeline
- P Pump Station
- AWTf
- Drinking Water Treatment Plant


*Additional hydraulic evaluation to be conducted as part of future alignment study to determine if booster pumps would be needed.*

**Kennedy/Jenks Consultants**






## Alternative 8b: 3-Way Regional GRR Project (to serve the City, Scotts Valley and San Lorenzo Valley)



**Non-City Demands/Uses:**  
0.5 mgd GRR for SVWD/SLV (annual ave)

- Description:** Regional AWWF to produce purified water for groundwater replenishment in the Santa Margarita Groundwater Basin. Utilize existing or new production wells to serve Santa Cruz, SVWD and SLVWD
- AWWF:** 4.2 mgd capacity
- Annual City Reuse:** 3.2 mgd (3,600 AFY)
- Uses:** GRR in SMGB
- Major Facilities:** AWWF, pipelines, PS, injection/production wells, brine discharge

## Summary of Engineers Opinion of Probable Costs




Notes: The stacked bars represent the life cycle unit cost for each project (left y-axis).  
The purple dots represent the average annual reuse in SCWD's service area.  
All costs represent City facilities or the City's proportional share of regional facilities based on flow.

## 2. Review of Screening Criteria & Guidance

- Screening Categories
- Quantitative Results from Alternative Evaluation
- Guidance for Qualitative Screening Criteria


Kennedy/Jenks Consultants

## Screening Categories



- Four categories to compare alternatives
- Triple Bottom Line (TBL) approach
- Integrates engineering and operational considerations

Kennedy/Jenks Consultants



### QUANTITATIVE Results from Alternatives Evaluation

Recycled Water Delivered:	Costs:	Energy / Other:
Annual Volume (AFY)	Construction Costs (\$)	Energy (kWH/AF) of RW Delivered
Average Annual Flow (mgd)	O&M Costs (\$/yr)	GHG emissions (MT of CO <sub>2</sub> e per year)
Peak Season Deliveries (AF Summer)	Life Cycle Costs (\$/AFY)	Social Cost of Carbon (\$/MT)
Peak Flow (mgd)	Annualized Cost per Million gallons of Average year Yield (ACAYY)	Construction Footprint (SF)
Average year Yield (MG)		# and Size of Facilities

**QUANTITATIVE results were provided for each alternative (Alt Webinars Part 1-4) and used to inform qualitative scoring**

*AF = acre-feet*                      *kWH = kilowatt hour*  
*AFY = acre-feet per year*       *MT = metric ton*  
*MG = million gallons*           *CO<sub>2</sub>e = carbon dioxide equivalent*  
*mgd = million gallons per day*   *SF = square feet*

Kennedy/Jenks Consultants

## Summary of QUANTITATIVE Results

Alternative	Sub-Alt	Description	Rejected Water Delivered					Estimated Costs			Energy / Emissions								
			Original Year Annual Base (MGY)	Original Average Year (MGY)	WWTW is Available (MGY)	SW Treated (MGY)	Production (MGY)	Peak Flow (MGY)	Treatment Cost (\$/MG)	Annual Cost (\$/Yr)	Grid Cost (\$/Yr)	Estimated Delivered (MGY)	Estimated Emissions (MGY)	Total Emissions (MGY)	Total Emissions (MGY)	Population (MGY)	Population (MGY)	Population (MGY)	Population (MGY)
The Public Water	Alternative 1 - Expansion 2015-2020	AW1A	300	300	200	100	44	1.4	31	312	27,300	100	1%	1,000	0.8	0.8	3	3,700	400
	Alternative 2 - Expansion 2015-2020	AW2A	300	300	200	100	44	1.4	31	312	100	4%	4,000	3.2	3.2	12	14,800	1,600	
	Alternative 3 - Expansion 2015-2020	AW3A	300	300	200	100	44	1.4	31	312	100	8%	8,000	6.4	6.4	24	29,600	3,200	
	Alternative 4 - Expansion 2015-2020	AW4A	300	300	200	100	44	1.4	31	312	100	12%	12,000	9.6	9.6	36	45,200	4,800	
City Line Water	Alternative 1 - Expansion 2015-2020	AW1B	1,000	1,000	700	300	100	3.0	100	1,000	100,000	100	1%	1,000	0.8	0.8	3	3,700	400
	Alternative 2 - Expansion 2015-2020	AW2B	1,000	1,000	700	300	100	3.0	100	1,000	100	4%	4,000	3.2	3.2	12	14,800	1,600	
	Alternative 3 - Expansion 2015-2020	AW3B	1,000	1,000	700	300	100	3.0	100	1,000	100	8%	8,000	6.4	6.4	24	29,600	3,200	
	Alternative 4 - Expansion 2015-2020	AW4B	1,000	1,000	700	300	100	3.0	100	1,000	100	12%	12,000	9.6	9.6	36	45,200	4,800	

The Quantitative Results are used to inform the Qualitative Metrics for Screening, Scoring and Ranking Alternative Projects

Kennedy/Jenks Consultants

## QUALITATIVE Criteria for Comparing Alternatives

Categories	Alternatives Screening Criteria	Considerations for Assessing Project based on Criteria
ENGINEERING & OPERATIONAL CONSIDERATIONS	Improve Regional Water Supply	Ability to fill water supply gap, supplement supply in peak season, timeline for implementation
	Ease of Implementation	Permitability, construction complexity, flexibility for phasing and potential for expansion
	Operational Complexity	Treatment requirements and impacts to WWTF, facility siting and potential impacts to Water Department operations
ECONOMIC	Cost Effectiveness	Relative unit costs
	Financial Implementability	Relative capital costs and tradeoffs
ENVIRONMENTAL	CEQA Considerations	Potential impacts and mitigation requirements
	Potential for Environmental Enhancement	Potential to enhance ecosystem and social cost of carbon (GHG emissions)
SOCIAL	Agency Coordination, Partnerships and Agreements	Level of effort and willingness to work together
	Public acceptance	Perceived public acceptance ←
	Local disruption	During construction and ongoing maintenance

The City recognizes the importance of public acceptance and will include it in the next analysis of water supply alternatives when more information can be drawn from the community in terms of their preferences and acceptance of the different types of beneficial reuse.

### 3. Approach to Scoring, Weighting & Ranking

- Alternative projects will be **scored** from 1 to 5 for each criteria
  - ✓ Score = 5 Fully Meets Criteria
  - ✓ Score = 4 Mostly Meets Criteria
  - ✓ Score = 3 Partially Meets Criteria
  - ✓ Score = 2 Somewhat Meets Criteria
  - ✓ Score = 1 Unable to Meet Criteria
- Scores are **weighted** to provide ranking of alternative projects by themes
- Sensitivity Analysis explores how **ranking** changes with different weighting themes

Kennedy/Jenks Consultants

### Weighting Screening Criteria

Categories	Alternatives Screening Criteria	Baseline (Balanced)	Maximize Water Supply	WSAC Criteria	WSAC Values	Maximize Beneficial Reuse	Maximizing Engineering & Operational Considerations	Low Cost	Minimize Local Impacts
ENGINEERING & OPERATIONAL CONSIDERATIONS	Improve Water Supply	15%	40%	70%	55%	10%	5%	10%	10%
	Maximize Beneficial Reuse	10%	5%	0%	0%	30%	10%	5%	5%
	Ease of Implementation	10%	10%	0%	0%	10%	5%	10%	5%
	Operational Complexity	10%	5%	0%	0%	15%	45%	5%	5%
ECONOMIC	Cost Effectiveness	15%	5%	15%	15%	5%	5%	30%	5%
	Financial Implementability	15%	10%	15%	15%	5%	5%	30%	5%
ENVIRONMENTAL	CEQA Considerations	10%	10%	0%	5%	5%	5%	3%	20%
	Potential for Environmental Enhancement	5%	5%	0%	5%	10%	10%	2%	20%
SOCIAL	Agency Coordination, Partnerships and Agreements	5%	5%	0%	5%	5%	5%	3%	5%
	Local Disruption	5%	5%	0%	0%	5%	5%	2%	20%
		100%	100%	100%	100%	100%	100%	100%	100%

**“THEMES”** Developed to support a sensitivity analysis to see how weighting criteria impacts ranking

Kennedy/Jenks Consultants



## Alternative Project Raw Scores

Categories			ENGINEERING & OPERATIONAL CONSIDERATIONS								ECONOMIC		ENVIRONMENTAL			SOCIAL		TOTAL		
Alternatives Screening Criteria			Improve Water Supply		Maximize Beneficial Reuse		Ease of Implementation				Operational Complexity		Cost Effectiveness	Financial Feasibility	CEQA Considerations	Potential for Environmental Enhancement	Agency Coordination, Partnerships and Agreements	Local Disruption	Total Raw Score (max 100)	
Alternative	Sub-Alt	Description	Supply/Use	Storage	Reuse/Conserve	Project/Alternative	Feasibility	Construction	Operation	M&O	Water Dept	Net Cost	Capital	Impacts/Mitigation	Jobs/Use	Cons.	Local/Outgroups	Number of Facilities		
Alternative 1 - Centralized Non-Potable Reuse	1a	Santa Cruz FWD-Tilt 22 Upgrades	3	5	1	5	5	5	5	5	5	5	5	5	2	5	5	5	68.0	
	1b	Reimburse tertiary treatment and reuse in the City	2	4	2	3	5	3	3	3	5	5	2	4	4	2	5	5	4	58.0
Alternative 2 - Decentralized Non-Potable Reuse	2	10 Santa Cruz satellite treatment and reuse on campus	1	4	1	3	3	3	3	3	5	2	5	2	2	5	2	3	58.0	
Alternative 3 - Santa Cruz Participation in SCQWD-led Groundwater Recharge Reuse (GRR) Project	3a	Send secondary effluent from SCWWTP to SCQWD for injection in SCQWD basin (to reuse in City)	Not analyzed because it provides no water to the City and would have no value in the scoring exercise																	
	3b	Send tertiary effluent from SCWWTP to SCQWD (save NPR users along the way)	2	4	2	2	3	4	3	3	3	4	3	2	2	3	3	3	4	57.0
	3c	Send additional secondary effluent from SCWWTP to SCQWD (AWTF and deliver purified water from SCQWD AWTF to recharge Bule Wellfield (GRR in Bule + NPR users along the way back))	4	4	4	5	4	4	4	4	4	4	3	3	2	4	3	3	3	57.0
	3d	Send purified RW from an AWTF (save SCWWTP to SCQWD - save NPR users along the way)	3	4	1	3	5	4	3	3	5	3	5	2	2	2	5	4	4	58.0
	3e	Send purified RW from an AWTF (save SCWWTP to SCQWD (GRR in Bule + NPR along the way))	4	4	4	3	4	3	4	3	4	4	3	2	3	2	4	4	3	58.0
Alternative 4 - Santa Cruz GRP	4a	Santa Cruz GRP in Bule Wellfield area with AWTF (save SCWWTP - save NPR users along the way)	4	4	4	4	4	4	4	2	4	4	3	2	3	4	5	3	58.0	
	4b	Santa Cruz in Bule Wellfield area with MBR + AWTF at DA Perath PS (save NPR users along the way)	4	3	4	4	3	3	4	1	4	4	3	3	3	3	4	2	58.0	
Alternative 5 - Surface Water Augmentation (SWA) in Loch Leimond Reservoir	5	Advanced treatment of Santa Cruz effluent for augmentation of Loch Leimond Reservoir (to NPR along the way)	4	2	3	4	2	3	4	2	1	3	2	3	3	5	3	5	47.0	
Alternative 6 - Streamflow Augmentation	6	Advanced treatment of Santa Cruz effluent for discharge to the San Lorenzo River (to Tal Sitoli Division for NPR users along the way)	3	2	3	4	1	4	4	2	1	4	2	3	3	4	5	4	49.0	
Alternative 7 - Direct Potable Reuse	7	Raw Water Bleedoff at Graham Hill WTP (via Coast PS or other point of bleedoff)	5	1	5	4	2	3	4	2	2	5	2	3	1	3	5	3	48.0	
Alternative 8 - Regional GRP	8a	Regional GRP in the Santa Margarita OW Basin to serve the City, Scotts Valley, Sequoia Creek, and San Lorenzo Valley	4	1	5	5	3	2	5	4	3	4	2	1	3	1	4	3	58.0	
	8b	Regional GRP in the Santa Margarita OW Basin to serve the City, Scotts Valley and San Lorenzo Valley	4	1	5	5	3	2	5	4	3	4	2	1	3	2	4	3	58.0	

Kennedy/Jenks Consultants

## Sensitivity Analysis

- Addresses variation in different perspectives by artificially increasing weighting for certain categories or criteria.
- Multiple percentages from Weighting Themes by Alternative Project Raw Scores
- Conditional shading shows GREEN as top scoring/top ranking and RED as bottom scoring/bottom ranking of all projects.

Category	Weighting Theme	Alternative 1	Alternative 2	Alternative 3	Alternative 4	Alternative 5	Alternative 6	Alternative 7	Alternative 8
Engineering & Operational Considerations	Improve Water Supply	20%	40%	20%	20%	20%	20%	20%	20%
	Maximize Beneficial Reuse	10%	10%	10%	10%	10%	10%	10%	10%
	Ease of Implementation	10%	10%	10%	10%	10%	10%	10%	10%
	Operational Complexity	10%	10%	10%	10%	10%	10%	10%	10%
Economic	Cost Effectiveness	10%	10%	10%	10%	10%	10%	10%	10%
	Financial Feasibility	10%	10%	10%	10%	10%	10%	10%	10%
Environmental	CEQA Considerations	10%	10%	10%	10%	10%	10%	10%	10%
	Potential for Environmental Enhancement	10%	10%	10%	10%	10%	10%	10%	10%
	Agency Coordination, Partnerships and Agreements	10%	10%	10%	10%	10%	10%	10%	10%
Social	Local Disruption	10%	10%	10%	10%	10%	10%	10%	10%
	Number of Facilities	10%	10%	10%	10%	10%	10%	10%	10%

Alternative	Engineering & Operational Considerations	Economic	Environmental	Social	Total Raw Score
Alternative 1	68.0	58.0	58.0	58.0	58.0
Alternative 2	58.0	58.0	58.0	58.0	58.0
Alternative 3	57.0	58.0	58.0	58.0	58.0
Alternative 4	58.0	58.0	58.0	58.0	58.0
Alternative 5	47.0	58.0	58.0	58.0	58.0
Alternative 6	49.0	58.0	58.0	58.0	58.0
Alternative 7	48.0	58.0	58.0	58.0	58.0
Alternative 8	58.0	58.0	58.0	58.0	58.0

Alternative	Engineering & Operational Considerations	Economic	Environmental	Social	Total Raw Score
Alternative 1	68.0	58.0	58.0	58.0	58.0
Alternative 2	58.0	58.0	58.0	58.0	58.0
Alternative 3	57.0	58.0	58.0	58.0	58.0
Alternative 4	58.0	58.0	58.0	58.0	58.0
Alternative 5	47.0	58.0	58.0	58.0	58.0
Alternative 6	49.0	58.0	58.0	58.0	58.0
Alternative 7	48.0	58.0	58.0	58.0	58.0
Alternative 8	58.0	58.0	58.0	58.0	58.0

Kennedy/Jenks Consultants

**BREAK**

Kennedy/Jenks Consultants

**PART II:**  
**Overview of Alternatives and  
Screening Approach**

4. Discuss Outcome of Sensitivity Analysis
5. Finalizing the RWFPS
6. Next Steps Beyond the RWFPS

Kennedy/Jenks Consultants

## 4. Outcome of Sensitivity Analysis

- a. Projects that consistently rose to the top
- b. Projects that fell to the bottom
- c. Criteria most influenced by weighting

Kennedy/Jenks Consultants

## Outcome of Ranking and Sensitivity Analysis

Summary of Alternative Project Ranking and Sensitivity Analysis			Baseline (Balanced)	Maximize Water Supply	WSPC Criteria	WSPC Values	Maximize Beneficial Reuse	Maximize Engineering & Operational Considerations	Low Cost	Maximize Local Impacts
Alternative	Sub-Alt #	Description	SENSITIVITY RANKING							
Alternative 1 – Centralized Non-Potable Reuse	1a	Santa Cruz PWD Title 22 Upgrades	1	1	4	1	1	1	1	1
	1b	Maximize tertiary treatment and reuse in the City	4	5	8	7	7	2	10	2
Alternative 2 – Decentralized Non-Potable Reuse	2	UC Santa Cruz satellite treatment and reuse on campus	5	7	11	11	8	5	6	3
Alternative 3 – Santa Cruz Participation in SqCWD led Groundwater Recharge Reuse (GRR) Project	3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (no reuse in City)	Not Analyzed							
	3b	Send tertiary effluent from SCWWTF to SqCWD (serve NPR users along the way)	2	6	6	5	9	3	2	4
	3c	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF to recharge Beltz Wellfield (GRR in Beltz + NPR users along the way back)	7	4	3	4	2	4	9	9
	3d	Send purified RW from an AWTF at/near SCWWTF to SqCWD (serve NPR users along the way)	8	8	9	9	12	6	3	5
	3e	Send purified RW from an AWTF at/near SCWWTF to SqCWD (GRR in Beltz + NPR along the way)	6	3	1	3	6	7	5	7
Alternative 4 – Santa Cruz GRRP	4a	Santa Cruz GRR in Beltz Wellfield area with AWTF at/near SCWWTF (Serve NPR users along the way)	3	2	1	2	3	8	4	5
	4b	Santa Cruz in Beltz Wellfield area with MBR + AWTF at DA Buxath PS (Serve NPR users along the way)	9	9	5	6	10	11	7	12
Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir	5	Advanced treatment of Santa Cruz effluent for augmentation of Loch Lomond Reservoir (no NPR along the way)	14	11	10	10	14	14	14	10
Alternative 6 – Streamflow Augmentation	6	Advanced treatment of Santa Cruz effluent for discharge to the San Lorenzo River d/s of Tail Street Diversion (no NPR users along the way)	13	13	12	11	13	13	13	8
Alternative 7 – Direct Potable Reuse	7	Raw Water Blending at Graham Hill WTP (via Coast PS or other point of blending)	10	10	7	8	11	12	8	13
Alternative 8 – Regional GRRP	8a	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley, Soquel Creek and San Lorenzo Valley	12	14	12	14	5	10	12	14
	8b	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley and San Lorenzo Valley	11	12	12	13	4	9	11	11

## Projects That Consistently Rose to the Top

Summary of Alternative Project Ranking and Sensitivity Analysis			TOP 4 RANKING PROJECTS			
			1	2	3	4
Alternative	Sub-Alt #	Description	Count # of Times RANKED Occurs			
Alternative 1 – Centralized Non-Potable Reuse	1a	Santa Cruz PWD Title 22 Upgrades	7	7	7	7
	1b	Maximize tertiary treatment and reuse in the City	7	7	7	7
Alternative 2 – Decentralized Non-Potable Reuse	2	UC Santa Cruz satellite treatment and reuse on campus			1	
	3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (no reuse in City)				
Alternative 3 – Santa Cruz Participation in SqCWD led Groundwater Recharge Reuse (GRR) Project	3b	Send tertiary effluent from SCWWTF to SqCWD (serve NPR users along the way)	2	2	1	1
	3c	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF to recharge Beltz Wellfield (GRR in Beltz + NPR users along the way back)	7	7	7	3
	3d	Send purified RW from an AWTF at/linear SCWWTF to SqCWD (serve NPR users along the way)			1	
	3e	Send purified RW from an AWTF at/linear SCWWTF to SqCWD (GRR in Beltz + NPR along the way)	1		2	
	4a	Santa Cruz GRR in Beltz Wellfield area with AWTF at/linear SCWWTF (Serve NPR users along the way)	7	2	2	1
Alternative 4 – Santa Cruz GRRP	4b	Santa Cruz in Beltz Wellfield area with MBR + AWTF at DA Pirath PS (Serve NPR users along the way)				
Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir	5	Advanced treatment of Santa Cruz effluent for augmentation of Loch Lomond Reservoir (no NPR along the way)				
Alternative 6 – Streamflow Augmentation	6	Advanced treatment of Santa Cruz effluent for discharge to the San Lorenzo River d/s of Tail Street Diversion (no NPR users along the way)				
Alternative 7 – Direct Potable Reuse	7	Raw Water Blending at Graham Hill WTP (via Coast PS or other point of blending)				
	8a	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley, Soquel Creek and San Lorenzo Valley				
Alternative 8 – Regional GRRP	8b	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley and San Lorenzo Valley				1

**NPR:**

- ✓ Santa Cruz PWD Title 22 Upgrades
- ✓ Maximize Tertiary Treatment

**IPR:**

- ✓ Alt 3b Send tertiary to SqCWD for NPR along the way
- ✓ Alt 3c SqCWD led GRR in Purisma with AWTF at Soquel
- ✓ Alt 3e SqCWD led GRR in Purisma with AWTF at SC WWTF
- ✓ Alt 4a City led GRR in Purisma

Kennedy/Jenks Consultants

## Projects That Consistently Drop to the Bottom

Summary of Alternative Project Ranking and Sensitivity Analysis			BOTTOM 2 RANKING PROJECTS	
			13	14
Alternative	Sub-Alt #	Description	Second to Last	Last
Alternative 1 – Centralized Non-Potable Reuse	1a	Santa Cruz PWD Title 22 Upgrades		
	1b	Maximize tertiary treatment and reuse in the City		
Alternative 2 – Decentralized Non-Potable Reuse	2	UC Santa Cruz satellite treatment and reuse on campus		
	3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (no reuse in City)		
Alternative 3 – Santa Cruz Participation in SqCWD led Groundwater Recharge Reuse (GRR) Project	3b	Send tertiary effluent from SCWWTF to SqCWD (serve NPR users along the way)		
	3c	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF to recharge Beltz Wellfield (GRR in Beltz + NPR users along the way back)		
	3d	Send purified RW from an AWTF at/linear SCWWTF to SqCWD (serve NPR users along the way)		
	3e	Send purified RW from an AWTF at/linear SCWWTF to SqCWD (GRR in Beltz + NPR along the way)		
	4a	Santa Cruz GRR in Beltz Wellfield area with AWTF at/linear SCWWTF (Serve NPR users along the way)		
Alternative 4 – Santa Cruz GRRP	4b	Santa Cruz in Beltz Wellfield area with MBR + AWTF at DA Pirath PS (Serve NPR users along the way)		
Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir	5	Advanced treatment of Santa Cruz effluent for augmentation of Loch Lomond Reservoir (no NPR along the way)		1
Alternative 6 – Streamflow Augmentation	6	Advanced treatment of Santa Cruz effluent for discharge to the San Lorenzo River d/s of Tail Street Diversion (no NPR users along the way)	5	
Alternative 7 – Direct Potable Reuse	7	Raw Water Blending at Graham Hill WTP (via Coast PS or other point of blending)	7	
	8a	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley, Soquel Creek and San Lorenzo Valley		3
Alternative 8 – Regional GRRP	8b	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley and San Lorenzo Valley	7	

**IPR:**

- ✓ Alt 5: SWA
- ✓ Alt 6: Streamflow Augmentation
- ✓ Alt 7: DPR
- ✓ Alt 8a: 4-Way Regional GRRP

Kennedy/Jenks Consultants

### Results Most Influenced by Weighting

Results	Directly Impacted Criteria	# of Criteria Influenced	% of Total Weighting <i>(Average of Themes)</i>
<b>Annual Volume of Reuse in City</b>	Water Supply, Beneficial Reuse, Cost Effectiveness, Env Enhancement	4	54%
<b>Costs</b>	Cost Effectiveness, Financial Implementability	2	24%
<b>#/Size of New Facilities</b>	Cost Effectiveness, Financial Implementability, Ease of Implementation, CEQA, Env Enhancement, Local Disruption	6	51%
<b>Need for Advanced Treatment</b>	Cost Effectiveness, Financial Implementability, Operational Complexity, Local Disruption	3	40%

Kennedy/Jenks Consultants

- ### Ranking Most Affected by Weighting Theme
- **High Volume Reuse Projects** dominate **WSAC Criteria and WSAC Values** weighting themes (which only give 0-5% weight to other factors)
  - **DPR and Regional GRRPs** score higher from a **Maximizing Beneficial Reuse** perspective
  - Projects that **increase City responsibilities** for O&M rank low for **Maximizing Eng/Ops Considerations**
  - **NPR Projects** rank higher for Low Cost and **Minimize Local Impacts** weighting themes
- Kennedy/Jenks Consultants

## 5. Finalizing RWFPS

- a. Putting sensitivity analysis into perspective when selecting project
- b. Discuss and select what projects will be evaluated in Financial Analysis Phase 1.
- c. Discuss how project alternative section will frame the next steps with regard to
  - ✓ further financial analysis,
  - ✓ potential to phase projects,
  - ✓ potential for other (not selected) projects to be part of a water supply portfolio

Kennedy/Jenks Consultants

### Selection of Project(s) for Financial Analysis Phase 1


Summary of Alternative Project Ranking and Sensitivity Analysis			RANKING for Sensitivity Analysis									Average RANKING for All Sensitivity Analysis
			Baseline (Baseline)	Maximize Water Supply	WSAC Costs	WSAC Values	Maximize Beneficial Reuse	Maximize Engineering & Operational Considerations	Low Cost	Minimize Local Impacts		
Alternative	Sub-Alt #	Description	SENSITIVITY RANKING									
Alternative 1 – Centralized Non-Potable Reuse	1a	Santa Cruz PWD Title 22 Upgrades	1	1	6	5	1	1	1	1	1	
	1b	Maximize tertiary treatment and reuse in the City	9	8	13	11	11	3	13	3	9	
Alternative 2 – Decentralized Non-Potable Reuse	2	UC Santa Cruz satellite treatment and reuse on campus	2	6	9	9	5	5	3	2	6	
Alternative 3 – Santa Cruz Participation in SqCWD led Groundwater Recharge Reuse (GRR) Project	3a	Send secondary effluent from SCWWTF to SqCWD for injection in SqCWD basin (no reuse in City)	15	13	15	15	14	7	15	13	15	
	3b	Send tertiary effluent from SCWWTF to SqCWD (serve NPR users along the way)	4	7	6	7	10	2	2	4	5	
	3c	Send additional secondary effluent from SCWWTF to SqCWD AWTF and deliver purified water from SqCWD AWTF to recharge Beltz Wellfield (GRR in Beltz + NPR users along the way back)	3	2	1	3	2	4	5	9	2	
	3d	Send purified RW from an AWTF at/near SCWWTF to SqCWD (serve NPR users along the way)	7	10	9	9	13	6	4	5	8	
	3e	Send purified RW from an AWTF at/near SCWWTF to SqCWD (GRR in Beltz + NPR along the way)	6	4	1	2	4	8	7	6	4	
Alternative 4 – Santa Cruz GWRR Project	4a	Santa Cruz GRR in Beltz Wellfield area with AWTF at/near SCWWTF (Serve NPR users along the way)	5	3	1	1	3	9	6	7	3	
	4b	Santa Cruz in Beltz Wellfield area with MBR + AWTF at DA Porath PS (Serve NPR users along the way)	8	5	1	4	7	11	8	12	7	
Alternative 5 – Surface Water Augmentation (SWA) in Loch Lomond Reservoir	5	Advanced treatment of Santa Cruz effluent for augmentation of Loch Lomond Reservoir (no NPR along the way)	13	14	14	12	15	15	11	10	13	
Alternative 6 – Streamflow Augmentation	6	Advanced treatment of Santa Cruz effluent for discharge to the San Lorenzo River d/s of Tail Street Diversion (no NPR users along the way)	10	11	8	8	12	14	9	7	11	
Alternative 7 – Direct Potable Reuse	7	Raw Water Blending at Graham Hill WTP (via Coast PS or other point of blending)	11	9	5	6	8	13	10	14	10	
Alternative 8 – Regional GWRR Project	8a	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley, Soquel Creek and San Lorenzo Valley	14	15	11	14	9	12	14	15	14	
	8b	Regional GRRP in the Santa Margarita GW Basin to serve the City, Scotts Valley and San Lorenzo Valley	12	12	11	13	6	10	12	11	12	

## 6. Next Steps Beyond the RWFPS

- a. Parallel projects pursued by different departments/regional entities
- b. Near-term vs Long-term pursuits
- c. Nexus with WSAC Work (Phase 2 work for Corona and Raftelis is creating water supply portfolio(s))

Kennedy/Jenks Consultants


## Schedule





# OPEN DISCUSSION


Kennedy/Jenks Consultants



# QUESTIONS

Kennedy/Jenks:	Dawn Taffler	<a href="mailto:DawnTaffler@KennedyJenks.com">DawnTaffler@KennedyJenks.com</a>
	Melanie Tan	<a href="mailto:MelanieTan@KennedyJenks.com">MelanieTan@KennedyJenks.com</a>
Corona Env:	Bob Raucher	<a href="mailto:BRaucher@CoronaEnv.com">BRaucher@CoronaEnv.com</a>
	Jim Henderson	<a href="mailto:jhenderson@coronaenv.com">jhenderson@coronaenv.com</a>
GHD:	Pat Collins	<a href="mailto:Pat.Collins@ghd.com">Pat.Collins@ghd.com</a>
Trussell:	Brian Pecson	<a href="mailto:brianp@trusselltech.com">brianp@trusselltech.com</a>
Merritt Smith:	Dave Smith	<a href="mailto:davesmith@merritt-smith.com">davesmith@merritt-smith.com</a>

Kennedy/Jenks Consultants 48







## Santa Cruz Regional Recycled Water Facilities Planning Study (RWFPS)

---

### WEBINAR

### Recommended Project and Financing and Revenue Considerations 17 July 2017 from 10 am to 12:00 pm

Conf Call - (855) 813-2486 Code – 2484

Web Meeting - <http://conf.kennedyjenks.com/conference/2484>

---

### AGENDA

**Overall Webinar Objective:** Present Recommended Projects with updated maps and costs. Present considerations for implementation, operations, financing and options for a future revenue program.

**Goal:** Obtain consensus on considerations and assumptions for Recommended Plan, Construction Financing Plan and Revenue Program to include in Sections 9 & 10 of the RWFPS

**Caveat:** Sections 9 & 10 are structured to meet the SWRCB Grant Requirements. Many of the elements related to the implementation plan, operation plan, financing and revenue program will require additional studies, agreements and design details to confirm. This webinar and the RWFPS will provide an overview of considerations and next steps to develop the City's recycled water program.

---


1. **Today's Webinar**
2. **Recommended Project**
  - a. Phase 1: SCPWD Title 22 Project ..... Ann/Dan (PWD)
  - b. Phase 2: BayCycle Project
  - c. Other Reuse Opportunities
3. **Implementation Plan Considerations**
4. **Operation Plan Considerations**
5. **Financing and Revenue Considerations** ..... Andrea (RFC)
6. **Next Steps**

**City of Santa Cruz  
Recycled Water Facilities Planning  
Study**

WEBINAR  
Recommended Projects and  
Financing and Revenue Considerations  
July 17, 2017

Conf Call: (855) 813-2486 Code – 2484  
Desktop Sharing: <http://conf.kennedyjenks.com/conference/2484>  
Recording: <http://conf.kennedyjenks.com/recording/6180669>

*\* Includes amended notes to reflect discussion at webinar*

 Kennedy/Jenks Consultants

**Agenda**

- **Recommended Project**
  - Phase 1: SCPWD Title 22 Project
  - Phase 2: BayCycle Project
  - Other Reuse Opportunities
- **Implementation Plan Considerations**
- **Operation Plan Considerations**
- **Financing and Revenue Considerations**

Kennedy/Jenks Consultants


## Today's Webinar

- **Objective:** Present Recommended Projects with updated maps and costs. Present considerations for implementation, operations, financing and options for a future revenue program.
- **Goal:** Obtain consensus on considerations and assumptions for Recommended Plan, Construction Financing Plan and Revenue Program to include in Sections 9 & 10 of the RWFPS


Kennedy/Jenks Consultants

## Today's Webinar

- Sections 9 & 10 are structured to meet the SWRCB Grant Requirements.
- Many of the elements related to the implementation plan, operation plan, financing and revenue program will require additional studies, agreements and design details to confirm.
- This webinar and the RWFPS will provide an overview of considerations and next steps to develop the City's recycled water program.



Kennedy/Jenks Consultants



### Recommended Projects

- **Phase 1: SCPWD Title 22 Project** – implement a near-term non-potable reuse project to meet in-plant demands, develop a bulk water station and serve the near-by La Barranca Park.
- **Phase 2: BayCycle Project** – expand the Phase 1 project to increase production and non-potable reuse to serve customers along Bay Street including UCSC and other City customers

Phase 1 and 2 are the focus of the Recommended Project and Construction Financing Plan for the RWFPS


Kennedy/Jenks Consultants

## Other Reuse Opportunities

1. **Coordination with Pure Water Soquel** – continue to work closely with SqCWD to support the Pure Water Soquel project including, but not limited to, the delivery of source water and considerations for benefits of shared infrastructure.
2. **Explore GRR in Mid-County Basin** – to replenish the **Mid-County Basin** through a collaborative project with Pure Water Soquel or as an independent City led project
3. **Explore GRR in Santa Margarita Basin** – continue regional discussions related to the benefits and limitations for a Regional GRRP in the SMGB, which has the potential to make the region more resilient in the long term.

Represent longer term efforts that will require more time to work collaboratively with regional partners and/or future studies to confirm the viability of groundwater replenishment.

## Phase 1: SCPWD Title 22 Project



## Phase 1: SCPWD Title 22 Project

- Purpose of the project is to enhance the robustness of the reclaimed water system and provide Title 22 water for off-site use.
- Estimated Demands

Demands	Average (gpd)	Peak (gpd)
In-plant Use	126,000	193,000
Bulk Water Station Use*	4,800	11,000
La Barranca Park**	800	2,700
Neary Park**	800	3,800
<b>TOTAL</b>	<b>132,400</b>	<b>210,500</b>

\* Total average demand from 3 bulk water stations in 2014

\*\* Average irrigation demand between 2012-2014

Kennedy/Jenks Consultants

## Phase 1: SCPWD Title 22 Project

- Key component upgrades
  - Upgrade treatment with Title 22 pasteurization unit
  - Convert existing chlorine contact tank to storage
  - New distribution system pump station and pipelines
  - New bulk water station
  - New dedicated pipeline to 2 water tank
  - Upgrade secondary effluent booster pumps

Kennedy/Jenks Consultants

## Phase 1: SCPWD Title 22 Project

- **Funding**
  - \$250,000 in FY 2018 WWTF CIP
  - Water /Public Works FY 2019 Funds TBD
- **Next Steps**
  - Title 22 Engineering Report
  - Environmental Documents
  - Design of Treatment System Upgrades
  - Design of Distribution System

Kennedy/Jenks Consultants

## Phase 1: Summary of Costs

Facility Component	Est. Loaded Cost (\$)
Treatment	730,000
Pipelines	380,000
Pump Stations	130,000
Storage	0
Site Retrofit Costs	20,000
<b>Total Construction Cost (\$)</b>	<b>1,260,000</b>
<b>Annual O&amp;M Costs (\$/year)</b>	<b>\$250,000</b>


Annual Life Cycle Unit Cost (\$/AFY) = \$2,200

\* Based on reuse of 0.13 mgd (150 AFY) of Title 22 water

*Facility Costs at the WWTF to be differentiated from those off-site (capital and O&M)*

Kennedy/Jenks Consultants

## Phase 2: BayCycle Project



## Phase 2: Summary of Costs

Facility Component	Est. Loaded Cost (\$)
Treatment	220,000
Pipelines	7,380,000
Pump Stations	690,000
Storage	380,000
Site Retrofit Costs	3,030,000
<b>Total Construction Cost (\$)</b>	<b>11,700,000</b>
<b>Annual O&amp;M Costs (\$/year)</b>	<b>\$320,000</b>

Annual Life Cycle Unit Cost = \$5,400

\* Based on annual demand of 0.14 mgd (160 AFY) for City and UCSC customers

*Facility Costs on campus to be differentiated from those off-campus (capital and O&M)*



## Implementation Plan Considerations

Considerations	Phase 1	Phase 2
<b>Coordination</b>	SCPWD and SCWD	City and UCSC
<b>Ability and Timing of Users</b>	SCWWTF = Ready to connect Bulk Water Station = New Park = Retrofit needed	City customers = retrofit UCSC = Agreement and retrofits
<b>Water Recycling Requirements</b>	Title 22 Report, Title 17 cross-connection, Supervisor training, monitoring and reporting, etc.	
<b>Commitments from Potential Users</b>	Memo or Letter of intent to use from SCPWD, SCWD and City Parks	Letter of interest from UCSC; develop agreement prior to initial design work or other financial commitments
<b>Water Rights Impact</b>	None required as Water Code Section 2010 assigns ownership of the treated wastewater to the owner of the wastewater treatment plant.	
<b>Permits, Right-of-Way, Design and Construction</b>	RWQCB/DDW permits for production and distribution, NOI for RW program, obtain ROW for pipelines and infrastructure, design, construction & environmental	


**KennedyJenks Consultants**

## Anticipated Phase 1 Schedule

Task and Key Deliverables	2017				2018				2019				2020			
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4
<b>Pre-design</b>																
<i>Confirm Pipeline Alignment and Facility Sizing Assumptions</i>																
<i>Utility Location, Survey, Geotech</i>																
<b>Permitting</b>																
<i>RWQCB WWTF NPDES Permit Update <sup>1</sup></i>																
<i>CEQA Compliance (Mitigated Negative Declaration assumed)</i>																
<i>RWQCB/DDW Permit Requirements for RW Production/Distribution/Use <sup>2,3</sup></i>																
<b>Design</b>																
<i>SCWWTF Treatment and Distribution System Upgrades (ROW if-needed)</i>																
<i>Off-Plant Distribution Pipeline (if independent from above)</i>																
<i>Retrofit Design for City Parks and Bulk Fill Station</i>																
<b>Construction</b>																
<i>Bid and Award (treatment, distribution, retrofit)</i>																
<i>SCWWTF Treatment and Distribution System Upgrades (ROW if-needed)</i>																
<i>Off-Plant Distribution Pipeline (if independent from above)</i>																
<i>Retrofit City Parks and Build Bulk Fill Station</i>																
<b>Commissioning</b>																
<i>Cross Connection Testing</i>																
<i>Startup</i>																

<sup>1</sup> Changes at the WWTF will likely trigger an update to the NPDES permit even if discharge limits don't change.  
<sup>2</sup> Per SWRCB Order WQ 2016-0068-DDW [http://www.waterboards.ca.gov/board\\_decisions/adopted\\_orders/water\\_quality/2016/wqo2016\\_0068\\_ddw.pdf](http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2016/wqo2016_0068_ddw.pdf)  
<sup>3</sup> Includes Title 22 Engineering Report, Retrofit Report and Notice of Intent for Uses.

**KennedyJenks Consultants**



## Operation Plan Considerations

Considerations	Phase 1	Phase 2
<b>Responsible Parties</b>	Water Dept (SCWD), Public Works (SCPWD), City Parks Supervisor	City, UCSC, Customer Site Supervisors
<b>Equipment Operations &amp; Maintenance</b>	SCPWD = Title 22 upgrades SCPWD = on-site distribution SCPWD/SCWD <sup>1</sup> = off-site distribution SCPWD/SCWD <sup>1</sup> = bulk water station SCWD = City Parks SCWD = residential fill station <sup>2</sup>	SCWD = distribution SCWD = City customers UCSC = campus customers
<b>Monitoring</b>	SCPWD = production SCWD = distribution/customers	SCPWD = production SCWD = distribution & customers UCSC = Campus customers
<b>Irrigation Scheduling</b>	SCWD = work with customers	SCWD = work with customers UCSC = Campus customers

<sup>1</sup> City department lead for facilities outside of the WWTF to be determined

<sup>2</sup> Residential fill station could be initiated as part of Phase 1 or 2

Water Department to be the "face" of RW for customers

## Financing and Revenue Considerations



Kennedy/Jenks Consultants

## Construction Financing Options

- PAYGO (Pay-as-you-go)
  - Water, Recycled Water, or Wastewater
- Debt Financing
- Grants / Loans
- Capacity Fees
- Combination of two or more





Kennedy/Jenks Consultants

## Potential Funding Mechanisms PAYGO vs Debt

PAYGO	
Advantages	Disadvantage
<ul style="list-style-type: none"> <li>Save on interest charges</li> <li>Eliminate cost of issuance</li> <li>No bond covenants to satisfy</li> <li>Projects only funded when cash is available</li> <li>Additional admin. costs are avoided</li> </ul>	<ul style="list-style-type: none"> <li>If capital costs spike - rates spike</li> <li>Capital may need to be deferred due to liquidity</li> <li>Existing customers are absorbing entire burden</li> <li>Inequity between existing / future customers</li> <li>Other needs not addressed due to CIP costs</li> </ul>

Debt	
Advantages	Disadvantage
<ul style="list-style-type: none"> <li>Favorable low interest rates</li> <li>Critical capital projects may move forward</li> <li>Achieve intergenerational equity</li> <li>Mitigate rate spikes in specific years</li> <li>Smooth out revenue adjustments</li> </ul>	<ul style="list-style-type: none"> <li>Total project cost increases due to interest and COI</li> <li>Bond coverage requires additional revenue collection</li> <li>Incurring debt may not be an option - politically</li> <li>Debt payments must be made while commodity revenue may fluctuate</li> </ul>

## Potential Funding Mechanisms Grant / Loan Funding

- Grant Funding
  - There are quite a few grants available for projects
    - ✓ SWRCB Water Recycling Funding Program
      - Research, feasibility studies, planning, and construction
    - ✓ Integrated Regional Water Mgt. Implementation Grant
    - ✓ Proposition 1
      - Regional Water Reliability, Water Recycling, Groundwater Sustainability
    - ✓ NOAA Coastal Resiliency Grants Program
  - Competitive basis, additional requirements (regulatory & administrative), timing of funds, often require ability to fund project without grants (matching funds)

Phase 1: Candidate for SRF Loan  
Phase 2: Candidate for Category III  
SWRCB Grant 25% = ~\$3M




## Financing Plan Considerations

It's important to look at the entire picture

- Objectives
  - ✓ Meet Regulations, New Water Supply, Reliability/Sustainability
- Assessing Revenue Needs
  - ✓ Capital Costs (Grants / Debt / PAYGO)
  - ✓ Annual Operations and Maintenance Costs
  - ✓ Conversion Costs (user hookup)
  - ✓ Depreciation recovery for ongoing reinvestment
- Revenue Recovery
  - ✓ Cost of Service
  - ✓ Interfund Transfers (Cost Sharing between Enterprises)
  - ✓ Type of capital expense may dictate funding mechanism



KennedyJenks Consultants

## What is the Industry Standard / Practice?

- Historically, recycled water rates have been pegged as percent of potable water rates (75% - 95%)
  - Legacy approach; not necessarily defensible
  - Provides financial incentive to use recycled water; otherwise, no reason to switch
  - RFC recommends a cost of service approach providing similar result (i.e. 75% -95% of potable)
    - ✓ Cost sharing required
    - ✓ Compliant with Proposition 218 & Proposition 26



KennedyJenks Consultants

## Legal Case Study:

- **Griffith vs. Pajaro Valley Water Mgt. Agency (2013)**
  - Agency included revenue requirements related to recycled water in the potable water rates as a groundwater augmentation charge
  - Plaintiff argued rates violated the proportionality requirements and that recycled water was not available to ALL customers
  - Ruling: Groundwater augmentation does NOT exceed the proportionate cost of providing service because ALL groundwater users benefit from the agencies groundwater management activities
    - ✓ Charges may be used to fund debt service
    - ✓ Charges may be used to fund recycled water service



Kennedy/Jenks Consultants

## Legal Case Study:

- **CTA vs. City of San Juan Capistrano**
  - Proposition 218 **does** allow public water agencies to pass on to their customers the capital costs of improvements to provide additional water, including building a recycling system
  - Recycled water is a **new source** of water
  - Government Code § 53750(m) – water is part of a holistic distribution system



Kennedy/Jenks Consultants

## Why do we need recycled water?

- **Is it for additional water supply/reliability? If so:**
  - Expansion of purple pipe may be covered through connection fees and/or potable water rates
  - Tertiary cost may be covered in the higher tiers of potable water users since their demand requires additional supply
  - Remaining operating costs recovered by recycled rates
- **Is it due to wastewater discharge requirements that require tertiary level treatment? If so:**
  - Expansion of treatment plant may be covered in wastewater connection fees or recycled water
  - Tertiary cost may be covered as part of the wastewater rates



KennedyJenks Consultants

## Why do we need recycled water?

- **Is it combination of both?**
  - Tertiary costs may be allocated to wastewater and to the higher potable water tiers
  - Purple pipe can be covered in utility capacity fees and rates
  - O&M should still be recovered from recycled water

Costs	Potable Rates	Wastewater Rates	Recycled Rates	Water Capacity Fees	Recycled Capacity Fees
<b>Tertiary</b>	Commonly	Commonly	Not usually	Commonly	Not usually
<b>Purple Pipe</b>	Commonly	No	Commonly	Commonly	Commonly
<b>Operating</b>	Not usually	No	Yes	No	No



*City to fill out this table with preliminary guidance for cost sharing.*

## What is going on in the Industry?

- El Toro Water District
  - Potable water rates have a RW component in the inefficient tiers (Tiers 3 & 4) that fund RW capital costs
  - Recycled water rates fund O&M and a portion of R&R / Debt Service
- Elsinore Valley MWD
  - Potable rates have rate components to fund RW
    - ✓ O&M is based on avoided purchased water costs
    - ✓ Capital costs are shared by future users (capacity fee), RW rates, and Potable rates for customers beyond their allocated water budget
- Fallbrook PUD
  - WW treatment plant costs (debt service) are allocated between wastewater and recycled water customers. Recycled users pay for the tertiary portion of costs.



Kennedy/Jenks Consultants

## Industry...

- Camarillo CSD
  - Relatively new enterprise
  - Potable funded Infrastructure – treated as an interfund loan with repayment occurring in future years
  - O&M covered by recycled rates
- Temescal Valley Water District
  - Mature enterprise, ~50% of total water demand is from recycled water
  - 100% of recycled revenue needs is funded from Recycled water rates
  - New recycled customers pay a recycled capacity fee

**There are lots of options and some level of flexibility, however, Projects and Policy should drive revenue recovery**



Kennedy/Jenks Consultants



## Using Data to Guide Policy Decisions

- **Phase I – PWD Title 22 Project**

- Majority of Title 22 tertiary treated water will be used within the plant
- Construction costs will be funded by the Wastewater Enterprise Fund (i.e. paid for by existing wastewater customers)
  - ✓ May consider applying for Grant/Low interest SRF Loan
- Will ongoing costs be born by wastewater customers or should recycled/potable customers share in these costs?



Kennedy/Jenks Consultants

## Using Data to Guide Policy Decisions

- **Phase 2 - BayCycle**

- Substantial Construction Costs
  - ✓ ~\$12M Construction Costs
  - ✓ Expected recycled demand ~ 160 AFY
- It may be reasonable to fund these costs via the potable water enterprise (New Water Supply)
  - ✓ However, is it feasible given the considerable potable infrastructure reinvestment already underway?
- Consider using SRF Loan (1.7% interest) and grant funding / reimbursement



Kennedy/Jenks Consultants

## Other Key Considerations

- **Phase 2 - BayCycle**
  - Timing of the project and new user connections
  - Demand Projections
    - ✓ What happens if UCSC doesn't commit or uses more/less recycled water than projected?
    - ✓ May need to consider setting up a contract rate with an annual minimum charge based on a "Use or Lose" structure
  - Keep in mind the fiscal impact of converting potable users over to recycled
    - ✓ A significant portion of Potable revenue requirements are recovered over the variable charge.
    - ✓ Recycled user candidates are currently potable customers
    - ✓ This will result in lost revenue if no adjustments are made to the potable rates



Kennedy/Jenks Consultants

## Partnerships through Contract Customers

- Major stakeholder
- Engagement starts early and customers have skin in the game
- Contract agreement outside of Prop. 218
  - Identify minimum revenue needs for project viability
  - Provides more flexibility for negotiations and agreement
  - Competitive rate may be determined for usage above minimum
  - Term for rates may be for multiple years



Kennedy/Jenks Consultants

## Long-term Projects

- Will need to be further evaluated once projects are known
- Good candidates for grant funding
  - Benefits a wider community / region
  - Supports groundwater sustainability and regional water reliability
- Pricing Policy
  - Purified recycled water likely seen as a new water source and may be priced as supplemental water supply




Kennedy/Jenks Consultants

## IPR / Groundwater Recharge

- Multiple agencies have separate charge for groundwater recharge
  - East Valley – all units of water
  - Met customers – standby charge
  - Tustin – Recharge fee by OCWD
  - Sierra Madre – New ground water recharge (current project)
  - San Diego – IPR – new project to assist with setting rates
    - ✓ Reservoir replenishment
    - ✓ Pure Water SD



Kennedy/Jenks Consultants



## OPEN DISCUSSION

Kenedy/Jenks Consultants

## QUESTIONS

Kennedy/Jenks:	Dawn Taffler	<a href="mailto:DawnTaffler@KennedyJenks.com">DawnTaffler@KennedyJenks.com</a>
	Sachi Itagaki	<a href="mailto:SachiItagaki@KennedyJenks.com">SachiItagaki@KennedyJenks.com</a>
Raftelis Financial Consultants	Andrea Boehling	<a href="mailto:aboehling@raftelis.com">aboehling@raftelis.com</a>
	Sanjay Gaur	<a href="mailto:sgaur@raftelis.com">sgaur@raftelis.com</a>
Corona Env:	Bob Raucher	<a href="mailto:BRaucher@CoronaEnv.com">BRaucher@CoronaEnv.com</a>



**Kennedy/Jenks Consultants**