



## **Downtown Library Site Re-Use Visioning Process**

April 8<sup>th</sup> – Technical Meeting

**Attendees:** City Staff from Public Works, Parks & Recreation, Planning, Fire, and the City Manager's Office.

### **Department Feedback:**

- Planning: Max height on the site is 35ft, but could go up to 50ft on parts of the site with City Council approval
- Fire Department: important to maintain access for Fire Trucks. Center Street is a key transit corridor and would be problematic to close on a regular basis. Church Street and Locust Street would be better for potential closures.
- City Manager's Office – Sustainability: consider a solar canopy. With proximity to other City owned sites might be opportunity to take advantage of net energy metering
- Parks & Recreation – Civic Auditorium: Parking and access to auditorium are important